

TRANSMISSION CONNECTION PLANNING REPORT

Produced jointly by the
Victorian Electricity Distribution Businesses
2020



Brunswick Terminal Station (Image credit: World Architecture Festival)



2020 TRANSMISSION CONNECTION PLANNING REPORT

TABLE OF CONTENTS

EXECUTIVE SUMMARY	4
1 INTRODUCTION AND BACKGROUND	13
1.1 Purpose of this report	13
1.2 Victorian joint planning arrangements for transmission connection assets	13
1.3 DBs' obligations as transmission connection planners	16
1.3.1 Victorian regulatory instruments	16
1.3.2 National Electricity Rules	17
1.3.3 Reliability incentive scheme (s-factor) for the Distribution Businesses	18
1.3.4 Role of transmission connection asset owners in delivering connection services	19
1.4 Matters to be addressed by proponents of non-network alternatives	19
1.5 Implementing Transmission Connection Projects	20
1.5.1 Land Acquisition	20
1.5.2 Connection Application to AEMO	21
1.5.3 Connection Application to AusNet Transmission Group	21
1.5.4 Town Planning Permit.....	22
1.5.5 Public Consultation Strategy	22
1.5.6 Project Implementation	23
1.5.7 Project lead times	23
1.6 Overview of Transmission Connection Planning Process.....	24
2 PLANNING STANDARDS	25
2.1 Planning standard applying to transmission connection assets	25
2.2 Overall objective of transmission connection planning	26
2.3 Overall approach to transmission planning and investment evaluation	27
2.4 VCR: Valuing supply reliability from the customers' perspective	27
2.5 Application of the probabilistic approach to transmission connection planning	30
3 CURRENT AND EMERGING PLANNING CONSIDERATIONS.....	31
3.1 Impacts of COVID-19	31
3.2 On-going industry change	32
3.3 Initiatives announced in the 2020-21 Victorian state budget.....	34
3.4 Issues arising from increased embedded generation	36
3.4.1 Transformer ratings	36
3.4.2 Impact of rooftop PV on estimates of energy at risk.....	36
3.4.3 Minimum demand and voltage management	37
3.4.4 The need for generation runback schemes	38
3.4.5 Stability issues in the West Murray area	38
3.5 Management of system fault levels	39
3.6 Managing the risk of transformer failure	40

3.7	Maintaining security of supply during major terminal station renewals	40
4	HISTORIC AND FORECAST DEMAND.....	41
5	RISK ASSESSMENT AND OPTIONS FOR ALLEVIATION OF CONSTRAINTS.....	42
5.1	Preamble	42
5.2	Interpreting “energy at risk”	43
5.3	Assessing the costs of transformer outages	44
5.4	Base reliability statistics for transmission plant	44
5.5	Availability of spare transformers	46
5.6	Treatment of Load Transfer Capability	47
5.7	Detailed risk assessments and options for alleviation of constraints, by terminal station	47
5.8	Interpreting the dates shown in the risk assessments	48
5.9	Augmentations to facilitate embedded generation connections	49
	APPENDIX: ESTIMATION OF BASIC TRANSFORMER RELIABILITY DATA AND EXAMPLE OF EXPECTED TRANSFORMER UNAVAILABILITY CALCULATION.....	50
	RISK ASSESSMENTS FOR INDIVIDUAL TERMINAL STATIONS (IN ALPHABETICAL ORDER)	55
	ALTONA/BROOKLYN TERMINAL STATION (ATS/BLTS) 66 kV	56
	ALTONA WEST TERMINAL STATION (ATS West) 66 kV	58
	BALLARAT TERMINAL STATION (BATS) 66 kV	63
	BENDIGO TERMINAL STATION (BETS) 22 kV	68
	BENDIGO TERMINAL STATION (BETS) 66 kV	69
	BROOKLYN TERMINAL STATION (BLTS) 22 kV	74
	BRUNSWICK TERMINAL STATION 22 kV (BTS 22 kV)	75
	BRUNSWICK TERMINAL STATION 66 kV (BTS 66 kV)	76
	CRANBOURNE TERMINAL STATION (CBTS)	77
	DEER PARK TERMINAL STATION (DPTS) 66 kV	84
	EAST ROWVILLE TERMINAL STATION (ERTS)	89
	FISHERMAN’S BEND TERMINAL STATION 66 kV (FBTS 66 kV)	94
	FRANKSTON TERMINAL STATION (FTS)	96
	GEELONG TERMINAL STATION (GTS) 66 kV	99
	GLENROWAN TERMINAL STATION 66 kV (GNTS 66 kV)	106
	HEATHERTON TERMINAL STATION (HTS)	107
	HEYWOOD TERMINAL STATION (HYTS) 22 kV	112
	HORSHAM TERMINAL STATION (HOTS) 66 kV	113
	KEILOR TERMINAL STATION 66 kV (KTS 66 kV)	114
	KERANG TERMINAL STATION (KGTS) 66kV & 22kV	120
	MALVERN 22 kV TERMINAL STATION (MTS 22 kV)	121
	MALVERN 66 kV TERMINAL STATION (MTS 66 kV)	122

MORWELL TERMINAL STATION 66 kV (MWTS 66 kV)	123
MOUNT BEAUTY TERMINAL STATION 66 kV (MBTS 66 kV)	128
RED CLIFFS TERMINAL STATION (RCTS) 22 kV	130
RED CLIFFS TERMINAL STATION (RCTS) 66 kV	131
RICHMOND TERMINAL STATION 22 kV (RTS 22 kV)	136
RICHMOND TERMINAL STATION 66 kV (RTS 66 kV)	137
RINGWOOD TERMINAL STATION 22 kV (RWTS 22 kV)	138
RINGWOOD TERMINAL STATION 66 kV (RWTS 66 kV)	139
SHEPPARTON TERMINAL STATION (SHTS) 66 kV	147
SOUTH MORANG TERMINAL STATION (SMTS 66 kV)	148
SPRINGVALE TERMINAL STATION (SVTS)	154
TEMPLESTOWE TERMINAL STATION (TSTS)	159
TERANG TERMINAL STATION (TGTS) 66kV	164
THOMASTOWN TERMINAL STATION 66 kV (TTS 66 kV)	169
TYABB TERMINAL STATION (TBTS)	171
WEMEN TERMINAL STATION (WETS)	175
WEST MELBOURNE TERMINAL STATION 22 kV (WMTS 22 kV)	177
WEST MELBOURNE TERMINAL STATION 66 kV (WMTS 66 kV)	178
WODONGA TERMINAL STATION (WOTS 66 kV and 22 kV)	180

EXECUTIVE SUMMARY

This document is a joint report on transmission connection planning in Victoria, prepared by the five Victorian electricity Distribution Businesses (“the DBs”)¹, in accordance with the transmission connection planning requirements of Clause 3.4 of the Victorian Electricity Distribution Code and clause 5.13.2 of the National Electricity Rules (the Rules).

Under their Electricity Distribution Licences, the DBs have responsibility for planning and directing the augmentation of the facilities that connect their distribution systems to the shared transmission network². The assets connecting the DBs’ distribution networks to the shared transmission network are known as transmission connection assets. Those assets provide prescribed transmission services in accordance with Chapter 6A of the Rules.

Apart from the connection assets at Deer Park terminal station which are owned, operated and maintained by TransGrid, the transmission assets that provide DB connection services are located within terminal stations which are owned, operated, and maintained by the transmission asset owner, AusNet Transmission Group.

The DBs apply a probabilistic planning approach to transmission connection assets, which is consistent with the approach applied by the Australian Energy Market Operator (AEMO) in planning the Victorian shared transmission network.³ That approach involves estimating the probability of a transmission plant outage occurring, and weighting the costs of such an occurrence by its probability. This calculation enables the assessment of:

- the expected amount (and value) of energy that will not be supplied under a ‘do nothing’ scenario, and
- whether it is economic to take action to reduce or eliminate the expected supply interruptions.

An important point to note about the use of a probabilistic approach is that it involves customers accepting the risk that there may be circumstances when the available terminal station capacity will be insufficient to meet demand, and significant load shedding could be required.

This report examines whether there is an emerging constraint at each terminal station and, if so, provides a description of the preferred network solution. In presenting this information, the report seeks non-network alternatives and provides an indication of the maximum annual payment that may be available for non-network proponents. It is emphasised that this report does not present the detailed investment decision analysis that is required under the RIT-T. Rather, the report presents a high-level indication of the expected balance between capacity

¹ The five DBs are: Jemena Electricity Networks (Vic) Ltd, CitiPower Pty, Powercor Australia Ltd, United Energy Distribution Pty Ltd, and AusNet Electricity Services Pty Ltd. AusNet Electricity Services is owned by AusNet Services, a diversified energy infrastructure business that also owns the Victorian electricity transmission system. Throughout this document “AusNet Transmission Group” refers to the transmission business of AusNet Services and “AusNet Electricity Services” refers to the electricity distribution business of AusNet Services.

² The shared transmission network is the main extra high voltage network that provides or potentially provides supply to more than a single point. This network includes all lines rated above 66 kV and main system tie transformers that operate at two or three voltage levels above 66 kV.

³ See: http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.pdf

and demand at each terminal station over the forecast period, and the likely investment requirements. Accordingly, the analysis in this report is presented at a high level, noting that the Regulatory Investment Test for transmission (RIT-T) will need to be undertaken prior to any investment proceeding.

The table below summarises the analysis for each terminal station. Following the summary table is a map showing the approximate locations of the existing transmission to distribution connection terminal stations. The following points should be noted in relation to the information presented in the summary table:

- For each terminal station, an indication of the potential exposure⁴ for customers under the ‘do nothing’ option is provided, in accordance with DBs’ obligations under clause 3.4 of the Victorian Electricity Distribution Code.
- The demand forecasts used in the preparation of this report are set out in the 2020 Terminal Station Demand Forecasts, which are prepared by the DBs and published alongside this report.
- Expected unserved energy estimates are provided for two forecasts of demand: the first forecast has a 10% probability of being exceeded, while the second forecast has a 50% probability of being exceeded.
- For each terminal station, the table identifies alternatives to network augmentation that may alleviate constraints.
- The analysis presented in this report may be subject to change as new information, including demand forecasts and project costs, becomes available.

In accordance with their obligations under the Rules to undertake joint planning, the DBs will provide AEMO with the transmission connection point data for sites with limitations as specified in section 4.1 of the AER’s Transmission Annual Planning Report (TAPR) Guideline. The relevant data will be provided by the DBs to AEMO over the course of 2021, to enable AEMO to meet its obligations to publish the Victorian TAPR by 31 October.

Parties seeking further information about any matter contained in this report should contact any one of the following people:

- Adam Ryan, Network Optimisation Manager, CitiPower / Powercor, phone 9683 4380.
- Tom Langstaff, Manager - Distribution Network Planning, phone 9695 6859.

⁴ Throughout this report, the terms “energy at risk” and “expected unserved energy” are used to provide an indication of the magnitude, and potential impact of loss of load for each terminal station. Unless stated otherwise, in this report:

“Energy at risk” is, for a given forecast of demand, the total energy that would not be supplied from a terminal station if a major outage of a transformer occurs at that station in a specified year (where a “major outage” is defined as one that has a mean duration of 2.65 months) and no other mitigation action is taken. This statistic provides an indication of the magnitude of loss of energy that would arise in the unlikely event of a major outage of a transformer.

“Expected unserved energy” is the energy at risk weighted by the probability of a major outage of a transformer (again, where a “major outage” is defined as one that has a mean duration of 2.65 months). This statistic provides an indication of the amount of energy, on average, that will not be supplied in a year, taking into account the very low probability that one transformer at the station will not be available because of a major outage.

- Roshanth Sivanathan, Head of Network Planning, United Energy, phone 8846 9528.
- Rudi Strobel, Customer & System Planning Manager, Jemena, phone 9173 8560.

Any of these contact officers will either be able to answer your queries or will direct you to the organisation that is best placed to provide you with the information you are seeking.

Summary of risk assessment and options for alleviation of constraints


Terminal Station	Indicative timing for completion of preferred network solution (using 2020 VCR)	Expected unserved energy for the year shown in the column to the left (in MWh, and valued at 2020 VCR)		Preferred network solution	Indicative annual cost of preferred network solution	Potentially feasible non-network solutions
		10 th percentile demand forecast	50 th percentile demand forecast			
Altona – Brooklyn (ATS/BLTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Altona no 3 & 4 (ATS West) 66 kV	2029	118.8 MWh in 2030 (\$4.1 million)	69.4 MWh in 2030 (\$2.4 million)	Install additional transformation capacity and reconfigure 66 kV exits at ATS.	\$1.33 million	Demand reduction; Local generation.
Ballarat (BATS)	Not before 2030	43.2 MWh in 2030 (\$1.47 million)	17.4 MWh in 2030 (\$0.59 million)	Install a third 150 MVA 220/66 kV transformer. The new 144.4 MW Yendon Wind Farm exports directly to BATS via a 66 kV connection and is expected to reduce the peak demand on the BATS transformers, thereby significantly reducing the load at risk at BATS.	\$1.03 million	Demand reduction; Local generation
Bendigo 22 kV (BETS 22 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Bendigo 66 kV (BETS 66 kV)	Not before 2030	12.6 MWh (\$0.47 million)	5.6 MWh (\$0.21 million)	Install an additional 150 MVA 220/66 kV transformer.	\$1.33 million	Demand reduction; Local generation
Brooklyn 22 kV (BLTS 22 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Brunswick 22 kV (BTS 22 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Brunswick 66 kV (BTS 66 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Cranbourne 66 kV (CBTS 66 kV)	To be determined by the RIT-T which is currently underway	38.1 MWh (\$1.36 million) in 2020/21	9.7 MWh (\$0.34 million) in 2020/21	Install a fourth transformer. After load transfers and emergency ties are taken into account, the optimal economic timing of augmentation is estimated to be around 2026/27	\$1.9 million	Demand reduction; Local generation.

Terminal Station	Indicative timing for completion of preferred network solution (using 2020 VCR)	Expected unserved energy for the year shown in the column to the left (in MWh, and valued at 2020 VCR)		Preferred network solution	Indicative annual cost of preferred network solution	Potentially feasible non-network solutions
		10 th percentile demand forecast	50 th percentile demand forecast			
Deer Park (DPTS)	2026	26.8 MWh (\$1.02 million)	5.3 MWh (\$0.2 million)	Procure a dedicated spare transformer. A RIT-T will be commenced in 2022/23.	\$0.3 million	Demand reduction; Local generation.
East Rowville (ERTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon. There is a small amount of energy at risk under 10% POE conditions over the forecast period. However AusNet Transmission Group plans to replace two aged and poor condition transformers at ERTS (transformers B1 and B4) by 2024. After this replacement project is completed, the station's N-1 rating will be increased so that there would be no energy at risk over the forward planning period. In the period prior to the completion of the transformer replacement project, the load at risk will be managed using contingency load transfers.					
Fishermans Bend (FBTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon					
Frankston (FTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Geelong (GTS)	Not before 2030	31.5 MWh (\$1.19 million)	4.5 MWh (\$170,000)	Install a fifth transformer.	\$1.33 million	Demand reduction; Local generation
Glenrowan (GNTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Heatherton (HTS)	Not before 2030	0.03 MWh (\$1,300)	Nil	Establish a new 220/66 kV terminal station in Dandenong. This option alleviates a number of emerging transmission, connection asset and sub-transmission limitations including at HTS.	\$5.2 million	Demand reduction; Local generation
Horsham (HOTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Heywood (HYTS 22 kV)	A 22 kV point of supply was established in late 2009, by utilising the tertiary 22 kV on 2 of the existing 3 x 500/275/22 kV South Australian / Victorian interconnecting transformers. The station presently supplies a small number of customers in the local area. There is sufficient capacity at the station to supply all expected 22 kV load over the forecast period, even with one transformer out of service.					
Keilor (KTS)	Not before 2030	125.8 MWh (\$4.7 million)	1.4 MWh (\$53,750)	No augmentation of capacity is expected to be required within the ten year planning horizon. Over the forecast period, the risk to supply reliability will be mitigated through contingency plans to transfer load quickly, where possible, to adjacent terminal stations.	N/A	Demand reduction; Local generation

Terminal Station	Indicative timing for completion of preferred network solution (using 2020 VCR)	Expected unserved energy for the year shown in the column to the left (in MWh, and valued at 2020 VCR)		Preferred network solution	Indicative annual cost of preferred network solution	Potentially feasible non-network solutions
		10 th percentile demand forecast	50 th percentile demand forecast			
Kerang (KGTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Malvern 22 kV (MTS 22 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Malvern 66 kV (MTS 66 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Mount Beauty (MBTS)	At times of high demand and with low output from Clover Power Station a transformer outage at MBTS could result in the loss of some customer load for a period of no more than 4 hours, as the “hot spare” transformer at the station is brought into service. At a cost of approximately \$2 million, it would not be economic to install full switching of the hot spare transformer at MBTS during the 10 year planning horizon to eliminate this risk.					
Morwell (MWTS)	Demand at MWTS is forecast to decline slightly over the ten year planning period. Bairnsdale Power Station’s contract to provide network support services to AusNet Services expires in March 2022, at which time, a feasible option would be to recontract network support services from Bairnsdale or another network support service provider in the area. AusNet Services is currently undertaking a regulatory investment test for distribution (RIT-D) to address sub-transmission limitations in the East Gippsland area, and has published a non-network options report which is available at https://ausnetservices.com.au/About/Projects-and-Innovation/Regulatory-Investment-Test . Continued availability of Bairnsdale and other embedded generation over the ten year planning horizon will obviate the need for network augmentation.					
Red Cliffs 22 kV (RCTS 22 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Red Cliffs 66 kV (RCTS 66 kV)	Not before 2030	12.6 MWh (\$525,000)	4.4 MWh (\$185,400)	The current and forecast level of expected unserved energy at RCTS 66 indicates that implementation of a network solution is unlikely to be economic over the ten year planning horizon. A contingency plan to transfer approximately 25 MVA from RCTS 66 to WETS will be implemented in the event of the loss of one of the RCTS 220/66 kV transformers.	N/A	Demand reduction; Local generation
Richmond 22 kV (RTS 22 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Richmond 66 kV (RTS 66 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					

Terminal Station	Indicative timing for completion of preferred network solution (using 2020 VCR)	Expected unserved energy for the year shown in the column to the left (in MWh, and valued at 2020 VCR)		Preferred network solution	Indicative annual cost of preferred network solution	Potentially feasible non-network solutions
		10 th percentile demand forecast	50 th percentile demand forecast			
Ringwood 22 kV (RWTS 22 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Ringwood 66 kV (RWTS 66 kV)	At the 10th percentile temperature, for an outage of one 220/66 kV transformer at RWTS, there will be a minor amount of load at risk in 2020/21 and this risk will be reduced as forecast demand declines throughout the planning horizon. Should the need arise, rebalancing loads across the two bus groups at the station could be implemented to manage the “N” risk on bus group 1-3. AusNet Electricity Services and United Energy would jointly identify the works required to rebalance loads in the most efficient manner, following which the cost and optimal timing of the required works would be established.					
Shepparton (SHTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
South Morang (SMTS)	Not before 2030	37.7 MWh in 2029/30 assuming no generation from Somerton PS (\$1.2 million)	17.2 MWh in 2029/30 assuming no generation from Somerton PS (\$0.6 million)	Install a third 225 MVA 220/66 kV transformer at SMTS.	\$1.6 million (including the cost of fault limiting reactors)	Demand Reduction Embedded generation
Springvale (SVTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Templestowe (TSTS)	Not before 2030	1.0 MWh (\$31,000)	Nil	Install a fourth 150 MVA 220/66 kV transformer at TSTS.	\$1.6 million	Demand reduction; Local generation
Terang (TGTS)	Not before 2030	25.3 MWh (\$0.9 million)	3.6 MWh (\$0.12 million)	Install a third 220/66 kV transformer (150 MVA) at TGTS	\$0.92 million	Demand reduction; Local generation
Thomastown (TTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Tyabb (TBTS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Wemen (WETS)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon. Input of generation connected to the station results in reverse power flows that approach the station’s (N) rating. AEMO has a constraint equation managing the terminal station transformer reverse loading. The generators are sent dispatch signals to reduce generation if the constraint equation binds. In addition, Powercor is currently developing a transformer overload protection scheme and this will be installed as a backup to the AEMO constraint equation.					

Terminal Station	Indicative timing for completion of preferred network solution (using 2020 VCR)	Expected unserved energy for the year shown in the column to the left (in MWh, and valued at 2020 VCR)		Preferred network solution	Indicative annual cost of preferred network solution	Potentially feasible non-network solutions
		10 th percentile demand forecast	50 th percentile demand forecast			
West Melb 22 kV (WMTS 22 kV)	No augmentation of capacity is expected to be required within the ten year planning horizon. Under joint plans developed by CitiPower and AusNet Transmission Group, existing load supplied from WMTS 22 kV will be transferred to adjacent stations to enable the retirement of all of the existing WMTS 22 kV systems by the end of 2026.					
West Melb 66 kV (WMTS 66 kV)	No demand-driven augmentation of capacity is expected to be required within the ten year planning horizon.					
Wodonga (WOTS)	Not before 2030	2.3 MWh in 2030 (\$0.1 million) excluding generation from Hume PS or any other source	0.05 MWh in 2030 (\$6,700) excluding generation from Hume PS or any other source	In view of the forecast level of expected unserved energy, there are currently no plans to implement a network solution within the ten year planning horizon.	N/A	Demand management; Local generation



1 INTRODUCTION AND BACKGROUND

1.1 Purpose of this report

This is a joint report on transmission connection asset planning in Victoria, prepared by the five Victorian electricity Distribution Businesses (the DBs)⁵, in accordance with the requirements of clause 3.4 of the Victorian Electricity Distribution Code⁶ and clause 5.13.2 of the National Electricity Rules (the Rules)⁷.

It is emphasised that this report does not present detailed investment decision analyses. Rather, the report presents a high-level indication of the expected balance between capacity and demand at each terminal station⁸ over the 10 year forecast period, and the likely investment requirements.

Data presented in this report may indicate an emerging major constraint. Therefore, this report provides a means of identifying those terminal stations where further consultation and detailed analysis - in accordance with the RIT-T - is required. This report also provides preliminary information on potential opportunities to prospective proponents of alternatives to network augmentations at terminal stations where remedial action may be required. Providing this information to the market should facilitate the efficient development of network and non-network solutions to best meet the needs of load customers.

1.2 Victorian joint planning arrangements for transmission connection assets

In Victoria:

- as explained in further detail in section 1.3.1 below, the DBs have responsibility for planning and directing the augmentation of the facilities that connect their distribution systems to the Victorian shared transmission network;⁹ and
- the Australian Energy Market Operator (AEMO) is responsible for planning and directing the augmentation of the shared transmission network.

It is noted that pursuant to Chapter 6A of the Rules, transmission connection assets are used to provide prescribed transmission services.

⁵ The five DBs are: Jemena Electricity Networks (Vic) Ltd, CitiPower, Powercor Australia, United Energy, and AusNet Electricity Services Pty Ltd. AusNet Electricity Services is owned by AusNet Services, a diversified energy infrastructure business that also owns the Victorian electricity transmission system. Throughout this document “AusNet Transmission Group” refers to the transmission business of AusNet Services and “AusNet Electricity Services” refers to the electricity distribution business of AusNet Services.

⁶ Version 11, effective from April 2020.


⁷ Version 150 of the Rules was in force at the time of preparing this report.

⁸ A terminal station is a facility that connects a distribution network to the shared transmission network.

⁹ The shared transmission network is the main extra high voltage network that provides or potentially provides supply to more than a single point. That network includes all lines rated above 66 kV and main system tie transformers that operate at two or three voltage levels above 66 kV.

Figure 1 below provides an example to illustrate the distinction between the shared transmission network and transmission connection assets in a notional network. The delineation between shared network and connection assets depends on high voltage switching configurations and other factors that may vary from one transmission connection point to another. Nonetheless, Figure 1 provides a useful illustration of the distinction between shared network and connection assets.

Figure 1: Shared network and connection assets in a notional network



In regions other than Victoria, the Rules¹⁰ set out arrangements to promote contestability in the provision of connection services for identified user groups other than networks (such as generators or large directly connected customers). Specifically, the Rules currently distinguish between:

- a) Identified user shared assets, which broadly describe the collection of components that are required to facilitate the connection of a connecting party to the shared transmission network and which, once commissioned, form part of the shared transmission network; and
- b) Dedicated connection assets¹¹, which describe the collection of components that are used to connect a connecting party to the shared transmission network and which, once commissioned, are able to be isolated from electricity flows on the transmission network.

In Victoria, however, the framework under which connections to the transmission network occur is fundamentally different to the processes and principles underlying the connection framework used in the rest of the National Electricity Market (NEM). This is because, as explained below, section 50C of the National Electricity Law authorises AEMO to exercise declared shared network functions in Victoria. In that role, AEMO determines whether works are:

- 'contestable' and so are procured through a competitive tender process; or

¹⁰ National Electricity Amendment, (Transmission Connection and Planning Arrangements) Rule 2017 No.4, 30 May 2017. See <https://www.aemc.gov.au/rule-changes/transmission-connection-and-planning-arrangements>

¹¹ The AEMC has recently published a draft Rule determination that would, if implemented, introduce the term 'Designated Network Assets' (DNAs) instead of large Dedicated Connection Assets. DNAs would be provided on a contestable basis, but the relevant TNSP would be responsible for operating and maintain the assets.

- 'non-contestable and so provided by the incumbent declared transmission system operator, which is AusNet Transmission Group.

As such, the Rules definitions noted above do not apply in Victoria.

The transmission planning responsibilities of AEMO are set out in section 50C(1) of the National Electricity (South Australia) (National Electricity Law—Australian Energy Market Operator) Amendment Act 2009. Under that act, AEMO's functions include:

“to plan, authorise, contract for, and direct, augmentation of the declared shared network, where the declared shared network is defined as “the adoptive jurisdiction’s [in this case, Victoria’s] declared transmission system excluding any part of it that is a connection asset within the meaning of the Rules”.

In accordance with clause 5.14.1(a)(1) of the Rules, AEMO and the DBs undertake joint planning to ensure the efficient development of the shared transmission and distribution networks, and the transmission connection facilities. To formalise these arrangements, the parties have agreed a Memorandum of Understanding (MoU).

The MoU sets out a framework for cooperation and liaison between AEMO and the DBs with regard to the joint planning of the shared transmission network and transmission connection assets in Victoria. In particular, the MoU sets out the approach to be applied by AEMO and the DBs in the assessment of options to address limitations in a distribution network where one of the options consists of investment in dual function assets or transmission investment, including connection assets and the shared transmission network. Under the MoU, the DBs and AEMO have agreed that subject to the thresholds set out in the Rules, joint planning projects should be assessed by applying the RIT-T.

The DBs also liaise regularly with AusNet Transmission Group to coordinate their transmission connection augmentation plans with AusNet Transmission Group's asset renewal and replacement plans¹².

¹² Chapter 5 of AEMO's 2020 Victorian Annual Planning Report provides information on AusNet Transmission Group's plans regarding asset retirement, replacement and deratings. The report is available from: https://www.aemo.com.au/-/media/files/electricity/nem/planning_and_forecasting/vapr/2020/2020-vapr-master.pdf?la=en

AusNet Transmission Services' asset renewal plan is available from: https://www.aemo.com.au/-/media/files/electricity/nem/planning_and_forecasting/vapr/2020/ausnet-services-asset-renewal-plan.pdf?la=en

1.3 DBs' obligations as transmission connection planners

1.3.1 Victorian regulatory instruments

Clause 14 of each DB's Distribution Licence states:

"The **Licensee** is responsible for planning, and directing the augmentation of, **transmission connection assets** to assist it to fulfil its obligations [to offer connection services and supply to customers] under clause 6."

The licence defines "transmission connection assets" as:

"those parts of an electricity transmission network which are dedicated to the connection of customers at a single point, including transformers, associated switchgear and plant and equipment."

In accordance with their obligations under clause 3.1(b) of the Victorian Electricity Distribution Code, the DBs plan and direct the augmentation of the transmission connection assets in a way which minimises costs to customers taking into account distribution losses and transmission losses.

Clause 3.4 of the Victorian Electricity Distribution Code states:

- "3.4.1 Together with each other distributor, a distributor must submit to the Commission a joint annual report called the 'Transmission Connection Planning Report' detailing how together all distributors plan to meet predicted demand for electricity supplied into their distribution networks from transmission connections over the following ten calendar years.
- 3.4.2 The report must include the following information:
 - (a) the historical and forecast demand from, and capacity of, each transmission connection;
 - (b) an assessment of the magnitude, probability and impact of loss of load for each transmission connection;
 - (c) each distributor's planning standards;
 - (d) a description of feasible options for meeting forecast demand at each transmission connection including opportunities for embedded generation and demand management and information on land acquisition where the possible options are constrained by land access or use issues;
 - (e) the availability of any contribution from each distributor including where feasible, an estimate of its size, which is available to embedded generators or customers to reduce forecast demand and defer or avoid augmentation of a transmission connection; and
 - (f) where a preferred option for meeting forecast demand has been identified, a description of that option, including its estimated cost, to a reasonable level of detail.
- 3.4.3 Each distributor must publish the Transmission Connection Planning Report on its website and, on request by a customer, provide the customer with a copy. The distributor may impose a charge (determined by reference to its Approved Statement of Charges) for providing a customer with a copy of the report."

The Victorian Electricity Distribution Code was amended in March 2008 to include an additional provision (clause 3.1A) relating to the security of supply of the Melbourne CBD. This provision establishes a separate planning process that applies to the network supplying the Melbourne CBD only. Details of the CBD security of supply upgrade plan are available from CitiPower's website at the following web pages:

<https://www.powercor.com.au/news/cbd-supply/>

<https://www.powercor.com.au/about-us/electricity-networks/metro-and-cbd-security-of-supply/>

The upgrade plan will ensure that the electricity network supplying the Melbourne CBD is 'N-1 Secure'. Under this standard, CitiPower must maintain supply after the loss of two 66 kV cable elements, with an allowance of 30 minutes switching time after the loss of the first element.

CitiPower has completed the 66 kV works required under the CBD security of supply upgrade plan. In accordance with the plan, a new Waratah Place zone substation was commissioned in June 2020 and new 66 kV cables have been constructed and re-configured to provide the security needed to maintain supply from alternate supply points at West Melbourne Terminal Station and Brunswick Terminal Station for the loss of two 66kV sub-transmission cables.

Due to load growth in the southwest of Melbourne CBD, CitiPower is planning to rebuild the existing zone substation at Tavistock Place (TP). Elements of the new zone substation are required as part of the Melbourne CBD security program which seeks to increase resilience into the 66 kV sub-transmission network given the critical nature of reliable electricity supply to the area. The new TP zone substation with new distribution feeders will provide sufficient transfer capacity at 11 kV to meet the requirements of 'N-1 Secure'.

The planned commissioning date for the TP zone substation is November 2023, with distribution feeder works to be completed by end of 2024.

1.3.2 National Electricity Rules

Part D of Chapter 5 of the Rules¹³ sets out provisions governing the planning and development of networks. These provisions require, amongst other things, Transmission and Distribution Network Service Providers to:

- prepare and publish annual planning reports;
- consult with interested parties on the possible options, including but not limited to demand side options, generation options and market network service options to address any projected network limitations; and
- undertake analysis of proposed network investments using the Regulatory Investment Test for Distribution or the RIT-T, as appropriate.

¹³ Version 150 of the Rules was in force at the time of preparing this report.

As noted in section 1.2, the DBs and AEMO have agreed that joint planning projects involving transmission connection and distribution investment should be assessed by applying the RIT-T.

Clause 5.13.2 of the Rules requires Distribution Network Service Providers to publish a Distribution Annual Planning Report (DAPR). The DAPR must contain the information specified in schedule 5.8 of the Rules, unless that information is provided in accordance with jurisdictional electricity legislation¹⁴.

Pursuant to clause 5.13.2(d) of the Rules, this Transmission Connection Planning Report presents all of the information on transmission-distribution connection planning required under schedule 5.8. The table below lists the relevant clauses and provides a cross reference to the section of this report where the required information is provided.

Table 1A: Schedule 5.8 requirements relating to transmission-distribution connection points addressed in this report

Schedule 5.8 clause	Matters addressed	Where the information is presented in this report
S5.8(b)(1)	A description of the forecasting methodology used.	Section 2.
S5.8(b)(2)(i), (iv), (v), (vi), (vii), (viii), and (ix)	Load forecasts and forecasts of capacity.	Section 4, Section 5.6 and individual risk assessments for each terminal station.
S5.8(b)(3)	Forecasts of future transmission-distribution connection points and any associated connection assets.	The Executive Summary and individual risk assessments for each terminal station.
S5.8(h)	The results of joint planning undertaken with Transmission Network Service Providers.	Section 1.2 describes the joint planning arrangements. The Executive Summary and individual risk assessments for each terminal station present the joint planning results.
S5.8(i)(1)	The results of joint planning undertaken with other Distribution Network Service Providers (DNSPs)	As above

1.3.3 Reliability incentive scheme (s-factor) for the Distribution Businesses

Under the Service Target Performance Incentive Scheme (STPIS) and the Distribution Determination that applies from 1 January 2016 to 31 December 2020, each DB's revenue cap contains an s-factor, which provides a revenue bonus when service performance is better than target, and a penalty when service performance is worse than target.

¹⁴ Clause 5.13.2(d) of the Rules states: "a Distribution Network Service Provider is not required to include in its Distribution Annual Planning Report information required in relation to transmission-distribution connection points if it is required to do so under jurisdictional electricity legislation."

The operation of the s-factor relates to the distribution network, and therefore is not directly relevant to the reliability of the transmission system. However, under clause 3.3(a)(6) of the STPIS¹⁵, the DBs are exposed to financial penalties if load interruptions are caused by a failure of transmission connection assets, where the interruptions are due to inadequate planning of transmission connections and the DNSP is responsible for transmission connection planning.

The financial incentives under these arrangements reinforce the DBs' responsibilities with respect to transmission connection planning, which are set out in the Distribution Licences and the Victorian Electricity Distribution Code as explained in section 1.3.1 above.

1.3.4 Role of transmission connection asset owners in delivering connection services

With the exception of the connection assets at the Deer Park Terminal Station, the transmission assets that provide DB connection services are located within terminal stations which are owned, operated, and maintained by AusNet Transmission Group¹⁶. Connection services are provided by the owners of the transmission connection assets in accordance with their connection agreements with the relevant DBs. These agreements set out, amongst other things, the standard of connection services to be provided.

In addition, the revenue caps applying to AusNet Transmission Group and TransGrid also contain a Service Target Performance Incentive Scheme, which provides the transmission connection asset owners with a financial incentive to improve service performance.

1.4 Matters to be addressed by proponents of non-network alternatives

One purpose of this document is to provide information to proponents of non-network solutions (such as embedded generation or demand management) regarding emerging network constraints. As noted in further detail in Chapter 2 below, the DBs aim to develop their networks and the associated transmission connection assets in a manner that minimises total costs (or maximises net economic benefit). To this end, proponents of non-network solutions to the emerging network constraints identified in this report are encouraged to lodge expressions of interest with the relevant DB(s).

Proponents of non-network proposals should make initial contact with the relevant DB as soon as possible, to ensure that sufficient time is available to the DB to fully assess feasible network and non-network potential solutions, having regard to the lead times associated with the evaluation, planning and implementation of various options. Indicative timeframes for the network solutions are provided in the table in the Executive Summary.

To assist in the assessment of non-network solutions, proponents are invited to make a detailed submission to the relevant DB. That submission should be informed by earlier discussions with the relevant DB, and should include all of the following details about the proposal, including:

¹⁵ AER, *Electricity Distribution Network Service Providers - Service Target Performance Incentive Scheme*, Version 2.0, November 2018.

¹⁶ The connection assets at Deer Park Terminal Station were commissioned in September 2017, and are owned, operated and maintained by TransGrid.

- (a) proponent name and contact details;
- (b) a detailed description of the proposal;
- (c) electrical layout schematics;
- (d) a firm nominated site;
- (e) capacity in MW and MVAR to be provided and number of units to be installed (if applicable);
- (f) fault level contribution, load flows, and stability studies (if applicable);
- (g) a commissioning date with contingency specified;
- (h) availability and reliability performance benchmarks;
- (i) network interface requirements (as agreed with the relevant DBs);
- (j) the economic life of the proposal;
- (k) banker / financier commitment;
- (l) proposed operational and contractual arrangements that the proponent would be prepared to enter into with the relevant DBs;
- (m) any special conditions to be included in a contract with the responsible DBs; and
- (n) evidence of a planning application having been lodged, where appropriate.

All proposals must satisfy the requirements of any applicable Codes and Regulations.

In addition, as a general rule of thumb, any network reinforcement costs required to accommodate the non-network solution will typically be borne by the proponent(s) of the non-network project. Some non-network alternatives such as embedded generation may raise issues relating to fault level control. In particular, connection of additional embedded generators will result in an increase in fault levels. Therefore, fault level mitigation measures may be required, in which case the proponents of embedded generation projects will bear the costs of fault level mitigation works.

1.5 Implementing Transmission Connection Projects

In the absence of any commitment by interested parties to offer non-network solutions such as embedded generation or demand side management, the process to implement the preferred network solution will commence. A brief description of the implementation process for network solutions and the issues involved is presented below.

1.5.1 Land Acquisition

Network solutions may require land acquisition. The process of land acquisition for new terminal stations may be complex especially in metropolitan areas. A detailed consideration of land acquisition issues and processes is beyond the scope of this report.

A limited number of vacant sites, currently owned by AusNet Transmission Group, have been reserved for possible future terminal station development in Victoria. DBs would

need to seek AusNet Transmission Group's consent to use any reserved land for transmission connection development.¹⁷

The granting of a town planning permit on lands reserved for future terminal station development is by no means certain. In some municipalities, town planning approval may also be required for network augmentation on existing developed sites.

1.5.2 Connection Application to AEMO

Where a network solution requires new connection points with the shared transmission network to be established, a connection agreement with AEMO is required in accordance with clause 5.3 (Establishing or Modifying Connection) of the National Electricity Rules. As noted in section 1.2, the assets that form part of the Victorian declared shared transmission network fall under the planning jurisdiction of AEMO. Hence, issues associated with 220 kV switching arrangements and connection to the shared transmission network, including direct connection to a 66 kV terminal station bus, would be clarified with AEMO at the connection application stage. It is also noted that AEMO's requirements regarding new connections must be finalised through a joint planning process involving AEMO and the relevant DBs. These activities can increase the lead time for delivery of projects by some months.

For augmentations to existing connection points, a connection application to AEMO may be required so that the effect on the shared transmission network, if any, can be taken into consideration. In some cases, AEMO and the relevant DBs may undertake a public consultation process in relation to the proposed development, in addition to the consultation processes that must be undertaken if the RIT-T applies. Similar to new connections, AEMO's requirements regarding any augmentation of shared transmission network assets must be finalised through a joint planning process involving AEMO and the relevant DBs.

A more detailed overview of the Victorian transmission connections process is available from AEMO's web page at: <https://aemo.com.au/energy-systems/electricity/national-electricity-market-nem/participate-in-the-market/network-connections/victorian-transmission-connections>.

1.5.3 Connection Application to AusNet Transmission Group

It is most likely that establishment of new transmission connections, or augmentation of existing transmission connections will require interface to transmission assets owned by AusNet Transmission Group. In such cases, an initial "Connection Inquiry" outlining the broad scope of service sought should be submitted to AusNet Transmission Group, followed by a "Connection Application" when the scope of the service has been accurately defined in consultation with AEMO and the relevant DB(s).

¹⁷ Electricity Industry Guideline No. 18 (*Augmentation and Land Access Guidelines*) issued by the ESC on 1 April 2005 may govern access to such sites, in some circumstances. See: <https://www.esc.vic.gov.au/electricity-and-gas/electricity-and-gas-codes-guidelines-policies-and-manuals>

1.5.4 Town Planning Permit

For greenfield sites, DBs may need to engage the services of experienced town planning consultants, because very extensive planning requirements are usually laid down by local planning authorities. In most cases, the town planning permit application would need to be accompanied by extensive supporting documents such as:

- flora and fauna study;
- archaeological and cultural assessment;
- noise study;
- electromagnetic field (EMF) assessment;
- traffic analysis;
- layouts and elevation plans; and
- landscaping and fencing plans.

The choice of appropriate town planning consultants is very important, as they may need to provide expert witness statements to the Victorian Civil and Administrative Tribunal (VCAT) if objections to the transmission connection application are received. Due to the possibility of simultaneous shared network development by AEMO on the same site, it may become necessary to invite AEMO to participate in the town planning process at the same time so that both the council and the public are made aware of the entire proposed development on the site.

For augmentation to existing transmission connection assets, the requirement for a town planning permit varies from council to council, and depends on the extent of the proposed work. AusNet Transmission Group is likely to be the initiator of the planning permit application for augmentation work at an existing terminal station.

1.5.5 Public Consultation Strategy

A key aspect of the public consultation strategy is the positive engagement of various stakeholders in the project from the initial stages of the development. The strategy may include:

- distribution of leaflets that provide information on the proposal in clear, concise, non-technical language to every nearby resident;
- presentations to the councillors of the local municipality and the local members of parliament; and
- public consultation such as display stands in local shopping centres to highlight the need for the project and the resultant benefits to the community, and invitation of public comments on the proposal.

Feedback from stakeholders is then considered in the design of the transmission connection work to ensure the resultant project is acceptable to the local community.

1.5.6 Project Implementation

As noted in section 1.3.1, the DBs are required by the Victorian Electricity Distribution Code to augment the transmission connections in a way which minimises costs to customers. This can be achieved by a variety of means, including competitive tendering and cost benchmarking.

Transmission connection augmentation works will be arranged by the relevant DBs in accordance with the requirements of any applicable guidelines.

1.5.7 Project lead times

The lead-time required for the implementation of connection asset augmentation projects depends on the number of interdependent activities involved in the project, and varies from between 3 to 5 years.

The critical path activities in the delivery of such projects include the following:


- Finalisation of any requirements for shared network augmentation due to planned connection asset augmentation works. These requirements are assessed through the joint planning process, which involves AEMO, AusNet Transmission Group and the DBs in Victoria.
- Procurement of a planning permit in relation to the proposed works. In order to obtain planning consent for proposed works, the statutory planning requirements of the local council(s) must be met, and community expectations must be addressed. For connection asset augmentations involving either major augmentations on an established site or the development of new terminal station(s) on new site(s), a period of at least 24 to 36 months is required for land planning and associated community issues to be resolved. The timely completion of this task requires effective coordination and cooperation between AEMO, AusNet Transmission Group and the DBs through the joint planning process in Victoria.
- After completing the above two tasks successfully, the next important tasks are:
 - finalisation of the scope of works;
 - preparation of cost estimates (including invitation to tender if the project is contestable); and
 - finalisation and execution of all contracts and agreements between distribution and transmission network service providers after obtaining all the necessary internal business approvals.

Once the project contracts are signed, the next important task is the delivery of the project itself, including installation and commissioning of the assets into service. AusNet Transmission Group's recent experience indicates that the lead-time required for the delivery of a connection asset augmentation involving power transformers is between 18 and 24 months. In some cases, issues identified during testing of completed units may further extend the overall process. In view of this, for planning purposes it is assumed that approximately 24 months would be required to procure, install and commission power transformers from the time that a commercial contract is signed between the parties to complete the project works.

1.6 Overview of Transmission Connection Planning Process

The flow chart below provides a summary of the transmission connection planning and augmentation process under the regulatory framework which applies to the Victorian DBs.

PROCESS FLOW CHART: TRANSMISSION CONNECTION PLANNING



2 PLANNING STANDARDS

2.1 Planning standard applying to transmission connection assets

Clause 3.4.2(c) of the Victorian Electricity Distribution Code requires this report to set out the planning standards applying to transmission connection assets.

The planning standard applied by the DBs is the RIT-T, the purpose of which is set out in clause 5.15A.1(c) of the Rules as follows:

“The purpose of the regulatory investment test for transmission [...] is to identify the credible option that maximises the present value of net economic benefit to all those who produce, consume and transport electricity in the market (the preferred option). For the avoidance of doubt, a preferred option may, in the relevant circumstances, have a negative net economic benefit (that is, a net economic cost) to the extent the identified need is for reliability corrective action or the provision of inertia network services required under clause 5.20B.4 or the provision of system strength services required under clause 5.20C.3.”

Clause 5.10.2 of the Rules defines “reliability corrective action” as follows:

“Investment by a Transmission Network Service Provider or a Distribution Network Service Provider in respect of its transmission network or distribution network for the purpose of meeting the service standards linked to the technical requirements of schedule 5.1 or in applicable regulatory instruments and which may consist of network options or non-network options.”

The terms “applicable regulatory instruments” is defined in the Rules as follows:

“All laws, regulations, orders, licences, codes, determinations and other regulatory instruments (other than the Rules) which apply to Registered Participants from time to time, including those applicable in each participating jurisdiction as listed below, to the extent that they regulate or contain terms and conditions relating to access to a network, connection to a network, the provision of network services, network service price or augmentation of a network.”

Under the definition contained in the Rules, “applicable regulatory instruments” in Victoria include:

- the Electricity Industry Act 2000 (EI Act);
- all regulations made and licences (Licences) issued under the EI Act;
- the Essential Services Commission Act 2001 (ESCV Act);
- all regulations and determinations made under the ESCV Act;
- all regulatory instruments applicable under the Licences; and
- the Tariff Order made under section 158A(1) of the Electricity Industry Act 1993 and continued in effect by clause 6(1) of Schedule 4 to the Electricity Industry (Residual Provisions) Act 1993, as amended or varied in accordance with section 14 of the Electricity Industry Act.

Further background information on the planning standard applying to transmission connection assets, and the probabilistic planning approach applied by the DBs for the purpose of evaluating net economic benefits is set out in sections 2.2 to 2.5 below.


2.2 Overall objective of transmission connection planning

The planning standards and criteria applied in network development are a significant determinant of network-related costs. Costs associated with transmission connection facilities can be considered to be comprised of two parts:

- the direct cost of the service (as reflected in network charges and the costs of losses); and
- indirect costs borne by customers as a consequence of supply interruptions caused by network faults and / or insufficient network capacity.

The DBs aim to develop transmission connection facilities in an efficient manner that minimises the total (direct plus indirect) life-cycle cost of network services. This basic concept is illustrated in Figure 2 below.

Figure 2: Balancing the direct cost of service and the indirect cost of interruption



In accordance with the requirements of the RIT-T, the DBs' transmission connection investment decisions aim to maximise the net present value to the market as a whole, having regard to the costs and benefits of non-network alternatives to augmentation. Such alternatives include, but are not necessarily limited to, demand-side management and embedded generation.

2.3 Overall approach to transmission planning and investment evaluation

In Victoria, pursuant to section 50F(2)(b) of the National Electricity Law, AEMO applies a probabilistic approach¹⁸ to planning the shared transmission network¹⁹.

Under the probabilistic approach, deterministic standards (such as N-1) are not applied. Instead, simulation studies are undertaken to assess the amount of energy that would not be supplied if an element of the network is out of service. The application of this approach can lead to the deferral of transmission capital works that might otherwise proceed if a deterministic standard were strictly applied. This is because:

- in a network planned using the probabilistic approach, there may be conditions under which some or all of the load cannot be supplied with a network element out of service (hence the N-1 standard is not met); however
- under these conditions, the value of the energy that is expected to be not supplied is not high enough to justify additional investment, taking into account the probability of a forced outage of a particular element of the transmission network.

However, implicit in the use of a probabilistic approach is acceptance of the risk that there may be circumstances (such as the loss of a transformer during a high demand period) when the available terminal station capacity will be insufficient to meet actual demand, and significant load shedding could be required.

In Victoria, the jurisdiction has not set deterministic standards applying to transmission connection assets. However, clause 5.2 of the Victorian Electricity Distribution Code sets out the following requirements relating to reliability of supply:

“A distributor must use best endeavours to meet targets required by the Price Determination and targets published under clause 5.1 and otherwise meet reasonable customer expectations of reliability of supply.”

In light of these considerations and the requirements of the RIT-T, the DBs apply probabilistic planning and economic investment decision analysis to transmission connection assets, subject to meeting the technical and other standards set out in the Rules and other applicable regulatory instruments including the Victorian Electricity Distribution Code.

2.4 VCR: Valuing supply reliability from the customers' perspective

In order to determine the economically optimal level and configuration of connection capacity - and hence to deliver a level of supply reliability that will meet customers'

¹⁸ A copy of the Victorian transmission planning criteria can be obtained from AEMO's web site at: http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.pdf

¹⁹ As explained in section 1, the “shared transmission network” is the Victorian transmission system, excluding the transmission facilities that connect the distribution networks (and the generators) to the high voltage network. The distribution businesses are responsible for the planning and development of the transmission facilities that connect their distribution networks to the shared transmission network. These arrangements are set out in the distribution licences issued by the ESC.

reasonable expectations - it is necessary to place a value on supply reliability from the perspective of customers. This is referred to as the value of customer reliability (VCR).

In July 2018, a final Rule determination on the VCR came into effect, giving the AER responsibility for developing and publishing a VCR methodology and VCR estimates. In December 2019, the AER published its VCR methodology and VCR estimates²⁰.

For the purpose of this 2020 Transmission Connection Planning Report, the DBs have applied the VCR sector estimates set out in Tables 1.1 to 1.5 of the AER's December 2019 Final Report. Table 1 below presents a comparison of the 2020 sector VCR estimates alongside those that were used in the 2019 Transmission Connection Planning Report.

Table 1: VCR estimates by sector

Sector	VCR for 2019 Source: AEMO's September 2014 VCR Review Final Report, adjusted for annual indexation as per s.5.2 of AEMO's December 2014 VCR Application Guide	VCR for 2020²¹ Source: AER's Final Report on VCR values, December 2019	Change in VCR from 2019 to 2020
Residential (Victoria)	26.80	21.43 ²²	-20%
Commercial (NEM)	48.41	44.52	-8%
Agricultural (NEM)	51.60	37.87	-27%
Industrial (NEM)	47.70 ²³	63.79 ²⁴	+34%

It is noted that:

- Residential, commercial and industrial sector VCR estimates for 2020 are lower than their 2019 estimates (by 20%, 8% and 27%, respectively).

²⁰ AER, Final Report on VCR values, December 2019, available at <https://www.aer.gov.au/networks-pipelines/guidelines-schemes-models-reviews/values-of-customer-reliability/final-decision>

²¹ The values in the AER's Final Report are expressed as "\$2019". Table A1.3 of the Final Report sets out the AER's methodology for annual adjustment of the VCR estimate, using the annual change in the September quarter CPI. Since the September CPI was not available at the time of preparing this report, the sector VCR estimates published by the AER in December 2019 have not been escalated for CPI. For next year's (2021) Transmission Connection Planning Report, the \$2019 values estimated by the AER will be escalated by the change in the September CPI from 2019 to 2020, in accordance with the method set out in Table A1.3 of the AER's Final Report.

²² The Victorian residential VCR is estimated for four different climate zones, as shown in Table 1.1 of the AER's Final Report. For simplicity, the value shown here is the composite Victorian residential VCR as per Table 1.2 of the AER's Final Report.

²³ Excludes industrial customers that are directly connected to the transmission network.

²⁴ For customers with a maximum demand below 10 MVA, as per Table 1.3 of the AER's Final Report on VCR values, December 2019.

- The 2020 estimate of the industrial sector (<10 MVA) VCR is 34% higher than the 2019 value.

It should be noted that this comparative reduction in the VCR estimates for the residential, commercial and agricultural sectors, and increase in the industrial component would tend to indicate a greater need for investment in more industrial areas and a reduced need in other sectors, compared to the previous VCR estimates.

The AER's draft decision on VCR considered the case for transitioning to new VCR estimates where there are significant changes in VCRs from one five-yearly review to the next. The draft decision concluded that such a transition is not warranted²⁵:

"[...] if a significant shift in consumer values is identified, there should not be any delay in transitioning to the new values. Therefore, we consider the preferable course is not to delay transitioning to new values in the absence of identifiable long-term benefits to consumers from a delay."

The AER's Final Report on VCR values did not address this issue. However, given the AER's position in its draft decision, this report applies the AER's VCR estimates without any transitional adjustments.

The DBs consider that while it is appropriate to have regard to the latest available VCR estimates, it is also important to recognise that all methods for estimating VCR are prone to error and uncertainty. The uncertainty in VCR estimates is illustrated by the wide differences between the latest VCR values and those estimated by previous studies.

It is also noted that the AER's estimates were determined prior to the COVID-19 pandemic, which may affect future VCR estimates. For example since December 2019, there has been a significant increase in the number of people working from home, so the AER's current estimate of the residential VCR may be understated.²⁶

The AER's Final Report provides the following guidance in how the VCR should be applied²⁷:

"When applying the VCR, the value used should be reflective of the customer composition on the network. For example, network investment decisions should use a VCR reflective of the composition of customer types located on the feeder or substation, rather than the VCR for the region, to properly consider the competing tensions of reliability and affordability."

In accordance with the AER's guidance, this report applies VCR values for each terminal station that reflect the composition of station energy consumption by sector, and the sector VCR estimates set out in Tables 1.1 to 1.5 of the AER's December 2019 Final Report on VCR values.

²⁵ AER, Values of Customer Reliability: Draft Decision, September 2019, pages 56 - 57.

²⁶ These considerations underscore the importance of sensitivity testing in investment decision analyses such as the RIT-T. It is noted that section 7.2 (page 84) of the AER's Final Report suggests that sensitivity ranges of up to +/- 30 per cent of VCR estimates could be used.

²⁷ AER, Final Report on VCR Values, December 2019, page 10.

2.5 Application of the probabilistic approach to transmission connection planning

The probabilistic planning approach involves estimating the probability of a plant outage occurring, and weighting the costs of such an occurrence by its probability to assess:

- the expected cost that will be incurred if no action is taken to address an emerging constraint,²⁸ and
- whether it is economic to augment terminal station capacity to reduce expected supply interruptions.

The quantity and value of energy at risk is a critical parameter in assessing a prospective network investment or other action in response to an emerging constraint. Probabilistic network planning aims to ensure that an economic balance is struck between:

- the cost of providing additional network capacity to remove constraints; and
- the cost of having some exposure to loading levels beyond the network's capability.

In other words, recognising that very high loading conditions may occur for only a few hours in each year, it may be uneconomic to provide additional capacity to cover the possibility that an outage of an item of network plant may occur under conditions of very high loading. The probabilistic approach requires expenditure to be justified with reference to the expected benefits of lower volumes of unserved energy.

This approach provides a reasonable estimate of the expected net present value to consumers of terminal station augmentation for planning purposes. However, as already noted, implicit in its use is acceptance of the risk that there may be circumstances (such as the loss of a transformer during a high demand period) when the available terminal station capacity will be insufficient to meet actual demand, and significant load shedding could be required. The level of investment that should be committed to mitigate that risk is ultimately a matter of judgment, having regard to:

- the results of studies of possible outcomes, and the inherent uncertainty of those outcomes;
- the potential costs and other impacts that may be associated with very low probability events, such as single or coincident transformer outages at times of peak demand, and catastrophic plant failure leading to increased safety risk, increased risk of property damage, and/or extended periods of plant non-availability;
- the availability and technical feasibility of cost-effective contingency plans and other arrangements for management and mitigation of risk; and
- the Victorian DBs' obligation (under clause 5.2 of the Victorian Electricity Distribution Code) to use best endeavours to meet, among other things, reasonable customer expectations of reliability of supply.

²⁸ The energy that would not be supplied in the event of an interruption is valued in accordance with the approach outlined in Section 2.4 above.

3 CURRENT AND EMERGING PLANNING CONSIDERATIONS

This chapter outlines current electricity market developments and recent events in Victoria that may have a bearing on the DBs' transmission connection planning activities. While such matters are considered routinely in preparing this report, the DBs recognise that stakeholders may value a short discussion of recent developments and how they relate to transmission connection planning.


3.1 Impacts of COVID-19

From mid-March 2020, significant restrictions on economic activity and social contact were imposed in response to the COVID-19 pandemic. AEMO's 2020 Victorian Annual Planning Report notes that²⁹:

- Initially, the COVID-19 restrictions resulted in a shift of approximately 500 MW between commercial and residential demand, with net daily demand remaining relatively consistent with previous years.
- In Victoria, stage 4 restrictions came into effect on 5 August 2020, requiring many businesses to close, and resulting in significantly reduced commercial demand which more than offset increased residential demand.
- Time-of-day usage patterns since March 2020 have exhibited reductions in the typical morning peak, and upward pressure into the afternoon peak.

The COVID-19 restrictions also led to changes in the pattern of electricity consumption across Victoria, with many regional areas exhibiting increases in consumption in July 2020 compared to July 2019, as illustrated below.

Figure 3: Changes in electricity consumption, July 2020 vs July 2019



Source: AEMO, Victorian Annual Planning Report, October 2020, Figure 16, page 41

²⁹

AEMO, Victorian Annual Planning Report, October 2020, page 27.

The COVID-19 pandemic is continuing to profoundly affect global economic activity. Whilst Victoria and Australia as a whole have made significant progress in suppressing the pandemic, there remains considerable uncertainty regarding the timing and profile of the future economic recovery at a state, national and global level. This uncertainty, combined with the effects already produced by the pandemic create challenges in forecasting future demand, and identifying emerging constraints at terminal stations.

In particular, as illustrated in Figure 3, the impacts of the COVID-19 pandemic on current and future demand will vary by geographical area. Some areas (i.e. residential areas) may experience increased maximum demand and stronger demand growth than the network average, while other areas (i.e. commercial areas that are subject to shutdowns) experience a drop-off in demand, and lower or no forecast demand growth.

In addition, it should be noted that at this stage, with unprecedented change due to the COVID-19 pandemic, the impact on demand is still highly uncertain and project timings may need to be varied (i.e. advanced or deferred) next year once more information on the impacts become available.

3.2 On-going industry change

As this report is focused on the planning of transmission assets that provide DB connection services, a number of the broader developments affecting the transmission and distribution networks are not directly relevant to this report. Nevertheless, it is useful to comment on these developments, noting the areas where transmission connection planning may be affected.

In the 2019 edition of this report, we commented on the rapid change taking place in the electricity sector following decades of relative stability characterised by steady growth in electricity consumption and demand. Since then, the energy landscape in Victoria has continued to change, driven in particular by strong investment in large-scale renewable generation projects, as noted in AEMO's 2020 Victorian Annual Planning Report. In that report³⁰, AEMO highlighted the following important factors affecting the Victorian transmission system:

- Consumer-led investment in distributed energy resources (DER), such as distributed solar photovoltaic (PV) systems, has altered the shape of the daily demand curve, and is creating new challenges through larger credible contingency sizes, new record levels of minimum demand, and decreasing levels of voltage control, inertia, and system strength.
- While the Victorian transmission network remained secure over the past year, a tightening supply balance, widespread bushfires, extreme weather events, and record low demands contributed to extremely difficult operating conditions and two days requiring dispatch of emergency reserves.
- Minimum demand continued to fall in 2019-20, reaching a record low daytime value of 3.3 GW on 1 January 2020. Further minimum demand records were subsequently set in the first half of 2020-21. This represents the second year in a row that Victoria's annual minimum occurred during the day, rather than overnight. These lower demands contributed to voltage control challenges, and new reactive power contracts have been used while long-term network investments are delivered.

³⁰ AEMO, Victorian Annual Planning Report, October 2020, pages 3 and 4.

- Victoria now has approximately 7.8 GW of existing or committed wind and solar generation, with large-scale projects contributing 4.9 GW and distributed PV contributing a further 2.9 GW. Victoria also has 2.3 GW of existing hydro units, and 75 MW of existing or committed battery storage, in addition to the 300 MW Tesla battery which is expected to be installed at Moorabool (near Geelong) for the 2021-22 summer³¹.
- Since the 2019 VAPR, 1.6 GW of new large-scale wind and solar projects have connected or commenced commissioning, with a further 1.5 GW committed to connect, and 16.3 GW having lodged enquiries.
- Victorian maximum demand peaked at 9.7 GW in January 2020, compared with 9.3 GW in January 2019. Over the coming decade, AEMO expects that system needs are likely to be dominated by minimum demand concerns and the integration of new generator projects including large pumped hydro schemes outside of Victoria.

On 30 October 2019, the Renewable Energy (Jobs and Investment) Amendment Bill 2019 passed the Victorian Parliament, bringing the Victorian Renewable Energy Target (VRET) 2030 target into legislation. The increased target of 50% by 2030 is now embedded in legislation, building on the existing legislated renewable energy generation targets of 25% by 2020 and 40% by 2025.

The Victorian Renewable Energy Target 2018-19 Progress Report³² found that Victoria is well on track to meet the first VRET target of 25% renewable energy generation by 2020³³. AEMO's 2020 ISP identifies that a minimum of 13.2 GW of Victorian renewable generation would be required by 2030 to meet the VRET. AEMO's 2020 Victorian Annual Planning Report comments that Victoria will need at least an additional 5.4 GW of large-scale projects and DER investment to meet the 2030 VRET.

In order to facilitate these changes, the 2020 Victorian Annual Planning Report explains that AEMO is progressing a targeted suite of transmission network development projects worth \$3.5 billion across Victoria over the next decade, including:

- Improved voltage control – AEMO and AusNet Transmission Group are installing four 100 MVAR reactors from 2021 to address voltage control limitations under light load conditions.
- Greater interconnection with New South Wales – AEMO and TransGrid are upgrading the Victoria–NSW Interconnector to enable additional Victorian exports from late 2022.
- System strength in north west Victoria – AEMO has entered into non-market ancillary services agreements with two system strength service providers in the Red Cliffs area and is now progressing procurement of a permanent solution that will support existing renewable projects in the area.

³¹ <https://www.energy.vic.gov.au/media-releases/victoria-to-build-southern-hemisphere-biggest-battery>

³² Victorian Department of Environment, Land, Water and Planning, Victorian Renewable Energy Target :2018-19 Progress Report, available at: https://www.energy.vic.gov.au/_data/assets/pdf_file/0030/439950/Victorian-Renewable-Energy-Target-2018-19-Progress-Report.pdf

³³ <https://www.energy.vic.gov.au/renewable-energy/victorias-renewable-energy-targets>

- Renewable Energy Zone (REZ) expansion in western Victoria – AEMO has contracted AusNet Transmission Group to deliver staged network upgrades in western Victoria by 2025 to reduce network congestion and unlock additional renewable capacity.
- Hosting capacity upgrade in south-west Victoria – AEMO is investigating new limitations and solutions in the south-west corridor, associated with the volume of new generator connections in the area.
- Major new interconnection and REZ expansions in the north west and central north of Victoria – AEMO and TransGrid are jointly progressing the VNI West RIT-T to assess the economic merits of additional transfer capacity between Victoria and New South Wales from 2027-28.

In addition, there are two major projects under examination which will affect the energy flows across the Victorian transmission network:

- TasNetworks is progressing its RIT-T in relation to a second Bass Strait electricity interconnector, known as Marinus Link. If Marinus Link proceeds, it is not expected that transmission augmentations would be required to accommodate the new interconnector in Victoria because the DC to AC converter station would be located adjacent to the existing Hazelwood substation, utilising the network capacity freed up following the retirement of Hazelwood Power Station.
- ElectraNet and TransGrid are progressing Project EnergyConnect to deliver an 800 MW interconnector between South Australia and New South Wales, with a reinforced connection to Victoria at Red Cliffs.

3.3 Initiatives announced in the 2020-21 Victorian state budget

In November's state budget the government committed \$540 million to fund the establishment of six REZs in Victoria³⁴. The Victorian REZs were identified as candidates in AEMO's 2020 Integrated System Plan. As shown in the figure below, the REZs are located in areas that are rich in renewable energy resources. The investment proposed by the Victorian government will provide the transmission and other infrastructure that is needed to enable the transport of clean energy from large-scale wind, solar and pumped hydro generators to load centres.

³⁴

<https://www.premier.vic.gov.au/making-victoria-renewable-energy-powerhouse>

Figure 4: Renewable Energy Zones - Victoria

Source: <https://www.theage.com.au/national/victoria/from-sunny-north-to-windy-east-what-are-victoria-s-renewable-energy-zones-20201125-p56hsl.html>

AEMO has said that it will work with the Victorian Government to develop a REZ Development Plan that will map out how alternative patterns of generation might impact the optimal development of transmission in the state – considering network projects that might best support areas of high developer interest”.³⁵

Similarly, the DBs will continue to work closely with AEMO and the Victorian government as the preparation and implementation of the REZ Development Plan proceeds, to ensure that any issues impacting on the DBs’ transmission connection planning responsibilities are identified.

In addition to funding REZ developments, the 2020-21 Victorian budget also provides:

- \$335 million to replace old wood or gas fired heaters with energy-efficient heating and cooling for 250,000 low-income households;
- \$191 million to expand the existing Solar Homes program, with an extra 42,000 solar panel rebates to be provided over the next two years; and
- \$12.6 million to bring online more than 600 megawatts of new renewable capacity, through a renewable energy auction.

These initiatives are intended to assist Victoria in meeting its VRET targets. In addition, they are likely to impact on the pattern of electricity supply and demand across Victoria, which will need to be considered in future demand forecasts and transmission connection planning assessments.

³⁵ <https://www.aemo.com.au/newsroom/media-release/victorian-annual-planning-report>

3.4 Issues arising from increased embedded generation

3.4.1 Transformer ratings

As a result of the increase in DER, several terminal stations that have historically behaved as net loads have increasingly become net generation sources. For example, measurements at Kerang Terminal Station show flows onto the transmission network for 30.7% of the time during the last 12 months, while reverse power flows at Wemen Terminal Station occurred for 35.1% over the same period.

Reverse power flows associated with substantial intermittent generation output may result in significantly increased variability of transformer loadings, increased transformer utilisation, and reduced time for transformers to cool down between periods of high loading in either direction. AusNet Transmission Services has advised that in these circumstances, the existing cyclic ratings may no longer be applicable to these transformers because they no longer exhibit a predictable cyclic loading pattern. Instead, it may be necessary to adopt the transformer's name plate rating (rather than the higher cyclic rating) for planning and operational purposes.

AusNet Transmission Services reviews transformer load profiles on an ongoing basis and updates applicable ratings as required. The ratings of some stations with significantly changed load profiles, caused by either changing load patterns and/or significant generation connected, have recently been revised. The relevant risk assessments presented in section 5 of this report incorporate these changes.

As additional new generation connections proceed, other transformers may be affected by significant reverse power flows, resulting in a reduction in ratings, and the possibility of potentially significant increases in load at risk at the affected stations. It is noted that some of the increased load at risk would likely be offset by the output from intermittent generation. However, it is also noted that deriving forecasts of intermittent generator output is complex, and particularly challenging given the limited data available to forecast that output at times of high demand.

3.4.2 Impact of rooftop PV on estimates of energy at risk

As already noted, there has been an increasing prominence of distributed generation at the consumer side of the supply chain, in particular rooftop solar PV generation. Rooftop PV has the impact of reducing the energy consumption as seen by the grid, and to a lesser degree³⁶, reducing the maximum demand at the transmission connection points.

The DBs account for this impact on maximum demand in their demand forecasts. It is these forecasts (of customer load with the generation output of rooftop PV netted off) that are used to assess the amount of energy at risk and expected unserved energy at each transmission connection point.

However, it is noted that in the event of a supply interruption, rooftop PV panels are tripped unless they have back-up battery systems configured and approved for island mode operation. Customers affected by such outages will experience a level of unserved energy equal to their total unserved consumption (that is, including the energy that would have been supplied by their PV panels and batteries). Under the current forecasting

³⁶ This is due to the fact that the maximum demand typically occurs later in the afternoon or in the early evening when the output of rooftop solar PV is well below its peak.

approach, estimates of energy at risk do not take this effect into account and as a consequence the amount of unserved energy due to a network outage may be underestimated by an amount equal to the energy contribution that would have been made by PV panels and batteries for the duration of the interruption.

An assessment of the impact of this issue was carried out in 2018. It was estimated that the average impact on the energy at risk across all Victorian transmission connection points was approximately 2% to 3%. However, the impact may be more significant at different transmission connection points depending on the installed capacity of rooftop PV in a particular supply area, and the time of day that the maximum demand occurs for the transmission connection point. In some cases the impact may be as much as 10% to 15%.

Whilst this impact on terminal station demand is not currently considered in this report, the DBs will re-examine this issue during 2021.

3.4.3 Minimum demand and voltage management

Networks have been designed and operated with a focus on one-way power flow because, traditionally, electricity was centrally generated and transmitted through the transmission network and connection asset transformers, and then consumed throughout the distribution network.

Network design relied on the fact that voltage levels would gradually and predictably drop from the generation source, and then be boosted back up via appropriately tapped transformers and strategically located reactive support, until the energy was delivered to the consumer. With these operational characteristics in mind, transformers were designed and purchased for a particular voltage profile and traditionally have a high boost, low buck tapping range. This means they are highly capable of raising (boosting) voltage from the high voltage side to the low voltage side, but have a very limited ability to drop (buck) the voltage down.

The recent prominence of embedded generation indicates that this traditional network design and operational philosophy is increasingly inadequate to meet future needs. As the penetration of embedded generation increases and offsets demand, the minimum demand at a number of stations is declining. This declining minimum demand results in higher voltage levels on the distribution side, requiring more capability from transformers to reduce voltage levels during times of minimum demand, rather than raising voltage levels. The management of voltage is made more challenging by the fact that demand at many stations is still growing, so the disparity between peak and minimum demand is increasing and the voltage band to be managed throughout the day is widening.

Similarly, the increased disparity between minimum and maximum demand is also resulting in a wider range of fault levels that the network protection systems need to be able to recognise and operate for. As with the design of transformers, the protection systems were not designed with such wide operating bands in mind.

In addition to the increased challenges of maintaining voltage levels within acceptable limits, AEMO's 2020 Victorian Annual Planning report³⁷ notes that new generators are applying to locate in areas of the network with the highest quality wind and solar resources, but low system strength. System strength not only relates to maintaining

³⁷ AEMO, Victorian Annual Planning Report, October 2020, page 92.

voltage levels within acceptable limits, as previously described, but extends to the power system's ability to remain stable under normal conditions and to return to a steady state condition following a system disturbance.

As a consequence, it is expected that additional reactive support, provided by NSPs and newly connected embedded generation, will be required to adequately manage voltage levels within the capabilities of the existing assets. Additionally, any new or replacement connection assets installed in the future may be required to meet new standards to ensure the assets are capable of operating in the wider voltage and fault level ranges expected at that location.

For example, connection asset transformers may require designs with wider tap ranges and/or more buck voltage capability to allow for the increased penetration of embedded generation driving lower minimum demand or reverse power flows through the transformers. While recent connection asset transformers procured by AusNet Transmission Group have incorporated additional buck voltage capability - with the existing spare transformers having a +3.9% buck capability rather than a zero buck capability - the distribution businesses will consider if this additional capability is suitable to meet long term needs. In addition, current transformers may require similarly wider operating ranges to ensure they can identify and operate for the wider fault level ranges being exhibited.

3.4.4 The need for generation runback schemes

At terminal stations where significant embedded generation is currently and/or forecast to be connected, power flows from the generation source(s) may lead to an increased risk of terminal station transformer overloading. Under the connection arrangements in the National Electricity Rules³⁸, the embedded generator is required to pay the costs of providing the connection services, including the costs of augmenting connection assets.

In some cases, the connecting generator may determine that it is uneconomic for conventional network augmentation to be undertaken, in which case, the need for and suitability of a generation runback scheme would be investigated by the DB. These schemes are designed to quickly reduce the amount of generation inflows, to ensure that distribution and transmission plant loadings are maintained within safe limits, and the connection services provided to load customers are not adversely affected by the connection of embedded generation.

3.4.5 Stability issues in the West Murray area

The West Murray Zone is an area of the NEM with low system strength, extending across parts of Victoria and New South Wales. This area has attracted significant investment in grid-scale solar and wind generation in the past three years. The scale and rapid pace of inverter-based renewable generator connections has resulted in new technical challenges, impacting grid performance and operational stability.

The nature, extent and causes of these issues only become apparent with the advanced and detailed modelling capability that is now essential for technical assessments in weak areas of the grid.

³⁸ Clauses 5.3 and 5.3A.

In the 2020 Victorian Annual Planning Report, AEMO states that it is committed to working collaboratively and transparently to find solutions to the challenges presented in the West Murray Zone. This includes working closely with developers, generators, network service providers, equipment manufacturers and industry groups.

Developers interested in connecting generation in the West Murray Zone and surrounding area should contact their local network service provider before making any financial commitments, to discuss whether, when and how they might be able to progress their project.

Further information on this matter is available from AEMO's website at:

<https://aemo.com.au/energy-systems/electricity/national-electricity-market-nem/participate-in-the-market/network-connections/west-murray>

3.5 Management of system fault levels

As noted above, there have been significant changes in the mix of generation in the Victorian power system, and across the NEM over recent years. These changes are expected to continue. The increasing proportion of non-synchronous generation (both large-scale and distributed) creates a number of operational challenges. One such challenge is the management of changing fault levels³⁹ across the power system.

In 2019, AEMO conducted a review which identified fault level issues at the following terminal stations that are relevant to this connection planning report⁴⁰:

- Thomastown 220 kV (Bus 1 and Bus 3); and
- West Melbourne 220 kV and 66 kV.

In relation to both terminal stations, AEMO proposed operational measures to manage the identified issues. These operational measures are expected to be sufficient to manage the fault level issues at Thomastown. For West Melbourne, there is a committed project to replace the existing four 150 MVA 220/66 kV transformer units with three 225 MVA transformer units, which is expected to be completed in 2021-22. This project is expected to reduce fault levels at both West Melbourne 220 kV and 66 kV.

AEMO's 2020 Victorian Annual Planning Report identified fault level issues at the following terminal stations that are relevant to this connection planning report:

- Limitations associated with minimum fault level requirements are emerging at Thomastown Terminal Station, due to lower demand. AEMO is undertaking further analysis of this limitation through the 2020 System Strength and Inertia Review, the results of which are to be published by the end of the year.

³⁹ In an electric power system, a fault or fault current is any abnormal electric current. For example, a short circuit is a fault in which current bypasses the normal load. In power systems, protective devices detect fault conditions and operate circuit breakers to protect an electrical circuit from damage caused by overload or short circuit. In order for a circuit breaker to operate safely and reliably, the current that flows in the event of a fault must be within the rating or short-circuit limits of the circuit breaker and other terminal station equipment.

⁴⁰ AEMO, Victorian Annual Planning Report, June 2019, page 48.

- In December 2019, AEMO published a Notice of Victorian Fault Level shortfall at Red Cliffs, declaring an immediate Victorian system strength gap. AEMO executed contracts with two system strength service providers in August 2020 as an interim measure, and has initiated a subsequent tender process to procure a long-term solution, which may involve a combination of network and non-network investments.

Further changes in the generation mix in Victoria are expected in the immediate future and over the medium term, with:

- further increases in the connection of new low carbon generation to the network, driven by, amongst other things, the Victorian Renewable Energy Target; and
- the possible development of increased interconnector capacity.

These developments are likely to drive fault level issues in future.

3.6 Managing the risk of transformer failure

Over the past six years, three transmission connection transformers have failed unexpectedly. In each of these cases, adverse impacts on customers have been mitigated through the installation of spare transformers that AusNet Transmission Group holds for this purpose.

In 2019, AusNet Transmission Group undertook a study to review the arrangements for spare transformers, and to determine the optimal number and type of spares that should be held. Further information on spare transformers is provided in section 5.5.

3.7 Maintaining security of supply during major terminal station renewals

Over recent years, AusNet Transmission Group has been undertaking an asset renewal program. As noted in more detail in the risk assessments in this report, a number of terminal station renewals have been completed, while others are planned or in progress.

AusNet Transmission Group's asset renewal plan provides details of the work that is planned for the next ten years. The report can be downloaded from AEMO's website at:

https://www.aemo.com.au/-/media/files/electricity/nem/planning_and_forecasting/vapr/2020/ausnet-services-asset-renewal-plan.pdf?la=en

The larger terminal station renewals require careful outage and construction sequencing to ensure security of supply to the distribution networks is not compromised. Security of supply risks can also be mitigated efficiently by planning some temporary or permanent reconfigurations of the distribution networks supplied from the terminal station.

As AusNet Transmission Group's asset renewal program continues to progress, the DBs will continue to work collaboratively to manage the reliability risks during construction, and to minimise supply impacts and total costs to customers.

4 HISTORIC AND FORECAST DEMAND

In accordance with the requirements of clause 3.4.2 of the Victorian Electricity Distribution Code, data showing the historical and forecast demand from, and capacity of, each transmission connection are presented for each terminal station in the individual risk assessments that form part of this Transmission Connection Planning Report.

The demand forecasts used in the preparation of this report are referred to as the Victorian Terminal Station Demand Forecasts (TSDF). The TSDF report is prepared by the Victorian DBs, and is published alongside this Transmission Connection Planning Report. As explained in section 3.1, the future economic impacts of the COVID 19 pandemic are highly uncertain, and this uncertainty is an inherent characteristic of the demand forecasts used in this report.

As noted in last year's Transmission Connection Planning Report, AEMO commenced publishing a separate connection point forecast report for Victoria in 2014. AEMO's transmission connection point forecasts⁴¹ are provided on an Operational Demand basis, where Operational Demand in a region is:

“Demand that is met by local scheduled generating units, semi-scheduled generating units, and non-scheduled intermittent generating units of aggregate capacity ≥ 30 MW, and by generation imports to the region. It excludes the demand met by non-scheduled non-intermittent generating units, non-scheduled intermittent generating units of aggregate capacity <30 MW, exempt generation (e.g. rooftop solar, gas tri-generation, very small wind farms, etc), and demand of local scheduled loads. The exceptions are Yarwun, Angaston, Port Stanvac, and Morton's Lane which are included.”⁴²

The Victorian DBs' TSDF report provides forecasts on a total demand basis, effectively adding back demand met by non-scheduled non-intermittent generating units, non-scheduled intermittent generating units of aggregate capacity <30 MW, exempt generation (other than rooftop solar and behind the meter battery storage) and demand of local scheduled loads. Consequently, there are some differences between the demand forecasts in the DBs' TSDF and AEMO's Victorian connection point forecasts.

As in previous years, the DBs consider it appropriate to continue to adopt the TSDF forecasts for the purpose of preparing this Transmission Connection Planning Report. It is noted that the TSDF forecasts have been applied in all previous Transmission Connection Planning Reports.

⁴¹ A copy of AEMO's 2020 Victorian Connection Point Forecasting Report is available from its website at: <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Planning-and-forecasting/Transmission-Connection-Point-Forecasting/Victoria>

⁴² <https://aemo.com.au/en/energy-systems/electricity/national-electricity-market-nem/data-nem/operational-demand-data>

5 RISK ASSESSMENT AND OPTIONS FOR ALLEVIATION OF CONSTRAINTS

5.1 Preamble

This section presents an overview of the magnitude, probability and impact of loss of load at each transmission connection, in accordance with the requirements of clause 3.4.2(b) of the Victorian Electricity Distribution Code.

The assessment presented is not a detailed planning analysis, but a high-level description of the expected balance between capacity and demand over the forecast period, and the likely investment requirements. Data presented in this high-level analysis may indicate an emerging major constraint. Therefore, this high-level assessment provides a means of identifying those terminal stations where further detailed analysis of risks and options for remedial action, in accordance with the RIT-T, is required.

It is emphasised that this high-level analysis focuses on risks to supply reliability that relate to the capacity and reliability of transformers only. There are typically risks to reliability associated with the performance and capacity of smaller plant items. However, these smaller items involve relatively low capital expenditure, the deferral of which is unlikely to entail a sufficiently high avoided cost to justify the employment of non-network alternatives.

In addition, capital expenditure is required from time to time to address fault level issues. This expenditure is driven chiefly by mandatory health and safety standards, and does not relate to terminal station capacity, per se. Fault level issues are therefore not within the scope of this report, however, the analysis of feasible and preferred options for increasing capacity will, where appropriate have due regard to issues relating to fault level control⁴³.

The following key data are presented in this section for each Terminal Station, with the exception of Deer Park Terminal Station (DPTS)⁴⁴:

- **Energy at risk:** For a given demand forecast, this is the amount of energy that would not be supplied from a terminal station if a major outage⁴⁵ of a transformer occurs at that station in that particular year, the outage has a mean duration of 2.65 months (as discussed in section 5.4 below), and no other mitigation action is taken. This statistic provides an indication of the magnitude of loss of load that would arise in the unlikely event of a major outage of a transformer.
- **Expected unserved energy:** For a given demand forecast, this is the energy at risk weighted by the probability of a major outage of a transformer. A load duration curve

⁴³ Some non-network alternatives such as embedded generation may raise issues relating to fault level control. A further discussion of this issue is set out in Section 1.4 of this report.

⁴⁴ At present, a spare 225 MVA transformer suitable for installation at DPTS is not available. The DB responsible for planning DPTS (CitiPower-Powercor) has adopted the conservative assumption that a major transformer failure would not be repairable, and therefore a replacement transformer would need to be procured. The procurement of a replacement would take 12 months, so in the case of DPTS, a major outage of a transformer is assumed to have a duration of 12 months.

⁴⁵ The term "major outage" refers to an outage that has a mean duration of 2.65 months, typically due to a significant failure within the transformer. The actual duration of an individual major outage may vary from under 1 month up to 12 months. Further details are provided in section 5.4 below.

is used to estimate the unserved energy in each hour of the year for a major transformer outage. The estimated unserved energy for each hour is then multiplied by the probability of the outage occurring in any hour of the year. The total expected unserved energy in a year is obtained by summing the probability-weighted estimates of unserved energy for each hour of the year. This statistic provides an indication of the amount of energy, on average, that will not be supplied in a year, taking into account the very low probability that one transformer at the station will not be available for 2.65 months because of a major outage.

Risk assessments for each terminal station provide estimates of energy at risk and expected unserved energy based on the 50th percentile and 10th percentile demand forecasts set out in Section 4. Consideration of energy at risk and expected unserved energy at these two demand forecast levels provides:

- an indication of the sensitivity of these two parameters to temperature variation over the peak period; and
- an indication of the level of exposure to supply interruption costs under higher demand conditions (namely, 10th percentile levels).

As already noted, this information provides an aid to identifying the likely timing of economically justified augmentations or other actions. However, the precise timing of augmentation or non-network solutions aimed at alleviating emerging constraints will be a matter for more detailed analysis prepared in accordance with the RIT-T requirements.

In interpreting the information set out in this report, it is important to recognise that in the case of a Summer peaking station, the 50th percentile demand forecast relates to a maximum average temperature that will be exceeded, on average, once every two years. By definition therefore, actual demand in any given year has a 50% probability of being higher than the 50th percentile demand forecast.⁴⁶


5.2 Interpreting “energy at risk”

As noted above, “energy at risk” is an estimate of the amount of energy that would not be supplied if one transformer was out of service due to a major failure during the critical loading season(s), for a given demand forecast.

The capability of a terminal station with one transformer out of service is referred to as its “N minus 1” rating. The capability of the station with all transformers in service is referred to as its “N” rating. The relationship between the N and N-1 ratings of a station and the energy at risk is depicted in the diagram below.

⁴⁶ Conversely, there is also a 50% chance that actual demand will be lower than the forecast in any one year.

Relationship between N rating, N-1 rating and energy at risk



5.3 Assessing the costs of transformer outages

As explained in Section 5.1, for a given demand forecast:

- “energy at risk” denotes the amount of energy that would not be supplied from a terminal station if a major outage of a single transformer occurs at that station in that particular year, and no other mitigation action is taken; and
- “expected unserved energy” is the energy at risk weighted by the probability of a major outage of a single transformer.

In estimating the expected cost of connection plant outages, this report considers the first order contingency condition (“N minus 1”) only. It is recognised that in the case of terminal stations that consist of two transformers, there is a significant amount of energy at risk if both transformers are out of service at the same time, due to a major outage.

The DBs have carefully considered whether this report should be expanded to include consideration of the costs of major outages under N-2 (second order contingency) conditions, and concluded that it is not necessary to do so. The principal reason for this conclusion is that the value of expected unserved energy associated with second order contingencies would be unlikely to be sufficiently high to justify the advancement of any major augmentation, compared to the augmentation timing that is economically justified by an analysis that is limited to considering first order contingencies. Section 3 of the Appendix contains a detailed example which illustrates this point.

5.4 Base reliability statistics for transmission plant

Estimates of the expected unserved energy at each terminal station must be based on the expected reliability performance of the relevant transformers. With the exception of Deer Park Terminal Station (which is owned by TransGrid), the basic reliability data for terminal station transformers has been established and agreed with the asset owner, AusNet Transmission Group. The base data focuses on:

- the availability of the connection point main transformers; and
- the probability of a major problem forcing these plant items out of service for an average period of 2.65 months. This does not include minor faults that would result in a transformer being unavailable for a short period of time (ranging from a few hours up to no more than two days).

The basic reliability data adopted for the purpose of producing this report is summarised in the following table.

Major plant item: Terminal station transformer		Interpretation
Major outage rate for transformer	1.0% per annum	A major outage is expected to occur once per 100 transformer-years. Therefore, in a population of 100 terminal station transformers, you would expect one major failure of any one transformer per year.
Weighted average of major outage duration	2.65 months	On average, 2.65 months is required to return the transformer to service (if repair is possible) or to replace the transformer with a strategic spare transformer, during which time, the transformer is not available for service.
Expected transformer unavailability due to a major outage per transformer-year	$0.01 \times 2.65/12 = 0.221\%$ approximately	On average, each transformer would be expected to be unavailable due to major outages for 0.221% of the time, or 19 hours in a year.

In October 2020, AusNet Transmission Group's Principal Engineer, Strategic Network Planning confirmed that the transformer outage rate data and the estimated average time to restore a failed transformer to service (shown in the above table) are reasonable for the purpose of preparing the transmission connection asset risk assessments, and it was noted that:⁴⁷.

- Recent changes in the Australian transformer industry resulted in reduced capability to undertake repairs to transformers that are subject to a major failure, and therefore, supply is more likely to be restored by installing a strategic spare transformer than to undertake major repairs of the transformer.
- Recent experience from major transformer failures has demonstrated that it is typically more economical to replace rather than repair a transformer following a major failure, particularly for transformers that have reached or are approaching the end of their expected service life.
- The estimated weighted average duration of a major outage is largely determined by the expected time that it takes to replace a failed transformer with a strategic spare (rather than the time taken to repair the transformer following a major transformer failure). Whilst it is expected to take around one month to replace a transformer with a strategic spare it may take more than 12 months to procure a replacement

⁴⁷ AusNet Transmission Group uses asset condition based failure risk information for asset replacement decisions. Joint planning is undertaken with the DBs to coordinate connection asset terminal station augmentation works with AusNet Transmission Group's replacement plans.

transformer should no spare transformer be available at the time of the transformer failure. The 2.65 months that is being used for the TCPR risk assessments is a weighted average duration, which recognises the possibility that a strategic spare may not be available at the time of the major transformer failure.

Further details regarding the estimation of the weighted average duration of “major outages” are provided in the Appendix. The Appendix also sets out an example demonstrating the calculation of the “Expected Transformer Unavailability” for a terminal station with two transformers, using the basic reliability data contained in this section.

As explained in section 5.1, a spare 225 MVA transformer suitable for installation at DPTS is not available. The DB responsible for planning DPTS (CitiPower-Powercor) has adopted the conservative assumption that a major transformer failure would not be repairable, and therefore a replacement transformer would need to be procured. The procurement of a replacement would take 12 months, so in the case of DPTS, a major outage of a transformer is assumed to have a duration of 12 months.

5.5 Availability of spare transformers

In October 2020, AusNet Transmission Group’s Principal Engineer, Strategic Network Planning advised that:

- Both 220/66 kV metropolitan spare transformers are available to manage the risk of a metro transformer failure and they are located at Thomastown and Heatherton terminal stations.
- Both 220/66/22 kV country spare transformers are available to manage the risk of a country transformer failure and they are located at Keilor and South Morang terminal stations.
- A spare 66/22 kV transformer is located at Brooklyn Terminal Station. This transformer serves as a spare for 66/22 transformers including those at Malvern Terminal Station.
- Spare transformers held by AusNet Transmission Group may be used to support essential maintenance activities including refurbishment programs. Any transformer used in this way would no longer be available to replace a failed transformer.
- There is a small number of AusNet Transmission Group terminal stations for which a stock of spare transformers is not held. These terminal stations are the metropolitan 220/22 kV connection stations (being Ringwood, Brunswick, Richmond, West Melbourne and Brooklyn) and Wodonga 330/66/22 kV Terminal Station. For the metropolitan 220/22 kV stations, an in-service ‘hot’ spare is normally provided by one of the 220/22 kV transformers at Brunswick. The timeframes for deploying the ‘hot’ spare may exceed one calendar month. In the case of Wodonga 330/66/22 kV Terminal Station, AusNet Transmission Group is examining the economics of procuring a spare 330/66/22 kV transformer around 2025.

In the case of Deer Park Terminal Station (which is owned and operated by TransGrid), the total 10th percentile load at this two-transformer station is not expected to exceed the rating of a single transformer until 2022, at which time there is forecast to be 8.4 MWh of load at risk (at the 10th percentile temperature). Load will be transferred to other terminal stations in an event of a transformer failure at DPTS to avoid overloading the remaining

transformer. It is therefore considered acceptable during the period prior to 2022 to operate the station without procuring further backup capacity. This approach is reviewed annually.

5.6 Treatment of Load Transfer Capability

Many terminal stations have some capability to transfer load from one station to adjacent ones using the distribution network. The amount of load that can be transferred varies from minimal amounts at most country terminal stations to significant amounts at some urban terminal stations. Some load transfers are able to be made at 66 kV and/or 22 kV and lower voltage levels.

In the event of a transformer failure at a terminal station, load could be transferred (where short-term transfer capability is available) to reduce unserved energy and the impact of an outage. The risk assessments presented in this planning report assume normal network operating conditions, and therefore they show estimates of load at risk and expected unserved energy before any potential short-term load transfers. The reasons for this approach are:

- There is no guarantee that capacity will be available at an adjacent terminal station to accept load transfers, due to uncertainty of the availability of transformation capacity at that station.
- The capability of the distribution network to effect load transfers is always changing. It will vary depending on network loading conditions and is usually at a minimum during peak demand times. The transfer capability can also be adversely affected by any abnormal configurations which may be implemented from time to time to manage power flows across the distribution network.
- Implementing short term transfers places the network in a suboptimal operating condition, thereby increasing operational risks. As already noted, the network planning studies presented in this report evaluate load at risk for a single contingency under otherwise normal network operating conditions. This approach accords with sound network planning practices.

Where short-term load transfer capability may be available, the relevant risk assessment identifies load transfer as an operational solution to mitigate the severity of a major outage.

5.7 Detailed risk assessments and options for alleviation of constraints, by terminal station

Set out on the following pages are the detailed risk assessments and a description of the options available for alleviation of constraints, for each individual terminal station. The assessments, by station, are set out in alphabetical order. For each station, the network augmentation requirements (if any) and the estimated annual costs of the augmentation works are identified.

We have adopted an annuity approach to estimating the annual costs, which means that the cost is constant in real terms throughout the estimated life of the asset, which is 45 years for the purpose of this report. The annualised cost calculation also assumes a real

pre-tax discount rate of 5.9%⁴⁸ and an annual operating cost that is 1% of the project's capital costs. Using these inputs, for the purpose of this report the annualised cost is estimated to be 7.4% of the project's capital cost.

This cost estimate also provides a broad indication of the maximum potential value available to proponents of non-network solutions in deferring or avoiding network augmentation. However, it should be noted that the value of a non-network solution depends on the extent to which it defers or avoids a network augmentation, and the expected timing of the network augmentation. For example, a non-network solution that defers a network augmentation from 2024 to 2027 is less valuable today than one which defers a similar network augmentation from, say, 2021 to 2024. These issues should be considered by proponents of non-network solutions in assessing the implications of this report.

In addition, any proponents of non-network solutions to emerging constraints should note that the lead time for completion of a major network augmentation (such as the development of a new station, or the installation of a new transformer) can easily be up to two to three years, taking into account the need to obtain local authority planning consent⁴⁹. In view of this consideration, the individual risk assessment commentaries for each terminal station will:

- identify the estimated lead time for delivery of the preferred network solution; and/or
- identify the latest date by which the relevant DB(s) will generally require a firm commitment from proponents of non-network alternatives, in order to be confident that the network augmentation can be displaced or deferred without compromising supply reliability in the future.

5.8 Interpreting the dates shown in the risk assessments

All charts and tables in the following risk assessments present data on a calendar year basis. However, the narrative within some of the risk assessments may refer to composite years; for instance "2021/22", or "summer of 2021/22".

References to composite years may be made in risk assessments relating to summer peaking stations. In these cases, the peak annual demand would typically be expected to occur around mid to late summer (that is, early in the calendar year, say, from late January to March).

Therefore, where a risk assessment refers to a peak demand occurring in a composite year (such as 2021/22, for instance), the peak would typically be expected to occur in the second year (in this example, 2022), and the relevant data for 2021/22 would be shown in the accompanying tables and charts as 2022.

⁴⁸ In its 2020 Inputs, Assumptions and Scenarios Report, AEMO adopts a discount rate of 5.9% real pre-tax. Clause 18 of the RIT-T requires a RIT-T proponent to adopt the discount rate from the most recent Inputs, Assumptions and Scenarios Report. Accordingly, this Transmission Connection Planning Report applies a discount rate of 5.9% real pre-tax.

⁴⁹ Section 1.5 provides a more detailed description of the processes and timeframes involved in implementing transmission connection projects.

5.9 Augmentations to facilitate embedded generation connections

As explained in section 1.3.1, clause 14 of the Distribution Code requires the DBs to plan and direct the augmentation of transmission connection assets to meet their obligations to supply load customers, not embedded generators. While our planning obligations are limited to facilitating electricity supply to load, the DBs also recognise that it may be useful to identify opportunities to augment transmission connection assets to provide improved access for embedded generators. The risk assessments therefore comment on any such opportunities, where applicable, noting that the investment would either need to be financed by the embedded generators or satisfy the RIT-T.

APPENDIX: ESTIMATION OF BASIC TRANSFORMER RELIABILITY DATA AND EXAMPLE OF EXPECTED TRANSFORMER UNAVAILABILITY CALCULATION

1. Estimation of basic transformer reliability data

The basic transformer reliability data adopted for the risk assessment is estimated as follows:

Based on historic data, a major outage is expected to occur once per 100 transformer-years (reflecting a 1% per annum failure rate). Therefore, in a population of 100 transformers, you would expect one major failure of any one transformer per year.

The mean duration of a major failure is derived from the following data:

	PROPORTION OF MAJOR FAILURES	MEAN OUTAGE DURATION
Restore supply with a strategic spare transformer	0.85 of failures	1 months
Restore supply with a new transformer or repaired transformer	0.15 of failures	12.0 month

Mean duration of a major failure = $(0.85 \times 1.0 \text{ month}) + (0.15 \times 12.0 \text{ months}) = \mathbf{2.65 \text{ months}}$

2. Expected transformer unavailability calculation

This appendix shows the calculation of the “Expected Transformer Unavailability” for a terminal station with two transformers, using the basic reliability data contained in Section 5.4.

Expected transformer unavailability due to major outage per transformer-year (Refer to Section 5.4 for the base reliability statistics)	A	0.221%
Number of transformers	B	2
Expected unavailability of one transformer (probability of being in state N-1)	C=A*B	0.442%
Expected unavailability of both transformers (probability of being in state N-2)⁵⁰	D=A*A	0.00049%

⁵⁰ The coincident outages of two transformers are considered to be “independent events”. This means that the failure of one transformer is assumed to not affect the availability of the other.


3. Example calculation of expected costs of first and second order contingencies

The following example is used to illustrate the methodology to calculate expected unserved energy for a 2-transformer terminal station, given the following data and the load duration curve shown below:

Data

- Maximum Demand = 80 MW
- (N-1) Rating = 70 MW
- (N-2) Rating = 0 MW
- Annual Maximum Demand Growth Rate = 3.0%
- Annual Energy Growth Rate = 1.5%
- VCR = \$35,000 per MWh

Risk assessment results for first and second order contingencies (i.e. one and two transformers out of service, respectively) over 10 years are presented for this example. It is assumed that the shape of the load duration curve will not change over the forecast period. Detailed calculations are shown for the first year.



Risk Assessment Calculations for the first year

Energy at risk for an N-1 contingency is determined as the area below the load duration curve, but in excess of the N-1 rating, as shown above. For this example, this is given by:

$$\text{Energy above N-1 Rating in year 1} = 132 \text{ MWh}$$

Similarly, energy at risk for an N-2 contingency is determined as the area below the load duration curve, but in excess of the N-2 rating:

Energy above N-2 Rating in year 1 = 367,877 MWh

First Order Contingency (N-1)

Expected Unserved Energy = (Energy above N-1 Rating) * (N-1 Probability)
 = (132 MWh) * (0.442%) = 0.6 MWh

Customer Value = (Expected Unserved Energy) * (VCR)
 = (0.6 MWh) * (\$35,000 per MWh) = \$20,420


Second Order Contingency (N-2)

Expected Unserved Energy = (Energy above N-2 Rating) * (N-2 Probability)
 = (367,877 MWh) * (0.00049%) = 1.8 MWh

Customer Value = (Expected Unserved Energy) * (VCR)
 = (1.8 MWh) * (\$35,000 per MWh) = \$63,000

Based on the data set out above, the expected unserved energy and corresponding customer value can be calculated for each year over the next 10 years. The results of these calculations are summarised and presented in the table and chart below. The following conclusions can be drawn from the results:

- The value of expected unserved energy for a second order contingency is comparable to the value of expected unserved energy for a first order contingency in the earlier years (when the peak demand is roughly the same as the N-1 rating at the station). However, the combined total value of unserved energy for first and second order contingencies in those early years is highly unlikely to economically justify a large capital investment, such as the installation of a new transformer.
- Over the ten year planning horizon, the value of expected unserved energy for a first order contingency grows at a much faster rate than the value of expected unserved energy for a second order contingency.
- The value of expected unserved energy associated with second order contingencies only would be unlikely to be sufficiently high to economically justify any major augmentation. Hence, if a terminal station was expected to remain within its N-1 rating over the planning period, major augmentation (such as the installation of a third transformer) would not be economically justified.
- In undertaking a detailed economic evaluation of network investment, the quantity and value of energy at risk associated with higher order contingencies should be assessed. However, for the purpose of providing an indication of the likely timing of the need for new investment, it is sufficient to consider the expected unserved energy associated with first order contingencies only.



Summary of Risk Assessment Results for a 2-Transformer Terminal Station Example

	Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10
Maximum Demand (MW)	80.0	82.4	84.9	87.4	90.0	92.7	95.5	98.4	101.3	104.4
N-1 Risk Assessment										
Rating (MW)	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0	70.0
Demand above Rating (MW)	10.0	12.4	14.9	17.4	20.0	22.7	25.5	28.4	31.3	34.4
Energy above Rating (MWh)	132	231	374	565	838	1,253	1,914	3,003	4,759	7,393
Probability	0.442%	0.442%	0.442%	0.442%	0.442%	0.442%	0.442%	0.442%	0.442%	0.442%
Expected Unserved Energy (MWh)	0.6	1.0	1.7	2.5	3.7	5.5	8.5	13.3	21.0	32.7
Customer Value (\$)	20,420	35,736	57,858	87,406	129,639	193,839	296,096	464,564	736,217	1,143,697
N-2 Risk Assessment										
Rating (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Demand above Rating (MW)	80.0	82.4	84.9	87.4	90.0	92.7	95.5	98.4	101.3	104.4
Energy above Rating (MWh)	367,877	373,395	378,996	384,681	390,452	396,308	402,253	408,287	414,411	420,627
Probability	0.00049%	0.00049%	0.00049%	0.00049%	0.00049%	0.00049%	0.00049%	0.00049%	0.00049%	0.00049%
Expected Unserved Energy (MWh)	1.8	1.8	1.9	1.9	1.9	1.9	2.0	2.0	2.0	2.1
Customer Value (\$)	63,091	64,037	64,998	65,973	66,963	67,967	68,986	70,021	71,071	72,138

RISK ASSESSMENTS FOR INDIVIDUAL TERMINAL STATIONS (IN ALPHABETICAL ORDER)

ALTONA/BROOKLYN TERMINAL STATION (ATS/BLTS) 66 kV

Altona/Brooklyn Terminal Station (ATS/BLTS) 66 kV comprises two terminal stations in close proximity, connected by strong sub-transmission ties. The ATS/BLTS 66 kV supply area includes Altona, Bacchus Marsh, Brooklyn, Laverton North, Tottenham, Footscray and Yarraville. It is the main source of supply for 56,749 customers. The station is shared by Jemena Electricity Network (46%) and Powercor (54%).

ATS consists of three 150 MVA 220/66 kV transformers with the 2-3 66 kV bus tie circuit breaker locked open to manage fault levels. Under these arrangements, only one ATS 150 MVA 220/66 kV transformer operates in parallel with the BLTS system. BLTS has two 150 MVA 220/66 kV transformers supplying the BLTS 66 kV bus.


The existing synchronous condenser connected to the BLTS 66 kV bus was decommissioned in 2017 as it is no longer required.

The load characteristic for ATS/BLTS substation is of a mixed nature, consisting of residential and industrial customers. The peak load demand on the entire ATS/BLTS 66 kV network reached 234 MW (236 MVA) in summer 2020. In 2017 the BATS-BLTS tie was closed and 12 MW of load was transferred to Ballarat Terminal Station (BATS). Further, the completion of Deer Park Terminal Station in 2017 has enabled transfers away from the ATS-BLTS Terminal Station. These load reductions are reflected in the ATS/BLTS load forecast graph below.

It is estimated that:

- For 13 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at the time of peak demand is 0.99.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.



The “N” rating on the chart indicates the maximum load that can be supplied from ATS-BLTS with all transformers in service. The “N-1” rating on the chart is the load that can be supplied from ATS-BLTS with one 150 MVA transformer out of service.

The graph shows there is sufficient capacity at the station to supply all expected demand at the 50th percentile over the forecast period, even with one transformer out of service. Under 10th percentile forecast conditions, there is a small amount of load at risk from 2030 onwards, which can be managed by utilising load transfers away to ATS, BATS, DPTS and KTS. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

ALTONA WEST TERMINAL STATION (ATS West) 66 kV

Altona Terminal Station 66 kV comprises three 150 MVA 220/66 kV transformers. For reliability and maintenance of existing supply requirements, the station is configured so that one transformer operates in parallel with the BLTS system, and is isolated from the other two transformers via a permanently open 2-3 bus tie CB at ATS. This electrically separates the two systems and effectively creates two separate terminal stations. These stations are referred to as ATS/BLTS and ATS West (ATS bus 3 & 4).

Background


The ATS West 66 kV supply area includes Laverton, Laverton North, Altona Meadows, Werribee, Wyndham Vale, Mount Cottrell, Eynesbury, Tarneit, Hoppers Crossing and Point Cook. The station supplies 95,585 Powercor customers, as well as Air Liquide, a company supplied directly from the 66 kV bus at ATS. Air Liquide's load has been included in the following assessment.

Growth in summer peak demand on the 66 kV network at ATS West has averaged around 4.6% per annum over last five years. The peak load on the station reached 234 MW in summer 2020.

It is estimated that:

- For 13 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at the time of peak demand is 0.95.

ATS West is summer peaking with high demand occurring over a five month period. The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the stations operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature. The forecast includes planned transfers of approximately 30 MW from the heavily loaded LV and WBE zone substations (supplied by ATS West) to Deer Park Terminal Stations (DPTS), which are expected to occur by the end of 2020.




The “N” rating on the chart indicates the maximum load that can be supplied from ATS West with all transformers in service. The “N-1” rating on the chart is the load that can be supplied from ATS West with one 150 MVA transformer out of service.

The graph above shows that there is insufficient capacity to supply the forecast demand at 50th percentile temperature at ATS West if a forced outage of a transformer occurs.

Magnitude, probability and impact of loss of transformer (N-1 System Condition):

The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile demand forecast, and the hours per year that the 50th percentile demand forecast is expected to exceed the N-1 capability rating. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.



Comments on Energy at Risk

For an outage of one transformer at ATS West 66 kV, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 576.3 hours in 2030. The energy at risk at the 50th percentile temperature under N-1 conditions is estimated to be 16,018 MWh in 2030. The estimated value to consumers of the 16,018 MWh of energy at risk is approximately \$556.5 million (based on a value of customer reliability of \$34,740.48/MWh)⁵¹. In other words, at the 50th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at ATS West in 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$556.5 million.

⁵¹ The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

It is emphasised however, that the probability of a major outage of one of the two 150 MVA transformers occurring over the year is very low at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (16,018 MWh for 2030) is weighted by this low unavailability, the expected unsupplied energy is estimated to be around 64.4 MWh. This expected unserved energy is estimated to have a value to consumers of \$2.4 million (based on a value of customer reliability of \$34,740.48/MWh).

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) summer temperatures occurring in each year. Under 10th percentile temperature conditions, the energy at risk in 2030 is estimated to be 27,412 MWh. The estimated value to consumers of this energy at risk in 2020 is approximately \$952 million. The corresponding value of the expected unserved energy (of 118.8 MWh) is \$4.1 million.

These key statistics for the year 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast under N-1 outage condition	16,018	\$556.5 million
Expected unserved energy at 50 th percentile demand under N-1 outage condition	69.4	\$2.4 million
Energy at risk, at 10 th percentile demand forecast under N-1 outage condition	27,412	\$952 million
Expected unserved energy at 10 th percentile demand under N-1 outage condition	118.8	\$4.1 million

Possible Impact on Customers

System Normal Condition (Both transformers in service)

Applying the 50th percentile and 10th percentile demand forecasts, there is sufficient capacity at Altona West Terminal Station to meet all demand when both transformers are in service.

N-1 System Condition

If one of the 150 MVA 220/66 kV transformers at ATS West is taken offline during peak loading times and the N-1 station rating is exceeded, the OSSCA⁵² automatic load shedding scheme which is operated by AusNet Transmission Group's TOC⁵³ will act swiftly to reduce the loads in blocks to within safe loading limits. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with Powercor's operational procedures after the operation of the OSSCA scheme.

Possible load transfers away to ATS/BLTS and DPTS terminal stations in the event of a transformer failure at ATS West total 7 MVA in summer 2021.

⁵² Overload Shedding Scheme of Connection Asset.

⁵³ Transmission Operation Centre

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

1. Install additional transformation capacity and reconfigure 66 kV exits at ATS, at an estimated indicative capital cost of \$18 million (equating to a total annual cost of approximately \$1.33 million). This would result in the station being configured so that three transformers are supplying the ATS West load, and one transformer will continue to provide capacity to the ATS/BLTS system.
2. A new Tarneit zone substation is planned for 2023; however it is not a committed project at this point in time. This zone substation would be supplied from DPTS and will offload Werribee and Laverton zones substations in the order of 40 MW. This will not eliminate the load at risk at ATS West, only reduce it.
3. Demand reduction: There is an opportunity to develop innovative customer schemes to encourage voluntary demand reduction during times of network constraint. The amount of potential demand reduction depends on the customer uptake and would be taken into consideration when determining the optimum timing of any network capacity augmentation.
4. Embedded generation, connected to the ATS 66 kV bus, may substitute capacity augmentations.

Preferred network option(s) for alleviation of constraints

In the absence of commitment by interested parties to offer network support services by installing local generation or through demand side management initiatives that would reduce load at ATS, it is proposed to install additional transformation capacity and to reconfigure 66 kV exits at ATS.

On the basis of the present demand forecasts and applying the 2020 VCR estimates, the installation of an additional transformer and the 66 kV exit reconfiguration works at ATS would be expected to be economically justified by around 2029.

The tables on the following pages provide more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

Altona West Terminal Station

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station:

Powercor (100%)

MW

MVA

Normal cyclic rating with all plant in service

Summer N-1 Station Rating:

Winter N-1 Station Rating:

	340
158	170
176	187

via 2 transformers (Summer peaking)

[See Note 1 below for interpretation of N-1]

Station: ATS West	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	205.6	217.1	225.4	230.5	238.4	249.0	261.6	278.5	295.7	311.1
50th percentile Winter Maximum Demand (MVA)	154.8	160.0	164.9	171.0	178.3	186.6	196.2	207.4	220.8	234.0
10th percentile Summer Maximum Demand (MVA)	224.3	234.5	240.8	249.7	259.2	273.2	284.0	301.7	318.3	337.3
10th percentile Winter Maximum Demand (MVA)	162.0	167.3	172.9	178.9	186.7	195.9	205.1	216.6	229.7	245.9
N-1 energy at risk at 50th percentile demand (MWh)	361	713	1052	1327	1805	2597	3788	6002	9939	16018
N-1 hours at risk at 50th percentile demand (hours)	24.3	39.3	50.8	59.0	72.0	92.5	126.0	202.5	364.8	576.3
N-1 energy at risk at 10th percentile demand (MWh)	1016	1555	1967	2643	3518	5068	6740	10486	16487	27412
N-1 hours at risk at 10th percentile demand (hours)	49.0	65.0	76.3	93.8	114.8	153.5	204.8	343.8	553.5	883.8
Expected Unserved Energy at 50th percentile demand (MWh)	1.56	3.09	4.56	5.75	7.82	11.25	16.42	26.01	43.07	69.41
Expected Unserved Energy at 10th percentile demand (MWh)	4.40	6.74	8.52	11.45	15.24	21.96	29.21	45.44	71.44	118.79
Expected Unserved Energy value at 50th percentile demand	\$0.05M	\$0.11M	\$0.16M	\$0.20M	\$0.27M	\$0.39M	\$0.57M	\$0.90M	\$1.50M	\$2.41M
Expected Unserved Energy value at 10th percentile demand	\$0.15M	\$0.23M	\$0.30M	\$0.40M	\$0.53M	\$0.76M	\$1.01M	\$1.58M	\$2.48M	\$4.13M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.08M	\$0.15M	\$0.20M	\$0.26M	\$0.35M	\$0.50M	\$0.70M	\$1.11M	\$1.79M	\$2.93M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating.
Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating.
Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) is in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016
(see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

BALLARAT TERMINAL STATION (BATS) 66 kV

Ballarat Terminal Station (BATS) 66 kV consists of two 150 MVA 220/66 kV transformers and is the main source of supply for 70,987 customers in Ballarat and the surrounding area. The station supply area includes Ballarat CBD and Ararat via the interconnected 66 kV tie with Horsham Terminal Station (HOTS).


Magnitude, probability and impact of loss of load

In 2015, one of the 150 MVA transformers failed at BATS. AusNet Transmission Group replaced the failed transformer with the 150 MVA country spare transformer. Accordingly, the station ratings have changed, and these changes are depicted in the graph below. Growth in summer peak demand at BATS has averaged around 6.2 MVA (3.9%) per annum over the last 5 years. The peak load on the station reached 179 MW (182 MVA) in summer 2020.

It is estimated that:

- For 8 hours per year, 95% of peak demand is expected to be reached under the 50th percentile forecast.
- The station load power factor at the time of peak demand is 0.98.

The graph below depicts the 10th and 50th percentile maximum demand forecasts together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.




The N rating on the chart indicates the maximum load that can be supplied from BATS with all transformers in service. Exceeding this level will require load shedding or emergency load transfers to keep the terminal station operating within its limits.

The graph above shows that the historic peak demands had been at the 'N-1' rating for the last three years and it is expected that the 2021 summer peak demand will exceed this

rating, which means there will be insufficient capacity to supply the forecast demand at 50th percentile temperatures at BATS if a forced outage of a transformer occurs.

The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile demand forecast, and the hours per year that the 50th percentile demand forecast is expected to exceed the N-1 capability rating. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.



Comments on Energy at Risk

For an outage of one transformer at BATS 66 kV, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 218 hours in 2030. The energy at risk at the 50th percentile temperature under N-1 conditions is estimated to be 4020 MWh, which is valued at approximately \$137 million (based on a value of customer reliability of \$34,137/MWh). In other words, at the 50th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at BATS in 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$137 million.

It is emphasised however, that the probability of a major outage of one of the two 150 MVA transformers occurring over the year is very low at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (4,020 MWh for 2030) is weighted by this low unavailability, the expected unsupplied energy is estimated to be around 17.4 MWh. This expected unserved energy is estimated to have a value to consumers of \$594,000 (based on a value of customer reliability of \$34,137.44/MWh).

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) summer temperatures occurring in each year. Under 10th percentile temperature conditions, the energy at risk in

2030 is estimated to be 9,962 MWh. The estimated value to consumers of this energy at risk in 2030 is approximately \$340 million. The corresponding value of the expected unserved energy (of 43.2 MWh) is \$1.47 million.

These key statistics for the year 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	4,020	\$137 million
Expected unserved energy at 50 th percentile demand	17.4	\$594,000
Energy at risk, at 10 th percentile demand forecast	9,962	\$340 million
Expected unserved energy at 10 th percentile demand	43.2	\$1.47 million

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

- Installation of a third 220/66 kV transformer (150 MVA) at BATS at an indicative capital cost of \$14 million.
- Demand reduction: There is an opportunity to develop a number of innovative customer schemes to encourage voluntary demand reduction during times of network constraint. The amount of demand reduction would depend on the customer uptake and would be taken into consideration when determining the optimum timing for any future capacity augmentation.
- A new 144.4 MW Yendon Wind Farm (YDW), located 17 km southeast of Ballarat was commissioned in May 2019. It exports directly to BATS via a 66 kV connection and therefore is expected to reduce the peak demand that is seen on the BATS transformers. With the export of YDW, the load at risk at BATS is expected to be reduced or possibly removed.
- A new 30 MW 30 MWh battery storage system has been connected to one of the BATS 220/66/22 kV transformers. The battery storage will be able to help supply the loads for a period of time and may defer the need for any capacity augmentation within the forecast period.
- There are presently several large embedded generation 66 kV wind farm proposals in the area which may drive the need for an additional 220/66 kV transformer at BATS to accommodate the reverse power flow expected at BATS.

Preferred option(s) for alleviation of constraints

In the absence of any commitment by interested parties to offer network support services by installing local generation or through demand side management initiatives that would reduce load at BATS, it is proposed to:

1. Install a third 220/66 kV transformer (150 MVA) at BATS at an indicative capital cost of \$14 million. This equates to a total annual cost of approximately \$1.03 million per annum. On the basis of the medium economic growth scenario and both 50th and 10th percentile weather probability, the transformer would not be expected to be required in the forecast period.
2. As a temporary measure, maintain contingency plans to transfer load quickly to the Horsham Terminal Station (HOTS) and Brooklyn Terminal Station (BLTS 66) by the use of the 66 kV tie lines that run from BATS to HOTS and BATS to BLTS 66 in the event of an unplanned outage of one transformer at BATS under critical loading conditions. This load transfer is in the order of 18 MVA. Under these temporary measures, affected customers would be supplied from the 66 kV tie line infrastructure on a radial network, thereby reducing the level of supply reliability they receive.
3. Subject to availability, an AusNet Transmission Group spare 220/66 kV transformer for rural areas (refer Section 5.5) can be used to temporarily replace a failed transformer to minimise the transformer outage period.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

Ballarat Terminal Station

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: Powercor (100%)

MW MVA

Normal cyclic rating with all plant in service 358 via 2 transformers (summer)

Summer N-1 Station Rating: 183 [See Note 1 below for interpretation of N-1]

Winter N-1 Station Rating: 206

Station: BATS	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	193.4	199.1	202.8	207.6	213.4	221.5	231.9	242.7	253.5	268.4
50th percentile Winter Maximum Demand (MVA)	171.0	175.6	179.5	183.8	189.7	197.4	206.1	216.0	227.3	240.8
10th percentile Summer Maximum Demand (MVA)	211.0	217.8	223.4	227.1	236.1	243.1	252.9	266.1	278.7	292.8
10th percentile Winter Maximum Demand (MVA)	178.9	184.0	187.7	192.4	198.4	206.1	216.1	226.6	237.8	251.5
N-1 energy at risk at 50% percentile demand (MWh)	17.0	40.7	64.4	107.9	184.7	337.9	639.1	1136.9	1975.7	4020.3
N-1 hours at risk at 50th percentile demand (hours)	3.0	5.5	7.8	11.0	16.0	23.8	38.8	62.3	103.3	218.0
N-1 energy at risk at 10% percentile demand (MWh)	149.8	261.3	381.5	486.9	800.5	1149.7	1820.1	3186.9	5422.0	9961.6
N-1 hours at risk at 10th percentile demand (hours)	14.0	20.0	25.5	30.5	45.0	59.8	87.0	146.3	254.8	481.3
Expected Unserved Energy at 50th percentile demand (MWh)	0.07	0.18	0.28	0.47	0.80	1.46	2.77	4.93	8.56	17.42
Expected Unserved Energy at 10th percentile demand (MWh)	0.65	1.13	1.65	2.11	3.47	4.98	7.89	13.81	23.50	43.17
Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.01M	\$0.01M	\$0.02M	\$0.03M	\$0.05M	\$0.09M	\$0.17M	\$0.29M	\$0.59M
Expected Unserved Energy value at 10th percentile demand	\$0.02M	\$0.04M	\$0.06M	\$0.07M	\$0.12M	\$0.17M	\$0.27M	\$0.47M	\$0.80M	\$1.47M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.01M	\$0.02M	\$0.02M	\$0.03M	\$0.05M	\$0.09M	\$0.15M	\$0.26M	\$0.45M	\$0.86M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which specified demand forecast exceeds the N-1 capability rating.
3. "N-1 hours at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating.
4. "Expected unserved energy" means "N-1 energy at risk" for the specified demand forecast multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with a duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx).


BENDIGO TERMINAL STATION (BETS) 22 kV

Bendigo Terminal Station (BETS) 22 kV consists of two 75 MVA 235/22.5 kV transformers supplying the 22 kV network ex-BETS. These two transformers have been in service since mid 2013 and they have enabled the separation of the 66 kV and 22 kV points of supply, and the transfer of load from the existing 230/66/22kV transformers. This configuration is the main source of supply for 27,401 customers in Bendigo and the surrounding area. The station supply area includes Marong, Newbridge and Lockwood.

BETS 22 kV demand is summer peaking. Growth in summer peak demand on the 22 kV network at BETS has averaged around 1.7 MVA (2.7%) per annum over the last 5 years. The peak load for the 22 kV network now on the station reached 78.5 MVA in summer 2020. There were load transfers from Eaglehawk Zone Substation to BETS 22 which have contributed to the higher peak demand since 2016 compared to 2015. It is estimated that:

- For 9 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at the time of peak demand is 0.99.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.



The above graph shows that there is sufficient capacity at the station to supply all expected demand at the 50th and 10th percentile temperature, over the forecast period, even with one transformer out of service. Under 10th percentile forecast conditions, there is a small amount of load at risk from 2028 onwards, which can be managed by utilising load transfers away to adjacent zone substations. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

BENDIGO TERMINAL STATION (BETS) 66 kV

Background

In 2013, AusNet Transmission Group commissioned 2x75 MVA 220/22 kV transformers to pick up the 22 kV load from the tertiary of the existing 230/66/22 kV transformers. The 66 kV and 22 kV points of supply at Bendigo Terminal Station are now segregated and supplied from separate transformers.

Also in 2013, two 70/57/51 MVA 230/66/22 kV transformers were retired and one new 150 MVA 220/66 kV transformer was commissioned in service supplying the 66 kV buses in parallel with one existing 125/125/40 MVA 230/66/22 kV transformer. These transformers provide the main source of 66 kV supply for 60,955 customers in Bendigo and the surrounding area. The station supply area includes Bendigo CBD, Eaglehawk, Charlton, St. Arnaud, Maryborough and Castlemaine.


AusNet Transmission Group down-rated the transformers in 2015. As a result the BETS 66 station has new ratings with the N rating reduced from 350 MVA to 310.9 MVA and the N-1 rating reduced from 180 MVA to 146.7 MVA in summer. These new ratings are depicted in the graph below.

Magnitude, probability and impact of loss of load

Growth in summer peak demand at BETS 66 kV has averaged around 2.6 MVA (1.7%) per annum over the last 5 years. The peak load on the station reached 166.7 MW in summer of 2020. It is estimated that:


- For 13 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at time of peak demand is 0.99.

BETS 66 kV demand is summer peaking. The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperatures.



The (N) rating on the chart indicates the maximum load that can be supplied from BETS with all transformers in service. Exceeding this level will initiate automatic load shedding by AusNet Transmission Group's automatic load shedding scheme.

The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile demand forecast, and the hours per year that the 50th percentile demand forecast is expected to exceed the N-1 capability rating. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.



Comments on Energy at Risk

For a major outage of one transformer at BETS 66 kV during the summer period, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 127.5 hours in 2030. The energy at risk at the 50th percentile temperature under N-1 conditions is estimated to be 2,589 MWh in 2030. The estimated value to consumers of the 2,589 MWh of energy at risk is approximately \$96.1 million (based on a value of customer reliability of \$37,134/MWh).⁵⁴ In other words, at the 50th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at BETS 66kV in 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers approximately \$96.1 million.

It is emphasised however, that the probability of a major outage of one of the two transformers occurring over the year is very low at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at

⁵⁴ The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

risk (2,589 MWh for 2030) is weighted by this low unavailability, the expected unsupplied energy is estimated to be around 5.6 MWh. This expected unserved energy is estimated to have a value to consumers of around \$0.21 million, (based on a value of customer reliability of \$37,134 /MWh).

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) summer temperatures occurring in each year. Under 10th percentile temperature conditions, the energy at risk in 2030 is estimated to be 5,812 MWh. The estimated value to consumers of this energy at risk in 2030 is approximately \$215.8 million. The corresponding value of the expected unserved energy (of 12.6 MWh) is approximately \$0.47 million.

These key statistics for the year 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	2,589	\$96.1 million
Expected unserved energy at 50 th percentile demand	5.6	\$0.21 million
Energy at risk, at 10 th percentile demand forecast	5,812	\$215.8 million
Expected unserved energy at 10 th percentile demand	12.6	\$0.47 million

Possible impacts of a transformer outage on customers

If one of the 230/66/22 kV transformers at BETS 66 kV is taken off line during peak loading times and the N-1 station rating is exceeded, the OSSCA⁵⁵ automatic load shedding scheme which is operated by AusNet Transmission Group's TOC⁵⁶ will act swiftly to reduce the loads in blocks to within safe loading limits. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with Powercor's operational procedures after the operation of the OSSCA scheme.

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or alleviate the emerging constraint over the next ten year planning horizon:

1. Implement a contingency plan to transfer 15 MVA of load away to BETS 22 kV, WETS, KTS East and SHTS in the event of loss of a transformer at BETS 66 kV.
2. Install an additional 150 MVA 220/66 kV transformer at BETS 66 kV at an estimated indicative capital cost of approximately \$18 million (equating to a total annual cost of approximately \$1.33 million per annum). This would result in the station being configured so that three transformers are supplying the BETS 66 kV load.

⁵⁵ Overload Shedding Scheme of Connection Asset.

⁵⁶ Transmission Operation Centre.

3. Demand reduction: There is an opportunity for voluntary demand reduction to reduce peak demand during times of network constraint. The amount of demand reduction would be taken into consideration when determining the optimum timing for the capacity augmentation.
4. Embedded generation, connected to the BETS 66 kV bus, may defer the need for an additional 220/66 kV transformer at BETS 66 kV.

Preferred option(s) for alleviation of constraints

As already noted, a contingency plan to transfer 20 MVA of load to BETS 22 kV, WETS, KTS East and SHTS will be implemented in the event of the loss of one of the BETS 220/66 kV transformers.

Given the contingency plans in place to address the forecast load at risk, it is unlikely that additional capacity can be economically justified during the forecast period. Demand reduction to reduce the load below the N-1 rating would be the preferred option.

Subject to availability, an AusNet Transmission Group spare 220/66 kV transformer for rural areas (refer to Section 5.5) can be used to temporarily replace a failed transformer to minimise the transformer outage period.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

Bendigo Terminal Station

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: Powercor (100%)

Normal cyclic rating with all plant in service 310.9 MVA via 2 transformers (Summer peaking)

Summer N-1 Station Rating: 146.7 MVA [See Note 1 below for interpretation of N-1]

Winter N-1 Station Rating: 173.7 MVA

Station: BETS66	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	157.8	165.3	167.6	169.4	172.5	176.7	182.1	189.3	197.9	207.8
50th percentile Winter Maximum Demand (MVA)	126.5	129.9	131.7	132.3	135.2	138.8	143.1	148.9	155.9	164.0
10th percentile Summer Maximum Demand (MVA)	176.6	184.5	187.0	189.2	192.5	197.5	203.3	211.2	220.6	231.5
10th percentile Winter Maximum Demand (MVA)	130.5	134.8	135.7	137.7	139.9	143.5	148.2	154.0	160.9	169.3
N-1 energy at risk at 50th percentile demand (MWh)	40	135.5	176.6	215.9	291.9	422.5	645.9	1038.6	1666.0	2588.6
N-1 hours at risk at 50th percentile demand (hours)	8.5	17.5	20.5	23.8	28.8	38.0	52.8	71.0	96.5	127.5
N-1 energy at risk at 10th percentile demand (MWh)	419	765	901	1037	1256	1630	2142	2964	4148	5812
N-1 hours at risk at 10th percentile demand (hours)	37.8	58.8	64.5	71.0	80.0	95.0	112.5	140.0	173.3	217.8
Expected Unserved Energy at 50th percentile demand (MWh)	0.1	0.3	0.4	0.5	0.6	0.9	1.4	2.3	3.6	5.6
Expected Unserved Energy at 10th percentile demand (MWh)	0.9	1.7	2.0	2.2	2.7	3.5	4.6	6.4	9.0	12.6
Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.01M	\$0.01M	\$0.02M	\$0.02M	\$0.03M	\$0.05M	\$0.08M	\$0.13M	\$0.21M
Expected Unserved Energy value at 10th percentile demand	\$0.03M	\$0.06M	\$0.07M	\$0.08M	\$0.10M	\$0.13M	\$0.17M	\$0.24M	\$0.33M	\$0.47M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.01M	\$0.03M	\$0.03M	\$0.04M	\$0.05M	\$0.06M	\$0.09M	\$0.13M	\$0.19M	\$0.29M

Notes:

1. "N-1" means cyclic station transformer output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)


BROOKLYN TERMINAL STATION (BLTS) 22 kV

The Brooklyn Terminal Station (BLTS) 22 kV supply area includes Altona, Brooklyn and Laverton North. The station supplies both Jemena Electricity Network (3%) and Powercor (97%) customers.

Brooklyn Terminal Station (BLTS) 22 kV is the main source of supply for 7,314 customers in Brooklyn and the surrounding area. The load characteristic for BLTS 22 kV substation is of a mixed nature, consisting of residential and industrial customers. In recent years, the industrial load has declined in the area; however this has been offset by some growth from residential developments. The peak load demand on the entire BLTS 22 kV network reached 57.6 MW (63.3 MVA) in summer 2020. It is estimated that:

- For 42 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station transformer power factor at the time of peak demand is 0.91.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.



The "N" rating on the chart indicates the maximum load that can be supplied from BLTS 22 kV Terminal Station with all transformers in service. The "N-1" rating on the chart is the load that can be supplied with one 75 MVA transformer out of service.

The graph shows there is sufficient capacity at the station to supply all expected demand at the 10th and 50th percentile temperature, over the forecast period, with one transformer out of service. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

BRUNSWICK TERMINAL STATION 22 kV (BTS 22 kV)

BTS 22 kV is a terminal station located in an inner northern suburb of Melbourne and shared by Jemena Electricity Networks (52%) and CitiPower (48%). It operates at 220/22 kV and supplies a total of approximately 45,611 customers in the Brunswick, Fitzroy, Northcote, Fairfield, Essendon, Ascot Vale and Moonee Ponds areas.


BTS 22 kV is a summer critical station with three 75 MVA transformers operating in parallel.

The peak load on the station transformers reached 109.1 MW (or 112.6 MVA) on 31 January 2020.

It is estimated that:

- For 12 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station transformer load power factor at the time of peak demand is 1.0.

The graph below depicts the BTS 22 kV operational “N-1” rating (for an outage of one transformer) at ambient temperatures of 38°C and 43°C, and the 50th and 10th percentile summer maximum demand forecasts⁵⁷.



The graph shows there is sufficient station capacity to supply all anticipated loads and that no customers would be at risk if a forced transformer outage occurred at BTS 22 kV over the forecast period. Accordingly, no capacity augmentation or other corrective action is planned at BTS 22 kV over the next ten years.

⁵⁷ Note that station transformer output capability rating and transformers' loading is used.


BRUNSWICK TERMINAL STATION 66 kV (BTS 66 kV)

Brunswick Terminal Station (BTS) 66 kV consisting of 3 x 225 MVA 220/66 kV transformers. It reinforces the security of supply to the northern and inner suburbs and the Central Business District areas. It currently provides supply to approximately 27,769 customers.

Magnitude, probability and impact of loss of load

The BTS load includes transfers from RTS 66 and WMTS 22 which occurred in September 2020 (the subsequent change in peak demand will occur in the 2020/21 summer) as shown below. The BTS demand is summer peaking. The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35 deg C ambient temperature.

The 50th percentile peak load on the station reached 169.8 MW in summer 2019/20 with a station load power factor of 0.97. The number of hours per year in which 95% of peak load is expected to be reached is estimated to be 3 hours.



BTS 66 is one of the terminal stations supplying the Melbourne CBD. In order to meet the code requirements of security of supply to the Melbourne CBD, CitiPower has been undertaking works to re-configure the CBD 66 kV network to provide the required security to maintain supply from alternate supply points. This means that for an 'N-1' event in other parts of the CBD network, additional load can be switched onto BTS 66. This required additional capacity must be reserved at the terminal station to ensure that CBD load can be supplied under any of the CBD Security contingency arrangements.

The graph above shows that there is expected to be sufficient capacity at the station to supply all expected load over the forecast period, even with one transformer out of service. Therefore, the need for augmentation or other corrective action at the station is not expected to arise over the current ten year planning horizon.

CRANBOURNE TERMINAL STATION (CBTS)

Cranbourne Terminal Station (CBTS) was originally commissioned with two 150 MVA 220/66 kV transformers in 2005 to reinforce the security of supply for United Energy and AusNet Electricity Services customers and to off-load East Rowville Terminal Station (ERTS). In order to supply the growing electricity demand in the area, a third 150 MVA 220/66 kV transformer was commissioned in 2009.


In late-2020, AusNet Transmission Group reviewed and updated the cyclic ratings of the CBTS transformers. That review resulted in an increased “N” summer cyclic rating of 553 MVA, up from 538 MVA, and an increased “N-1” summer cyclic rating of 369 MVA, up from 356 MVA. The increased cyclic rating is a result of a changing transformer load profile driven by increased distributed energy resources (DER) reducing station loading during the day.

The geographic area supplied by CBTS spans from Narre Warren in the north to Clyde in the south, and from Pakenham in the east to Carrum and Frankston in the west. The electricity distribution networks for this area are the responsibility of both AusNet Electricity Services (62%) and United Energy (38%).

Magnitude, probability and impact of loss of load

CBTS 66 kV is a summer peaking station. The summer peak demand at CBTS 66 kV has increased by 172 MVA between 2007/08 and 2019/20, which is equivalent to an average annual growth rate of 4.1%. In 2019/20 the summer peak demand on the station reached 470.6 MW (481.9 MVA), which is the highest annual peak demand recorded. The station load has a power factor of 0.98 at maximum demand. Demand at CBTS 66 kV is expected to exceed 95% of the 50th percentile peak demand for 2 hours per annum.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station’s expected operational “N” rating (all transformers in service) and the “N-1” rating at 35°C as well as 40°C ambient temperatures.




The “N” rating on the chart indicates the maximum load that can be delivered from CBTS 66 kV with all transformers in service. Exceeding this level would require load shedding or emergency load transfers to keep the terminal station operating within its limits.


Load at CBTS 66 kV is forecast to be above the station’s “N” rating under 10th percentile summer maximum demand conditions from summer 2022/23 but remain within its 50th percentile “N” rating throughout the planning horizon.

The winter ratings of transformers are higher than the summer ratings due to lower ambient temperatures. The maximum demand at CBTS in winter is also much lower than in summer. Thus, energy at risk during the winter period is much lower than the summer period. The graph below demonstrates the 10th and the 50th percentile winter maximum demand forecast together with the station’s operational “N” rating and “N-1” rating for winter.

CBTS 66 kV Winter Peak Demand Forecasts



The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile demand forecast, and the hours per year that the 50th percentile demand forecast is expected to exceed the “N-1” capability rating. The line graph shows the cost to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.



Comments on Energy at Risk

As already noted, CBTS 66 kV is a summer peaking station and most of the energy at risk occurs in the summer period because the rating of the transformers is lower at higher ambient temperatures in addition to higher summer demand. For simplicity therefore, the comments below focus on the energy at risk over the summer period.

For an outage of one 220/66 kV transformer at CBTS, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 46 hours in 2020/21. The energy at risk under “N-1” conditions is estimated to be 1,457 MWh in 2020/21. The estimated value to consumers of the 1,457 MWh of energy at risk is approximately \$51 million (based on a value of customer reliability of \$34,778/MWh)⁵⁸. In other words, at the 50th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one 220/66 kV transformer at CBTS for the entire duration of the 2020/21 summer would lead to involuntary supply interruptions that are valued by consumers at \$51 million.

It is emphasised however, that the probability of a major transformer outage is very low, with a network average of 1.0% per transformer per annum applied for this TCPR assessment, contributing to an expected unavailability per transformer per annum of 0.221%. When the energy at risk (1,457 MWh) is weighted by this low unavailability, the expected unserved energy is estimated to be around 9.7 MWh. This expected unserved energy is estimated to have a value to consumers of around \$0.34 million (based on a value of customer reliability of \$34,778/MWh).

The above estimates of energy at risk and expected unserved energy are based on an assumption of moderate temperatures occurring in each year. Under higher temperature

⁵⁸ The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

conditions (that is, at the 10th percentile level), there is a higher amount of energy at risk, which is estimated to be 5,747 MWh in summer 2020/21. The total estimated value to consumers of this energy at risk in 2020/21 is approximately \$200 million. The corresponding value of the expected unserved energy (of 38.1 MWh) is \$1.36 million.

These key statistics for the year 2020/21 are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	1,457	\$51 million
Expected unserved energy at 50 th percentile demand	9.7	\$0.34 million
Energy at risk, at 10 th percentile demand forecast	5,747	\$200 million
Expected unserved energy at 10 th percentile demand	38.1	\$1.36 million

Possible impacts of a transformer outage on customers

If one of the 220/66 kV transformers at CBTS is taken out of service during peak loading times and the N-1 station rating is exceeded, the Overload Shedding Scheme for Connection Assets (OSSCA)⁵⁹ which is operated by AusNet Transmission Group's TOC⁶⁰ will act swiftly to reduce the loads in blocks to within ratings of available plant. In the event of OSSCA operating, it would automatically shed up to 180 MVA of load, affecting up to 75,000 customers in 2020/21. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with United Energy's and AusNet Electricity Services' operational procedures after the operation of the OSSCA scheme.

Feasible options for alleviation of constraints

The following options are technically feasible actions to mitigate the risk of supply interruption and/or to alleviate the emerging constraint.

1. Implement contingency plans to transfer load to adjacent terminal stations: Both AusNet Electricity Services and United Energy have established and implemented the necessary plans that enable load transfers under contingency conditions via both 22 kV distribution and emergency 66 kV ties to the adjacent terminal stations at East Rowville (ERTS 66 kV), Tyabb (TBTS 66 kV) and Heatherton (HTS 66 kV). The 22 kV distribution network is capable of transferring approximately 70 MVA. Where required, such as if a 10th percentile temperature day was anticipated, the 22 kV load transfers would also be utilised to manage system normal loading to within the terminal station's limits until augmentation is economically justified and implemented. The emergency 66 kV ties can be in operation within 2 hours and have a combined capability to transfer up to 150 MVA of load.
2. Establish a new 220/66 kV terminal station: AusNet Electricity Services expects that a new terminal station in the Pakenham area (with a site yet to be acquired) will be required

⁵⁹ OSSCA is designed to protect connection transformers against transformer damage caused by overloads. Damaged transformers can take months to repair or replace, which can result in prolonged, long term risks to the reliability of customer supply.

⁶⁰ Transmission Operations Centre

in around 10 to 20 years to service demand growth in the region. This development will help to off-load CBTS as well as address constraints on the existing 66 kV sub-transmission network from CBTS to the Pakenham area. AusNet Electricity Services will carry out planning studies to assess whether this option is economic, and if so, to determine the optimal timing of any investment. An alternative would be to develop a new terminal station on a reserved site in North Pearcedale. The North Pearcedale site, however, is not located within the growth area and is considered suboptimal at this time.

3. Install a 4th 220/66 kV transformer at Cranbourne Terminal Station: The site has provision for a 4th transformer and implementing this option is relatively straight forward, although it would require 66 kV lines to be re-arranged so that the station can operate with split 66 kV buses in order to maintain fault levels within equipment ratings.
4. Install two new 50 MVAR 66 kV capacitor banks: CBTS currently does not have 66 kV capacitor banks and the station operates with a power factor around 0.98 lagging in summer. Two 50 MVAR 66 kV capacitor banks will help to reduce the net MVA supplied by the transformers by approximately 11 MVA and could defer a network augmentation by approximately one year.
5. Demand Management: United Energy and AusNet Electricity Services have developed a number of innovative network tariffs that encourage voluntary demand reduction during times of network constraints. The amount of demand reduction depends on the tariff uptake and the subsequent change in the load pattern, and will be taken into consideration when determining the optimum timing for the capacity augmentation.
6. Embedded Generation: Embedded generation, with a capacity in the order of 20 MW, connected to the CBTS 66 kV bus, could defer the need for augmentation by approximately two years.

Preferred network option for alleviation of constraints

AusNet Electricity Services and United Energy have completed Stage 1, the project specification consultation report (PSCR), of the Regulatory Investment Test for Transmission (RIT-T) to address the supply risks at CBTS⁶¹. That report demonstrated that based on the 2019 maximum demand forecasts and the 2019 station ratings the optimal economic timing for installation of a fourth 220/66 kV transformer was by summer 2022/23. With the change in discount rate, demand forecasts and revision of the station cyclic ratings, this optimal timing has now been revised to 2025/26, or possibly 2026/27 considering available load transfers.

AusNet Services and United Energy received two submissions to the RIT-T PSCR, one to establish a large battery energy storage facility and the other proposing demand management services to defer installation of the fourth 220/66 kV transformer. These non-network options are currently being assessed alongside the other credible options identified. The outcome of this assessment will be communicated to the submission proponents. Progression to Stage 2 of the RIT-T assessment, publication of the project assessment draft report (PADR), will depend on the actual demand levels observed during the 2020/21 summer period, and any demand forecast revision resulting from these demand observations.

Subject to availability, one of AusNet Transmission Group's spare 220/66 kV transformers for the metropolitan area (refer Section 5.5) can be used to temporarily replace a failed

⁶¹ [Regulatory Investment Test \(ausnetservices.com.au\)](https://www.ausnetservices.com.au)

transformer at CBTS. Given the identified risks, AusNet Transmission Group is also considering relocating the metro spare transformer to CBTS.

Prior to implementing any augmentation option, the following temporary measures to cater for any “N” risk and an unplanned outage of one transformer at CBTS under critical loading conditions have been established:

- maintain emergency plans to transfer load to adjacent terminal stations via 22 kV feeders and 66 kV tie lines;
- fine-tune the OSSCA scheme settings to minimise the impact on customers of any automatic load shedding that may take place; and
- subject to the availability of a spare 220/66 kV transformer for metropolitan areas (refer Section 5.5), a spare transformer can be used to temporarily replace a failed transformer.

The capital cost of installing a fourth 150 MVA 220/66 kV transformer at CBTS is estimated to be \$26 million. The cost of establishing, operating and maintaining a new transformer would be recovered from network users through network charges, over the life of the asset. The estimated total annual cost of this network augmentation is approximately \$1.9 million. This cost provides a broad upper bound for the maximum annual network support payment which may be available to embedded generators or customers to reduce forecast demand, and to defer or avoid the transmission connection component of this augmentation. Any non-network solution that defers this augmentation for say 1-2 years, will not have as much potential value (and contribution available from distributors) as a solution that eliminates or defers the augmentation for, say, 10 years.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

CRANBOURNE TERMINAL STATION**Detailed data: Magnitude and probability of loss of load**

Distribution Businesses supplied by this station:

United Energy (38%) and AusNet Electricity Services (62%)

Normal cyclic rating with all plant in service

553 MVA via 3 transformers (Summer peaking)

Summer N-1 Station Rating

369 MVA [See Note 1 below for interpretation of N-1]

Winter N-1 Station Rating

413 MVA

Station: CBTS 66 kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	469.4	477.7	486.9	491.5	496.9	503.3	509.5	515.9	524.3	531.0
50th percentile Winter Maximum Demand (MVA)	343.4	351.0	358.9	363.5	368.2	372.5	376.8	381.8	386.4	391.1
10th percentile Summer Maximum Demand (MVA)	522.1	531.4	541.5	547.5	556.4	563.0	571.0	576.6	585.6	593.5
10th percentile Winter Maximum Demand (MVA)	349.9	357.7	365.8	370.6	375.5	379.9	384.4	389.6	394.4	399.3
N - 1 energy at risk at 50th percentile demand (MWh)	1,457	1,804	2,241	2,479	2,781	3,163	3,569	4,013	4,651	5,192
N - 1 hours at risk at 50th percentile demand (hours)	46	53	60	64	70	77	84	90	99	106
N - 1 energy at risk at 10th percentile demand (MWh)	5,747	6,426	7,213	7,716	8,497	9,114	9,896	10,466	11,430	12,303
N - 1 hours at risk at 10th percentile demand (hours)	85	94	103	108	116	124	132	137	146	154
N energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N energy at risk at 10th percentile demand (MWh)	0	0	1	12	66	127	217	295	444	596
N and N-1 Expected Unserved Energy at 50th percentile demand (MWh)	10	12	15	16	18	21	24	27	31	34
N and N-1 Expected Unserved Energy at 10th percentile demand (MWh)	38	43	48	63	122	187	283	364	519	678
N and N-1 Expected Unserved Energy value at 50th percentile demand	\$0.34M	\$0.42M	\$0.52M	\$0.57M	\$0.64M	\$0.73M	\$0.82M	\$0.92M	\$1.07M	\$1.20M
N and N-1 Expected Unserved Energy value at 10th percentile demand	\$1.32M	\$1.48M	\$1.68M	\$2.20M	\$4.25M	\$6.50M	\$9.84M	\$12.66M	\$18.06M	\$23.57M
N and N-1 Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.63M	\$0.74M	\$0.87M	\$1.06M	\$1.72M	\$2.46M	\$3.53M	\$4.44M	\$6.17M	\$7.91M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an summer ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

DEER PARK TERMINAL STATION (DPTS) 66 kV

Deer Park Terminal Station (DPTS) 66 kV consists of two 225 MVA 220/66 kV transformers connected into one of three existing KTS-GTS 220 kV lines, and is located at the corner of Christies Road and Riding Boundary Road in Deer Park. The station supplies 70,604 Powercor customers in the areas of Sunshine, Truganina, Tarneit, Laverton North, Caroline Springs and Melton.

DPTS was commissioned for service in the fourth quarter of 2017. It has enabled the offloading of both transformer groups at KTS, thereby mitigating a significant emerging constraint at KTS from summer 2017/18 onwards. The initial transfer to the new DPTS of SU (Sunshine) zone substation from KTS (B1,2,5) transformer group has been completed and the transfer of MLN (Melton) zone substation from KTS (B3,4) group was completed during Autumn of 2018. DPTS also supplies a nearby new zone substation, Truganina (TNA), offloading nearby LV (Laverton), LVN (Laverton North), SU and WBE (Werribee) zone substations, and augments supply to the fast-growing western suburbs of Melbourne.

The transfer of load from LV, WBE and LVN zone substations which were supplied from ATS West and ATS/BLTS terminal stations respectively also defers augmentation at those terminal stations.


Magnitude, probability and impact of loss of load

The peak load on the station reached 217.6 MW in summer 2020. Peak demand at the 10th percentile temperature is forecast to increase to 437.6 MW by 2030, due to the high load growth in the western suburbs of Melbourne and additional transfers from LVN, , LV and WBE zone substations.

It is estimated that:

- For 15 hours per year, 95% of peak demand is expected to be reached under the 50th percentile forecast.
- The station load power factor at time of peak demand is 0.98

The graph below depicts the 10th and 50th percentile maximum demand forecasts together with the stations estimated operational “N” rating (all transformers in service) and the “N-1” rating at 35°C ambient temperature.




The (N) rating on the chart indicates the maximum load that can be supplied from DPTS with all transformers in service. The “N-1” rating on the chart is the load that can be supplied from DPTS with one 225 MVA transformer out of service.

The graph shows there is insufficient capacity at the station to supply all expected demand at the 50th percentile temperature from 2023 and from 2022 at the 10th percentile temperature if a forced outage of a transformer occurs.

The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile demand forecast, and the hours per year that the 50th percentile demand forecast is expected to exceed the N-1 capability rating. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.

At present, a spare 225 MVA transformer suitable for installation at DPTS is not available. CitiPower-Powercor have adopted the conservative assumption that a major transformer failure would be highly unlikely to be repairable, and therefore a replacement transformer would need to be procured. The procurement of a replacement would take 12 months, so in the case of DPTS, a major outage of a transformer is assumed to have a duration of 12 months.



Comments on Energy at Risk

For a major (12 month) outage of one transformer at DPTS 66 kV, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 12.3 hours in 2026. The energy at risk at the 50th percentile temperature under N-1 conditions is estimated to be 133.1 MWh in 2026. The estimated value to consumers of the 133.1 MWh of energy at risk is approximately \$5.05 million (based on a value of customer reliability of

\$37,952/MWh)⁶². In other words, at the 50th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at DPTS in 2026 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$5.05 million.

It is emphasised however, that the probability of a major outage of one of the two 225 MVA transformers occurring over the year is very low at about 1.0% per transformer per annum, which, as already noted, in the case of DPTS equals the expected unavailability per transformer per annum due to Transgrid not holding a spare transformer. When the energy at risk (133.1 MWh for 2026) is weighted by this low unavailability, the expected unsupplied energy is estimated to be around 5.32 MWh. This expected unserved energy is estimated to have a value to consumers of \$202,000 (based on a value of customer reliability of \$37,952/MWh).

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) summer temperatures occurring in each year. Under 10th percentile temperature conditions, the energy at risk in 2026 is estimated to be 669.6 MWh. The estimated value to consumers of this energy at risk in 2026 is approximately \$25.4 million. The corresponding value of the expected unserved energy (of 26.8 MWh) is \$1.02 million.

These key statistics for the year 2026 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50th percentile demand forecast under N-1 outage condition	133.1	\$5.05 million
Expected unserved energy at 50th percentile demand under N-1 outage condition	5.32	\$0.2 million
Energy at risk, at 10th percentile demand forecast under N-1 outage condition	669.9	\$25.4 million
Expected unserved energy at 10th percentile demand under N-1 outage condition	26.8	\$1.02 million

Possible Impact on Customers

System Normal Condition (Both transformers in service)

Applying the 50th percentile and 10th percentile demand forecasts, there is sufficient capacity at Deer Park Terminal Station to meet all demand when both transformers are in service.

N-1 System Condition

If one of the 225 MVA 220/66 kV transformers at Deer Park is taken offline during peak loading times and the N-1 station rating is likely to be exceeded, transfers will be undertaken to KTS to avoid overloading the remaining transformer. Possible load transfers away to ATS/BLTS and ATS West terminal stations in the event of a transformer failure at DPTS total 15 MVA in summer 2026.

⁶² The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

Preferred option(s) for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

5. Install additional transformation capacity at DPTS, at an estimated indicative capital cost of approximately \$18 million (equating to a total annual cost of approximately \$1.33 million per annum). This would result in the station being configured so that three transformers are supplying the DPTS load.
6. Demand reduction: There is an opportunity to develop innovative customer schemes to encourage voluntary demand reduction during times of network constraint. The amount of potential demand reduction depends on the customer uptake and would be taken into consideration when determining the optimum timing of any network capacity augmentation.
7. Embedded generation, connected to the DPTS 66 kV bus, may possibly act as a substitute for capacity augmentations.
8. Procurement of a dedicated spare transformer at an annual cost of approximately \$300,000 to allow a fast replacement of a failed unit.

Preferred network option for alleviation of constraints

In the absence of a commitment by interested parties to offer network support services that would reduce the load at DPTS, the preferred network option to address emerging constraints at DPTS would be to procure a dedicated spare transformer. Given the present forecasts of expected unserved energy, the procurement of a spare transformer at DPTS is justified by 2026.

Deer Park Terminal Station

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station:

Powercor (100%)

MW

MVA

Normal cyclic rating with all plant in service

Summer N-1 Station Rating:

Winter N-1 Station Rating:

	MW	MVA
		560
	269	280
	289	300

via 2 transformers (Summer peaking)

[See Note 1 below for interpretation of N-1]

Station: DPTS66	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	234.3	268.1	284.0	290.8	299.8	310.6	325.7	343.1	358.1	379.2
50th percentile Winter Maximum Demand (MVA)	187.1	213.0	220.8	225.2	231.2	238.9	248.4	259.8	272.2	287.1
10th percentile Summer Maximum Demand (MVA)	254.9	288.3	306.4	314.9	328.1	337.2	352.7	369.3	389.8	413.1
10th percentile Winter Maximum Demand (MVA)	192.4	219.1	226.9	231.7	238.3	246.4	256.0	267.2	280.6	296.1
N-1 energy at risk at 50% percentile demand (MWh)	0.0	0.0	2.3	13.3	43.9	133.1	375.0	851.8	1498.7	2780.7
N-1 hours at risk at 50th percentile demand (hours)	0.0	0.0	1.3	2.3	5.5	12.3	23.3	39.3	58.3	86.3
N-1 energy at risk at 10% percentile demand (MWh)	0.0	8.4	90.3	186.8	424.7	669.6	1239.6	2122.4	3602.3	5880.4
N-1 hours at risk at 10th percentile demand (hours)	0.0	2.0	9.3	15.0	25.5	33.5	51.0	71.8	100.8	142.0
Expected Unserved Energy at 50th percentile demand (MWh)	0.00	0.00	0.09	0.53	1.76	5.32	15.00	34.07	59.95	111.23
Expected Unserved Energy at 10th percentile demand (MWh)	0.00	0.34	3.61	7.47	16.99	26.78	49.58	84.89	144.09	235.22
Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.02M	\$0.07M	\$0.20M	\$0.57M	\$1.29M	\$2.28M	\$4.22M
Expected Unserved Energy value at 10th percentile demand	\$0.00M	\$0.01M	\$0.14M	\$0.28M	\$0.64M	\$1.02M	\$1.88M	\$3.22M	\$5.47M	\$8.93M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.00M	\$0.00M	\$0.04M	\$0.10M	\$0.24M	\$0.45M	\$0.96M	\$1.87M	\$3.23M	\$5.63M

NOTES:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating.
Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating.
Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer for one year.
5. The value of unserved energy is derived from the sector values given in Table 1 of Section 2.4, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) is in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016
(see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

EAST ROWVILLE TERMINAL STATION (ERTS)

ERTS is the main source of supply for part of the outer south-eastern corridor of Melbourne. The geographic coverage of the area supplied by this station spans from Scoresby in the north to Lyndhurst in the south, and from Belgrave in the east to Mulgrave in the west. The electricity supply network for this large region is split between United Energy (UE) and AusNet Electricity Services.


ERTS 66 kV is a summer critical station. The station reached its highest recorded peak demand of 504.9 MW (523.4 MVA) in summer 2009 under extreme weather conditions. The recorded demand in summer 2020 was 463.3 MW (476.3 MVA). Five embedded generation units over 1 MW are connected at ERTS 66 kV.⁶³

The risk of supply interruption at ERTS 66 kV for a single contingency event was assessed as being unacceptable in 2007. As a result, a Regulatory Test was undertaken by both AusNet Electricity Services and United Energy which identified the installation of a fourth 150 MVA 220/66 kV transformer as the most economic network solution. A new fourth transformer was installed at ERTS and commissioned in January 2012. In 2019 the ERTS B3 transformer was replaced with a new higher impedance transformer. This resulted in a decline in the station ratings due to an increased load share on the older transformers.

In 2012, AusNet Electricity Services transferred approximately 15 MVA of load away from ERTS to CBTS. Also, when United Energy's new Keysborough zone substation was commissioned in 2014-15, approximately 7 MW of demand was transferred away from ERTS to HTS. These load transfers are also reflected in the figure below.

Magnitude, probability and impact of loss of load

The graph below depicts the 10th and 50th percentile total summer maximum demand forecasts together with the station's expected operational N rating (all transformers in service) and the (N-1) rating at 35°C as well as 40°C ambient temperature.



⁶³ The maximum demand forecasts adopted in this risk analysis excludes the impact of the five embedded generators.

With the commissioning of the fourth transformer in 2012, the ERTS 66 kV bus was split into two bus groups (B12 and B34), each containing two transformers during normal operation, in order to reduce the 66 kV fault level. In the event of a transformer outage, the normally open 66 kV bus tie circuit breaker will automatically be closed to share the demand across the other three transformers.

The graph above indicates that the overall demand at ERTS remains below its N rating within the 10 year planning period. However with the reduction in ratings in 2019, the 10th percentile summer demand is expected to exceed the 35°C and 40°C N-1 rating of the station from summer 2021. The 50th percentile summer peak demand is not expected to exceed the station's N-1 rating at 35°C in the forward planning period.

The station load is forecast to have a power factor of 0.973 at times of peak demand. The demand at ERTS is expected to exceed 95% of the peak demand for approximately 8 hours per annum. There is approximately 79 MVA of load transfer available at ERTS for summer 2020/21.


As noted above, the 2019 reduction in rating results in a small amount of energy at risk under 10% POE conditions over the forecast period. However AusNet Transmission Group plans to replace the remaining two aged and poor condition transformers at ERTS (transformers B1 and B4) by 2024. After this replacement project is completed, the load sharing of the transformers will become balanced, enabling the station N-1 rating to be increased so that there would be no energy at risk over the forward planning period. In the period prior to the completion of the transformer replacement project, the load at risk will be managed using contingency load transfers.

The following sections discuss the demand on the two bus groups under normal operating conditions.

Transformer group ERTS (B12) Summer Peak Forecasts

This bus group supplies United Energy's Mulgrave and Lyndale zone substations and AusNet Electricity Services' Ferntree Gully, Lysterfield and Belgrave zone substations.

The graph below depicts the ERTS (B12) bus group rating with both transformers in service ("N" rating), the historical demand and the 10th and 50th percentile summer maximum demand forecasts.



The graph indicates that both the 10th and 50th percentile forecast maximum demands connected to the bus group ERTS (B12) are below its N rating for the entire planning period. Therefore, the maximum demand at ERTS (B12) bus group is not expected to exceed its total capacity under normal operation at any time over the 10 year planning period.


Transformer group ERTS (B34) Summer Peak Forecasts

This bus group supplies UE's Dandenong South, Dandenong and Dandenong Valley zone substations and AusNet Electricity Services' Hampton Park zone substation.

The graph below depicts the ERTS (B34) bus group rating with both transformers in service ("N" rating), the historical demand and the 10th and 50th percentile summer maximum demand forecasts.

As previously noted, the ERTS B3 transformer was replaced in 2019 resulting in an uneven load share and lower rating on this bus group. Also, approximately 7 MW of demand was transferred from ERTS to HTS after commissioning of the new Keysborough zone substation in 2014-15. This is reflected in the diagram below.

The graph indicates that the forecast demand connected to the bus group ERTS (B34) is below its N rating for the full planning period. Therefore, it is not expected that the connected demand will exceed the total capacity of the bus group under normal operation at any time over the 10 year planning period.



Load at ERTS remains below the “N-1” rating under both 10th percentile and 50th percentile maximum demand forecasts for the ten year planning period. Further, load at both bus groups remains below their respective N ratings within the ten year planning period. Therefore, on the basis of the current forecasts, there is not expected to be any need for augmentation over the ten year planning period.

EAST ROWVILLE TERMINAL STATION 66 kV

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: United Energy (73%) and SPIE (27%)
Station operational rating (N elements in service): 680 MVA via 4 transformers (Summer peaking)
Summer N-1 Station Rating: 501 MVA [See Note 1 below for interpretation of N-1]
Winter N-1 Station Rating: 576 MVA

Station: ERTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	455	460	465	460	460	464	466	465	465	467
50th percentile Winter Maximum Demand (MVA)	373	386	397	401	404	407	410	414	417	422
10th percentile Summer Maximum Demand (MVA)	494	500	505	502	502	509	512	512	512	515
10th percentile Winter Maximum Demand (MVA)	380	392	403	408	412	415	418	422	426	430
N-1 energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N-1 hours at risk at 50th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
N-1 energy at risk at 10th percentile demand (MWh)	3	22	38	29	29	54	70	69	74	91
N-1 hours at risk at 10th percentile demand (hours)	2	3	4	4	4	5	6	6	6	6
Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy at 10th percentile demand (MWh)	0.0	0.2	0.3	0.3	0.3	0.5	0.6	0.6	0.6	0.8
Expected Unserved Energy value at 50th percentile demand	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k
Expected Unserved Energy value at 10th percentile demand	\$0.8k	\$7.2k	\$12.6k	\$9.7k	\$9.6k	\$18.0k	\$23.2k	\$22.9k	\$24.4k	\$29.9k
Expected Unserved Energy value using AEMO weighting of 0.7 x 50th percentile value + 0.3 x 10th percentile value	\$0.2k	\$2.2k	\$3.8k	\$2.9k	\$2.9k	\$5.4k	\$7.0k	\$6.9k	\$7.3k	\$9.0k

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the VCR relevant climate zone and sector values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

FISHERMAN'S BEND TERMINAL STATION 66 kV (FBTS 66 kV)

FBTS 66 kV is a terminal station shared by both CitiPower (currently 98.6%) and Powercor (currently 1.4%). It is a summer critical station consisting of three 150 MVA 220/66 kV transformers supplying the Docklands areas and an area south-west of the City of Melbourne bounded by the Yarra River in the north and west, St Kilda/Queen's Roads in the east and Hobsons Bay in the south. FBTS 66 kV is the main source of supply for 40,518 customers in the areas of Docklands, Southbank, Port Melbourne, Fisherman's Bend, Albert Park, Middle Park, St Kilda West and the south west corner of the CBD.


As part of its asset renewal program, AusNet Transmission Group plans to replace the B4 transformer with a new 150 MVA 220/66 kV transformer unit by 2021.

The peak load on the station reached 270 MW in summer 2020. It is estimated that:

- For 5.8 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand summer forecast.
- The station load power factor at the time of peak demand is 0.97.

Magnitude, probability and impact of loss of load

AEMO decided to retire the 125 MVA synchronous compensator at FBTS in 2015 and the station is now operating with all three 220/66 kV transformers in service under system normal conditions. Previously the station was run with one transformer operating on "Normal Open Auto Close" duty for fault level mitigation. AusNet Services has updated the terminal station ratings to reflect this change. The updated ratings shown in the graph below also reflect the permanent replacement of the failed B1 transformer unit with the metropolitan spare transformer, which occurred in late 2016.



The graph above depicts the 10th and 50th percentile maximum demand forecasts during the summer periods over the next ten years, together with the station's operational N and

N-1 ratings. The forecast demand includes the effects of any future load transfer works that have been committed.

The graph shows that there would be sufficient capacity at FBTS 66 kV to supply all expected load over the forecast period until 2030, even with one transformer out of service under 10th percentile forecast conditions. CitiPower expects that any such load at risk will be managed through load transfers or other cost-effective operational measures. The alternative would be to install a 4th transformer for which space exists, however due to the low expected unserved energy and the likely availability of cost effective alternatives, there are presently no plans to install the fourth transformer at that time. Therefore, the need for augmentation is not expected to arise over the next ten years.

FRANKSTON TERMINAL STATION (FTS)

FTS is a 66 kV switching station. FTS was originally supplied from East Rowville terminal station (ERTS), and was transferred to Cranbourne terminal station (CBTS) in May 2005. The station is now supplied via three 66 kV supply routes from CBTS. There is one embedded generation unit over 1 MW connected at FTS 66 kV.⁶⁴

United Energy upgraded its existing CBTS-CRM 66 kV line in 2009. This increased the summer thermal rating of the line from 930 A to 1120 A at 35°C. Also in 2017 a project was completed to implement dynamic line ratings on the CBTS-FTS 66 kV double circuit tower lines using actual wind velocity.

Arrangements relating to the ownership of assets supplying FTS, as well as the ratings of those assets are listed in the table below. For the purpose of this risk assessment it is assumed that the CBTS-FTS lines are rated as per the higher of the two wind speed ratings shown.

66kV Supply Route to FTS	Thermal Rating @ 35°C	Dynamic Rating @ 35°C	Ownership
CBTS-FTS #1	825 Amp	825 Amp @ 1.2m/s 920 Amp @ 2.2m/s	Transmission connection asset owned by AusNet Transmission Group
CBTS-FTS #2	825 Amp	825 Amp @ 1.2m/s 920 Amp @ 2.2m/s	Transmission connection asset owned by AusNet Transmission Group
CBTS-CRM-(FTN/LWN)-FTS	1120 Amp	N/A	Distribution system assets owned by United Energy

The station load is forecast to have a power factor of 0.966 at times of peak demand. The demand at FTS is expected to exceed 95% peak demand for approximately 13 hours per annum. There is approximately 36 MVA of load transfer available for the loop for summer 2020/21.


Magnitude, probability and impact of loss of load

The various 66 kV supply routes and ownership arrangements mean that the risk assessment for FTS is more complicated than for other terminal stations. As far as transmission connection assets are concerned, load flow studies indicate that the lowest (N-1) rating of FTS during summer corresponds to the outage of the CBTS-CRM 66 kV line which is limited by the thermal rating of the CBTS-FTS #2 66 kV line. The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational (N-1) rating at 35°C as well as 40°C ambient temperature.

⁶⁴ The maximum demand forecast adopted in this risk analysis excludes the impact of embedded generation scheme.

It should be noted that if the CBTS-FTS 66 kV lines (owned and operated by AusNet Transmission Group) become overloaded, AusNet Transmission Group's centralised System Overload Control Scheme (SOCS) would be initiated to trip both lines. This would result in loss of electricity supply to all customers connected at FTS until the lines are re-energised with sufficiently reduced demand level to avoid further overloading.

The (N-1) rating on the chart below indicates the maximum load that can be supplied from FTS with the CBTS-CRM 66 kV line out of service.



The graph indicates that overall summer maximum demand at FTS 66 kV is not expected to exceed the respective (N-1) ratings under both 10th POE and 50th percentile summer maximum demand over the next 10 years. Therefore, no further works to address load at risk are expected to be required over the ten year planning horizon.

FRANKSTON TERMINAL STATION 66 kV

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: United Energy (100%)
Normal cyclic rating with all plant in service 251 MVA via all 66kV lines (Summer peaking)
Summer N-1 Loop Rating: 208 MVA for an outage of CBTS-CRM line [See Note 1 below for interpretation of N-1]
Winter N-1 Loop Rating: 244 MVA for an outage of CBTS-CRM line

Station: FTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	171	174	177	176	176	179	181	181	182	182
50th percentile Winter Maximum Demand (MVA)	134	140	146	148	151	153	155	157	160	162
10th percentile Summer Maximum Demand (MVA)	183	185	189	189	189	193	196	197	197	199
10th percentile Winter Maximum Demand (MVA)	136	142	148	151	153	156	158	160	163	165
N-1 energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N-1 hours at risk at 50th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
N-1 energy at risk at 10th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N-1 hours at risk at 10th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy at 10th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy value at 50th percentile demand	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K
Expected Unserved Energy value at 10th percentile demand	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K
Expected Unserved Energy value using AEMO weighting of 0.7 x 50th percentile value + 0.3 x 10th percentile value	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K	\$0.0K

Notes:

1. "N-1" means cyclic station output capability rating with outage of the 66kV line. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one 66kV line. An unavailability of 0.007% has been used in this risk assessment for the CBTS-CRM line.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) is in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

GEELONG TERMINAL STATION (GTS) 66 kV

Geelong Terminal Station (GTS) 66 kV consists of four 150 MVA 220/66 kV transformers. Due to the excessive fault levels associated with all four transformers operating in parallel the following strategy has been adopted:

- (a) Prior to 2012 the B3 transformer operated as a hot standby with a normally open auto close scheme on its 66 kV circuit breaker.
- (b) In 2012 the 66 kV loop lines were rearranged so that the B3 transformer could be placed in service with the 66 kV bus tie circuit breaker between 66 kV buses 2&3 normally open. Under system normal, 66 kV buses 1&2 are supplied via B1 and B2 transformers and 66 kV buses 3&4 are supplied via B3 and B4 transformers. For loss of a transformer, the normally open 66 kV bus tie circuit breaker between buses 2&3 is closed. This measure increased the N-1 capacity significantly as shown in the total station load forecast graph below. The GTS N-1 summer rating is then 524 MVA.
- (c) As part of the AusNet Transmission Group asset renewal program, the B3 transformer was replaced in 2013, and the B1 transformer was replaced in 2014. These works increased the terminal station's capacity slightly as reflected in the total load forecast graph below.

GTS is the main source of supply for over 144,094 customers in Geelong and the surrounding area. The station supply area includes Geelong, Corio, North Shore, Drysdale, Waurin Ponds and the Surf Coast.


Due to the operating arrangement at this station, load comparisons with the N rating are provided against the separate bus groups below, followed by comment on load comparisons against the N-1 rating shown in the overall station graph.

GTS 1 & 2 66kV Bus Group Summer Peak Forecasts

This bus group supplies Powercor's zone substations at Ford North Shore, Waurin Ponds, Colac and Winchelsea and 66kV customer substations Shell Refinery Corio and Blue Circle Cement

The peak load on the GTS 1 & 2 Bus group reached 187.4 MW (190.9 MVA) in summer 2020.

GTS 66 kV buses 1&2 demand is summer peaking. The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service).




The (N) rating on the chart indicates the maximum load that can be supplied from GTS bus 1&2 with two transformers in service. The graph shows there is sufficient capacity (N rating) at the station to supply all expected load over the forecast period.

GTS 3 & 4 66kV Bus Group Summer Peak Forecasts

This bus group supplies Powercor's zone substations at Geelong East, Geelong City, Geelong B, Corio and 66kV customer substation Ford Norlane. The peak load on the GTS 3 & 4 Bus group reached 270.6 MW (282.2 MVA) in summer 2020.

GTS 66 kV buses 3&4 demand is summer peaking. The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service).



The (N) rating on the chart indicates the maximum load that can be supplied from GTS bus 3&4 with two transformers in service. The graph shows there is sufficient capacity (N rating) at the station to supply all expected load over the forecast period.


GTS Total Load Summer Peak Forecasts

Growth in summer peak total demand at GTS has averaged around 2.7 MW (1.03%) per annum over the last 6 years. The peak total load on the station reached 443.9 MW (456.1 MVA) in Summer 2020.

It is estimated that:


- For 11 hours per year, 95% of peak demand is expected to be reached under the 50th percentile forecast.
- The station load power factor at the time of peak demand is 0.97

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.



The (N) rating on the chart indicates the maximum load that can be supplied from GTS with all transformers in service.

The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile demand forecast, and the hours per year that the 50th percentile demand forecast is expected to exceed the N-1 capability rating. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.



Comments on Energy at Risk

For an outage of one transformer at GTS, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 22 hours in 2030. The energy at risk at the 50th percentile temperature under N-1 conditions is estimated to be 519.7 MWh in 2030. The estimated value to consumers of the 519.7 MWh of energy at risk is approximately \$19.6 million (based on a value of customer reliability of \$37,721 per MWh).⁶⁵ In other words, at the 50th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at GTS in 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$19.6 million.

It is emphasised however, that the probability of a major outage of one of the four transformers occurring over the year is very low at about 1.0% per transformer per annum, while the expected unavailability per transformer per annum is 0.221%. When the energy at risk (519.7 MWh for 2030) is weighted by this low unavailability, the expected unsupplied energy is estimated to be 4.5 MWh. This expected unserved energy is estimated to have a value to consumers of around \$170,000 (based on a value of customer reliability of \$37,721 per MWh).

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) summer temperatures occurring in each year. Under 10th percentile temperature conditions, the energy at risk in 2030 is estimated to be 3,629 MWh. The estimated value to consumers of this energy at risk in 2030 is approximately \$136.9 million. The corresponding value of the expected unserved energy (of 31.45 MWh) is \$1.19 million.

⁶⁵ The value of unserved energy is derived from the sector values given in Table 1 of Section 2.4, weighted in accordance with the composition of the load at this terminal station.

Key statistics relating to energy at risk and expected unserved energy for the year 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	519.7	\$19.6 million
Expected unserved energy at 50 th percentile demand	4.5	\$170,000
Energy at risk, at 10 th percentile demand forecast	3,629	\$136.9 million
Expected unserved energy at 10 th percentile demand	31.45	\$1.19 million

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

- Installation of a fifth 220/66 kV transformer (150 MVA) at GTS at an indicative capital cost of \$18 million, which equates to a total annual cost of \$1.33 million.
- Demand reduction: There is an opportunity to develop a number of innovative customer schemes to encourage voluntary demand reduction during times of network constraint. The amount of demand reduction would depend on the customer uptake and would be taken into consideration when determining the optimum timing for any future capacity augmentation.
- Embedded generation: A new wind farm at Mt Gellibrand (132 MW) was commissioned in 2019 and some portion of this generation capacity will contribute into 66 kV infrastructure ex-GTS. This may defer the need for any capacity augmentation at GTS.
- Possible uptake of battery storage in the future could provide some contribution to supporting the peak load.

Preferred option(s) for alleviation of constraints

In the absence of any commitment by interested parties to offer network support services by installing local generation or through demand side management initiatives that would reduce load at GTS, it is proposed to:

1. Install a fifth 220/66 kV transformer (150 MVA) at GTS at an indicative capital cost of \$18 million. This equates to a total annual cost of approximately \$1.33 million per annum. On the basis of the medium economic growth scenario and both 50th and 10th percentile weather probability, the transformer would not be expected to be required within the ten-year forecast period.
2. As a temporary measure, maintain contingency plans to transfer load quickly to TGTS by the use of the 66 kV tie lines between TGTS and GTS in the event of an unplanned outage of one transformer at GTS under critical loading conditions. This load transfer is

in the order of 10 MVA. Under these temporary measures, affected customers would be supplied from the 66 kV tie line infrastructure on a radial network, thereby reducing their level of reliability.

3. Subject to availability, an AusNet Transmission Group spare 220/66 kV transformer for rural areas (refer Section 5.5) can be used to temporarily replace a failed transformer to minimise the transformer outage period.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

Geelong Terminal Station

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: Powercor (100%)

MVA

Normal cyclic rating with all plant in service

704 via 4 transformers (summer)

Summer N-1 Station Rating:

524 [See Note 1 below for interpretation of N-1]

Winter N-1 Station Rating:

524

Station: GTS 1-2 & 3-4	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	432.6	471.5	486.4	497.6	507.4	523.1	539.9	557.4	579.8	606.8
50th percentile Winter Maximum Demand (MVA)	391.9	429.6	441.0	450.6	459.5	474.4	488.8	506.9	527.9	553.3
10th percentile Summer Maximum Demand (MVA)	496.5	536.5	553.6	568.5	579.9	594.6	613.0	638.3	663.0	694.4
10th percentile Winter Maximum Demand (MVA)	419.1	457.3	468.7	479.1	489.3	504.8	520.7	540.6	563.1	590.3
N-1 energy at risk at 50% percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	15.0	58.2	167.5	519.7
N-1 hours at risk at 50th percentile demand (hours)	0.0	0.0	0.0	0.0	0.0	0.0	1.8	3.3	7.0	22.0
N-1 energy at risk at 10% percentile demand (MWh)	0.0	9.7	46.9	101.7	166.4	287.6	504.6	956.8	1720.8	3629.2
N-1 hours at risk at 10th percentile demand (hours)	0.0	1.3	3.0	4.8	6.5	10.0	14.5	25.5	44.8	102.8
Expected Unserved Energy at 50th percentile demand (MWh)	0.00	0.00	0.00	0.00	0.00	0.00	0.13	0.50	1.45	4.50
Expected Unserved Energy at 10th percentile demand (MWh)	0.00	0.08	0.41	0.88	1.44	2.49	4.37	8.29	14.91	31.45
Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.02M	\$0.05M	\$0.17M
Expected Unserved Energy value at 10th percentile demand	\$0.00M	\$0.00M	\$0.02M	\$0.03M	\$0.05M	\$0.09M	\$0.16M	\$0.31M	\$0.56M	\$1.19M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.00M	\$0.00M	\$0.00M	\$0.01M	\$0.02M	\$0.03M	\$0.05M	\$0.11M	\$0.21M	\$0.47M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The winter rating is at an ambient temperature of 5 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which specified demand forecast exceeds the N-1 capability rating.
3. "N-1 hours at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating.
4. "Expected unserved energy" means "N-1 energy at risk" for the specified demand forecast multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with a duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

GLENROWAN TERMINAL STATION 66 kV (GNTS 66 kV)

Glenrowan Terminal Station (GNTS) consists of one 125 MVA 220/66kV three phase transformer and one 150 MVA 220/66 kV three phase transformer.

The station is the main source of supply for a major part of north-eastern Victoria including Wangaratta in the north; to Euroa in the south; to Mansfield and Mt Buller in the east; and Benalla more centrally.

AusNet Electricity Services is responsible for planning the transmission connection and distribution networks for this region.


Magnitude, probability and impact of loss of load

GNTS has historically been a winter peaking station. However the summer peak demand has more recently been exceeding the winter peak demand. The rate of growth in summer and winter peak demand at GNTS 66 kV has been low in recent years, and demand is forecast to continue increasing slowly, averaging around 0.7% per annum for the 10 year planning horizon.

The peak load on the station reached 104.2 MW (110.4 MVA) in summer 2019/20 and 101.0 MW (104.1 MVA) in winter 2019. The demand at GNTS 66 kV is expected to exceed 95% of the 50th percentile peak demand for 5 hours per annum. The station load has a power factor of 0.94 at summer maximum demand.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast, together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at an ambient temperature of 35°C.

GNTS 66 kV Summer Peak Demand Forecasts



The graph shows that there is no energy at risk under 50th percentile or 10th percentile loading conditions for the summer period for the next ten years. There is therefore not expected to be any need for augmentation over the ten year planning period.

HEATHERTON TERMINAL STATION (HTS)

HTS is the main source of supply for a major part of the southern metropolitan area. The geographic coverage of the HTS supply area spans from Brighton in the north to Edithvale in the south.


HTS is a summer critical terminal station. The station reached its highest ever recorded peak demand of 363.5 MW (373 MVA) in summer 2020 which was 5.4 MW higher than the previous record peak that was set the previous year in 2019. There are no embedded generation units over 1 MW connected at HTS.

United Energy's new Keysborough zone substation was commissioned in 2014. After commissioning, approximately 24 MW of demand was transferred from ERTS and SVTS to HTS. This load transfer is reflected in the graph below.

In 2017 AusNet Transmission Group replaced the existing HTS 220/66 kV transformers as part of their asset replacement programme. This resulted in an increase in the station ratings for summer 2018 as reflected in the graph below.

Magnitude, probability and impact of loss of load

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational N rating (all transformers in service) and the (N-1) rating at 35°C as well as 40°C ambient temperature.




The N rating on the graph indicates the maximum load that can be supplied from HTS with all transformers in service.

The graph indicates that with the increased station rating the 10th percentile maximum demand is expected to exceed the (N-1) rating from summer 2027 and the 50th percentile maximum demand is not expected to exceed the (N-1) rating in the 10 year period.

The station load is forecast to have a power factor of 0.974 at times of peak demand. The demand at HTS is expected to exceed 95% of peak demand for approximately 6 hours.

The bar chart below depicts the energy at risk with one transformer out of service for the 10th percentile demand forecast, and the hours per year that the 10th percentile demand forecast is expected to exceed the (N-1) capability rating. The line graph shows the value to consumers of the expected unserved energy in each year, for the 10th percentile demand forecast.



Comments on Energy at Risk

For an outage of one transformer at HTS, it is expected that from 2027, there would be insufficient capacity at the station to supply all demand at the 10th percentile temperature.

By the end of the ten-year planning period in 2030, the energy at risk under N-1 conditions is estimated to be 4 MWh at the 10th percentile demand forecast. Under these conditions, there would be insufficient capacity to meet demand for 1 hour in that year. The estimated value to customers of the 5 MWh of energy at risk in 2030 is approximately \$0.2 million (based on a value of customer reliability of \$40,535/MWh)⁶⁶. In other words, at the 10th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at HTS over the summer of 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$0.2 million.

Typically, the probability of a major outage of a terminal station transformer occurring over the year is very low at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (5 MWh in

⁶⁶ The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

2030) is weighted by this low unavailability, the expected unserved energy is estimated to be around 0.03 MWh. This expected unserved energy is estimated to have a value to consumers of around \$1,300 (based on a value of customer reliability of \$40,535/MWh).

It should be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of 10th percentile temperatures occurring in each year. Under 50th percentile temperature conditions, the energy at risk is expected to be zero in 2030.

These key statistics for the year 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	0	\$0.0 million
Expected unserved energy at 50 th percentile demand	0.0	\$0
Energy at risk, at 10 th percentile demand forecast	5	\$0.2 million
Expected unserved energy at 10 th percentile demand	0.03	\$1,300

Possible impacts of a transformer outage on customers

If one of the 220/66 kV transformers at HTS is taken off line during peak loading times and the (N-1) station rating is exceeded, the OSSCA⁶⁷ load shedding scheme which is operated by AusNet Transmission Group's TOC⁶⁸ will act swiftly to reduce the loads in blocks to within safe loading limits. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with United Energy's operational procedures after the operation of the OSSCA scheme.

In the case of HTS supply at maximum loading periods, the OSSCA scheme would shed about 160 MVA of load, affecting up to approximately 47,000 customers.

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

1. Implement a contingency plan to transfer load to adjacent terminal stations. United Energy has established and implemented the necessary plans that enable load transfers under contingency conditions, via both 66 kV subtransmission and 22/11 kV distribution networks. These plans are reviewed annually prior to the summer season. Transfer capability away from HTS 66 kV onto adjacent terminal stations via the distribution network is assessed at 89 MVA for summer 2021.
2. Install a fourth 220/66 kV transformer at HTS.

⁶⁷ Overload Shedding Scheme of Connection Asset.

⁶⁸ Transmission Operations Centre

3. Establish a new 220/66 kV terminal station (DNTS) in the Dandenong area to off-load HTS.

Joint planning studies previously conducted with AEMO identified that establishment of a new terminal station connection point in the Dandenong area would be the preferred solution to address constraints in the area. This was predominantly driven by the load at risk associated with the 220 kV line constraints in the area as well as a number of other significant sub-transmission and connection asset constraints in the Dandenong, Keysborough and Braeside areas, which a 4th transformer at HTS would not be able to resolve.

The capital cost of installing a new 220/66 kV terminal station in Dandenong and related subtransmission works is estimated to be in excess of \$70 million with an estimated total annual cost of approximately \$5.2 million.

The replacement of the transformers at HTS in 2017 increased the HTS rating, so the need for a new terminal station is now more likely to be driven by transmission network constraints alone, and is unlikely to be economically justified within the ten year planning horizon. United Energy will continue to work with AEMO on this joint planning exercise to assess the need for and timing of any new terminal station development in the Dandenong area.

Preferred network option(s) for alleviation of constraints

In the absence of any commitment by interested parties to offer network support services by installing local generation or through demand side management initiatives that would reduce load at HTS, it is proposed to:

1. Implement the following temporary measures to cater for an unplanned outage of one transformer at HTS under critical loading conditions:
 - maintain contingency plans to transfer load quickly to adjacent terminal stations;
 - fine-tune the OSSCA scheme settings in conjunction with TOC to minimise the impact on customers of any load shedding that may take place; and
 - subject to availability, an AusNet Transmission Group spare 220/66 kV transformer for metropolitan areas (refer to Section 5.5) can be used to temporarily replace a failed transformer.
2. Establish a new 220/66 kV terminal station in the Dandenong area to off-load HTS and the surrounding terminal stations and transmission lines. As explained above, on the present forecasts, the new terminal station in the Dandenong area is unlikely to be economic within the ten year planning horizon.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

HEATHERTON TERMINAL STATION 66 kV

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: United Energy (100%)
Station operational rating (N elements in service): 619 MVA via 3 transformers (Summer peaking)
Summer N-1 Station Rating: 411 MVA [See Note 1 below for interpretation of N-1]
Winter N-1 Station Rating: 434 MVA

Station: HTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	341	346	353	351	352	359	362	362	361	362
50th percentile Winter Maximum Demand (MVA)	272	281	289	292	293	294	294	295	296	297
10th percentile Summer Maximum Demand (MVA)	371	377	385	385	387	396	400	400	401	403
10th percentile Winter Maximum Demand (MVA)	277	285	294	297	299	299	300	302	303	304
N-1 energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N-1 hours at risk at 50th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
N-1 energy at risk at 10th percentile demand (MWh)	0	0	0	0	0	0	2	2	3	5
N-1 hours at risk at 10th percentile demand (hours)	0	0	0	0	0	0	1	1	1	1
Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy at 10th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M
Expected Unserved Energy value at 10th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M
Expected Unserved Energy value using AEMO weighting of 0.7 x 50th percentile value + 0.3 x 10th percentile value	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

HEYWOOD TERMINAL STATION (HYTS) 22 kV

Heywood Terminal Station (HYTS) 22 kV consists of two 70 MVA 500/275/22 kV transformers and is the source of supply to an industrial customer in the local area and the only large customer supplied from this supply point. Another 169 small domestic and farming customers along the line route are also supplied from this supply point.

Magnitude, probability and impact of loss of load


The peak load on the station reached 1.7 MW (1.8 MVA) in winter 2019.

The 22 kV point of supply was established in late 2009, by utilising the tertiary 22 kV on 2 of the existing 3 x 500/275/22 kV South Australian / Victorian interconnecting transformers. The supply is arranged so that one transformer is on hot standby (on its tertiary 22 kV), due to excessive fault levels.

It is estimated that:

- For 11 hours per year, 95% of peak demand is expected to be reached under the 50th percentile forecast.
- The station load power factor at time of peak demand is 0.96.

The graph depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N-1" rating at 35°C ambient temperature.



The graph shows that there is sufficient capacity at the station to supply all expected load over the forecast period, even with one transformer out of service. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

HORSHAM TERMINAL STATION (HOTS) 66 kV

Horsham Terminal Station (HOTS) 66 kV consists of two 100 MVA 235/67.5 kV transformers and is the main source of supply for some 36,563 customers in Horsham and the surrounding area. The station supply area includes Horsham, Edenhope, Warracknabeal and Nhill. The station also supplies Stawell via the inter-terminal 66 kV ties with Ballarat Terminal Station (BATS).


Magnitude, probability and impact of loss of load

HOTS 66 kV demand is summer peaking. Summer peak demand at HOTS has increased by an average of around 1.8 MVA (2.5%) per annum over the last 5 years. The peak load on the station reached 78.8 MVA in summer 2020.

It is estimated that:

- For 3 hours per year, 95% of peak demand is expected to be reached under the 50th percentile forecast.
- The station load power factor at the time of peak demand is 0.99.

The graph depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.



The graph shows there is sufficient capacity at the station to supply all expected load over the forecast period, even with one transformer out of service under 50th and 10th percentile forecast conditions. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

KEILOR TERMINAL STATION 66 kV (KTS 66 kV)

Keilor Terminal Station is located in the north west of Greater Melbourne. It operates at 220/66 kV and currently supplies a total of approximately 186,233 customers in Jemena Electricity Networks and Powercor in the Airport West, St. Albans, Woodend, Pascoe Vale, Essendon and Braybrook areas.

Background

KTS has five 150 MVA transformers and is a summer critical station. Up until 2012, the station was operated with one of the five transformers, also known as KTS B5 transformer, in “hot standby” mode, with the then No. 2-3 66 kV bus tie circuit breaker open for the purpose of limiting the maximum prospective fault levels to within switchgear ratings. In the event of an outage of one of the four “normally on-load” transformers, the B5 unit would be connected in automatically. Therefore the “N” and “N-1” ratings were the same.

In 2012, the station was re-configured to enable the KTS B5 transformer to take load under system normal conditions. Under system normal conditions, the No.1, No.2 & No.5 transformers are operated in parallel as one group (KTS (B1,2,5)) and supply the No.1, No.2 & No.5 66 kV buses. The No.3 & No.4 transformers are operated in parallel as a separate group (KTS (B3,4)) and supply the No.3 & No.4 66 kV buses. The 66 kV bus 3-5 and bus 1-4 tie circuit breakers are operated in the normally open position to limit the maximum prospective fault levels on the five 66 kV buses to within switchgear ratings.

For an unplanned transformer outage in the KTS (B3,4) group, the No.5 transformer will automatically change over to the KTS (B3,4) group. Therefore, an unplanned transformer outage of any one of the five transformers at KTS will result in both the KTS (B1,2,5) and KTS (B3,4) groups being comprised of two transformers each. Given this configuration, load demand on both the KTS(B3,4) and KTS (B1,2,5) groups must be kept within the capabilities of two transformers at all times or load shedding will occur.


The following sections examine the two transformer groups separately.

Transformer group KTS (B1,2,5) Summer Peak Forecasts

The peak load on KTS (B1,2,5) reached 304.1 MW (or 323.3 MVA) in summer (January) 2020.

The graph below depicts the KTS (B1,2,5) rating with all transformers (B1, B2 & B5) in service (“N” rating), and with one of the three transformers out of service (“N-1” rating), along with the 50th and 10th percentile summer maximum demand forecasts⁶⁹. The recent transfer of load from KTS to DPTS is reflected in the load forecasts shown below.

⁶⁹ Note that station transformer output capability rating and transformer loading are shown in the graph.



The above graph shows that with all transformers in service, there is adequate capacity to meet the anticipated maximum load demand for the entire forecast period. However, under N-1 condition during peak demand (at the 10th percentile temperature) the forecast load is greater than the N-1 rating of KTS (B1,2,5), which could affect some customers.


Transformer group KTS (B3,4) Summer Peak Forecasts

The peak load on KTS (B3,4) reached 235.1 MW (or 242.6 MVA) in summer 2020 (January).

The graph below depicts the summer maximum demand forecasts (for 50th and 10th percentile temperatures) for KTS (B3,4) and the corresponding rating with both transformers (B3 & B4) operating.

It shows that with all transformers in service, there will be sufficient capacity to meet the anticipated maximum load demand for the entire forecast period. The new Deer Park Terminal Station (DPTS) was commissioned in September 2017 and has off-loaded the KTS (B3,4) group.

As explained above, if an unplanned transformer outage in the KTS (B3,4) group occurs, the No.5 transformer will automatically change over to the KTS (B3,4) group. In effect, the N-1 and N ratings of the KTS (B3,4) group are equivalent. Thus the load at risk level under a transformer outage condition is equivalent to the load at risk under system normal conditions.



Comments on Energy at Risk at KTS

At the 10th percentile level, the demand forecast is expected to be below the N capability rating for the entire forecast period. There is no load at risk at under N-1 condition at both KTS (B1,2,5) and KTS (B3,4) at the 50th percentile demand forecast.

However, under 10th percentile summer temperature conditions, the customer demand increases significantly due to air conditioning loads and there will be a small amount of energy at risk (3.7 MWh in 2021) at KTS (B1,2,5).

The energy at risk at KTS (B1,2,5) increases gradually over the ten year forecast period, to 125.8 MWh in 2030 at the 10th percentile demand forecast. Under these conditions, there would be insufficient capacity to meet demand for 14 hours in that year. The estimated value to customers of the 125.8 MWh of energy at risk in 2030 is approximately \$4.7 million (based on a value of customer reliability of \$37,470/MWh). In other words, at the 10th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at KTS (B1,2,5) over the summer of 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$4.7 million.

Typically, the probability of a major outage of a terminal station transformer occurring over the year is very low at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (125.8 MWh in 2030) is weighted by this low unavailability, the expected unserved energy is estimated to be around 1.4 MWh. This expected unserved energy is estimated to have a value to consumers of around \$53,750 (based on a value of customer reliability of \$37,470/MWh).

These key statistics for 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	0	\$0
Expected unserved energy at 50 th percentile demand	0	\$0
Energy at risk, at 10 th percentile demand forecast	125.8	\$4.7 million
Expected unserved energy at 10 th percentile demand	1.4	\$53,750

Possible Impacts on Customers

System Normal Condition (All 5 transformers in service)

Applying the 10th percentile demand forecast, there will be sufficient capacity at the station to supply all customer demand for the entire forecast period under system normal condition.

N-1 System Condition

If one of the KTS 220/66 kV transformers is taken off line during peak loading times, causing the KTS (B1,2,5) rating to be exceeded, the OSSCA⁷⁰ load shedding scheme which is operated by AusNet Transmission Group's TOC⁷¹ will act swiftly to reduce the loads in blocks to within transformer capabilities. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored after the operation of the OSSCA scheme, at zone substation feeder level in accordance with Jemena Electricity Networks' and Powercor's operational procedures.

Feasible options and preferred network option(s) for alleviation of constraints

The amount of energy at risk over the 10 year forecast period is insufficient to economically justify capacity augmentation at the station. Over the forecast period, the risk to supply reliability will be mitigated through the following measures:

- Maintain contingency plans to transfer load quickly, where possible, to adjacent terminal stations. Jemena Electricity Networks has up to 36 MVA of load transfer capacity available and Powercor has up to 15 MVA of transfer capacity available.
- Fine-tune the OSSCA scheme settings in conjunction with AusNet Transmission Group to minimise the impact on customers of any automatic load shedding that may take place; and
- Subject to the availability of an AusNet Transmission Group spare 220/66 kV transformer for urban areas (refer to section 5.5), a spare transformer could be installed at KTS and used to temporarily replace a failed transformer.

The tables on the following pages provide more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

⁷⁰ Overload Shedding Scheme of Connection Asset.

⁷¹ Transmission Operations Centre.

KEILOR TERMINAL STATION (KTS(B1,2,5) TRANSFORMER GROUP)⁷²**Detailed data: Magnitude and probability of loss of load**

Distribution Businesses supplied by this station:

Normal cyclic rating with all plant in service

Summer N-1 Station Transformer Rating:

Winter N-1 Station Transformer Rating:

JEN (72%), Powercor (28%) (following transfer of load to Deer Park Terminal Station)

509 MVA at 50th percentile temperature and 490 MVA at 10th percentile temperature (Summer peaking)339 MVA at 50th percentile temperature and 327 MVA at 10th percentile temperature [See Note 1 below for interpretation of N-1]

353 MVA

Station: KTS (B125)		2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50 th percentile Summer Maximum Demand (MVA)		323	295.0	301.2	300.0	299.3	302.4	305.0	305.6	307.1	311.1	316.3
50 th percentile Winter Maximum Demand (MVA)		228	231.2	233.4	233.4	233.9	235.4	237.1	238.4	241.1	244.1	248.5
10 th percentile Summer Maximum Demand (MVA)		323	329.5	333.2	333.2	331.3	332.9	336.9	337.1	340.9	344.4	347.6
10 th percentile Winter Maximum Demand (MVA)		234	239.0	240.5	240.5	241.4	242.4	243.1	246.0	247.3	250.7	255.6
N-1 energy at risk at 50th percentile demand (MWh)		-	-	-	-	-	-	-	-	-	-	-
N-1 hours at risk at 50th percentile demand (hours)		-	-	-	-	-	-	-	-	-	-	-
N-1 energy at risk at 10th percentile demand (MWh)		4	14	14	8	13	26	27	53	89	126	126
N-1 hours at risk at 10th percentile demand (hours)		2	3	3	3	3	6	6	10	12	14	14
Expected Unserved Energy at 50th percentile demand (MWh)		-	-	-	-	-	-	-	-	-	-	-
Expected Unserved Energy at 10th percentile demand (MWh)		0.0	0.2	0.2	0.1	0.1	0.3	0.3	0.6	1.0	1.4	1.4
Expected Unserved Energy value at 50th percentile demand		\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M
Expected Unserved Energy value at 10th percentile demand		\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.1 M
Expected Annual Unserved Energy value (using AEMO weighting of 0.7 x 50th percentile value + 0.3 x 10th percentile value)	\$37.47k/MWh	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M	\$ 0.0 M

Notes:

- "N-1" means cyclic station transformer output capability rating with outage of one transformer. The rating is at an ambient temperature of 38.5 degrees Centigrade and 42 degrees Centigrade (for 50th percentile value and 10th percentile value respectively) as this is the typical temperatures where 50% PoE loads and 10% PoE loads are likely to occur at KTS.
- "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
- "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
- "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
- The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
- The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx).

⁷² Note that risk assessment for this station is carried out using station transformers' rating and loading.

KEILOR TERMINAL STATION (KTS(B3,4) TRANSFORMER GROUP)⁷³**Detailed data: Magnitude and probability of loss of load**

Distribution Businesses supplied by this station:

JEN (37%), Powercor (63%) (following transfer of load to Deer Park Terminal Station)

Normal cyclic rating with all plant in service:

321 MVA at 50th percentile temperature and 311 MVA at 10th percentile temperature (Summer peaking)

Summer N-1 Station Transformer Rating:

321 MVA at 50th percentile temperature and 311 MVA at 10th percentile temperature [See Note 1 below for interpretation of N-1]

Winter N-1 Station Transformer Rating:

344 MVA

Station: KTS (B34)		2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50 th percentile Summer Maximum Demand (MVA)		242.6	214.5	225.4	225.9	230.5	232.6	238.1	244.9	251.8	256.4	267.8
50 th percentile Winter Maximum Demand (MVA)		170.1	177.2	183.6	186.1	188.8	192.6	196.8	203.0	208.7	216.2	225.0
10 th percentile Summer Maximum Demand (MVA)		242.6	238.9	249.3	252.5	253.6	260.3	265.6	268.0	276.9	288.2	294.2
10 th percentile Winter Maximum Demand (MVA)		177.7	184.0	191.3	193.5	196.9	200.6	205.6	211.2	217.7	224.5	233.7
N-1 energy at risk at 50th percentile demand (MWh)		-	-	-	-	-	-	-	-	-	-	-
N-1 hours at risk at 50th percentile demand (hours)		-	-	-	-	-	-	-	-	-	-	-
N-1 energy at risk at 10th percentile demand (MWh)		-	-	-	-	-	-	-	-	-	-	-
N-1 hours at risk at 10th percentile demand (hours)		-	-	-	-	-	-	-	-	-	-	-
Expected Unserved Energy at 50th percentile demand (MWh)		-	-	-	-	-	-	-	-	-	-	-
Expected Unserved Energy at 10th percentile demand (MWh)		-	-	-	-	-	-	-	-	-	-	-
Expected Unserved Energy value at 50th percentile demand		\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M
Expected Unserved Energy value at 10th percentile demand		\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M
Expected Annual Unserved Energy value (using AEMO weighting of 0.7 x 50th percentile value + 0.3 x 10th percentile value)	\$37.47k/MWh	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M	\$ - M

Notes:

- "N-1" means cyclic station transformer output capability rating with outage of one transformer. The rating is at an ambient temperature of 38.5 degrees Centigrade and 42 degrees Centigrade (for 50th percentile value and 10th percentile value respectively) as this is the typical temperatures where 50% PoE loads and 10% PoE loads are likely to occur at KTS.
- "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is the same as "N-1 energy at risk" for this bus group.
- "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) is the same as "N-1 hours per year at risk" for this bus group.
- "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
- The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
- The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx).

⁷³ Note that risk assessment for this station is carried out using station transformers' rating and loading.

KERANG TERMINAL STATION (KGTS) 66kV & 22kV


Kerang Terminal Station (KGTS) 66 kV and 22 kV consists of three 35 MVA 235/66/22 kV transformers and is the main source of supply for over 18,260 customers in Kerang and the surrounding area. The station supply area includes Kerang, Swan Hill and Cohuna.

Growth in summer peak demand at KGTS has averaged around 1 MVA (1.6%) per annum over the last 5 years. The peak load on the station reached 70.5 MW (66 kV and 22 kV networks) in summer 2020.

It is estimated that:

- For 7 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at the time of peak demand is 0.99.

KGTS 22 & 66 kV demand is summer peaking. The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.




The above graph shows that there is sufficient capacity at the station to supply all expected demand at the 50th and 10th percentile temperatures over the forecast period, even with one transformer out of service. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

MALVERN 22 kV TERMINAL STATION (MTS 22 kV)

MTS 22 kV is the source of supply for over 12,000 customers in Burwood, Ashwood, Glen Iris, Mount Waverley and Surrey Hills.

MTS 22 kV is a summer critical terminal station. The recorded demand in summer 2020 was 37.2 MW (37.7 MVA), which was approximately 0.3 MW higher than the summer 2019 peak. There are no embedded generation units over 1 MW connected at MTS 22 kV.

In addition to historical summer maximum demands, the graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational N rating (all transformers in service) and the (N-1) rating at 35°C as well as 40°C ambient temperature.



The N rating on the graph indicates the maximum load that can be supplied from MTS 22 kV with all transformers in service. Exceeding this level will require load shedding or emergency load transfers to keep the terminal station operating within its limits.

The graph above shows that with one transformer out of service, the demand at MTS 22 kV will remain well within the (N-1) station rating over the next ten years.

The station load is forecast to have a power factor of 0.988 at times of peak demand. The demand at MTS 22 kV is expected to exceed 95% of peak demand for approximately 5 hours per annum. There is approximately 4 MVA of load transfer available at MTS 22 kV for summer 2020/21.

On the basis of the current forecasts, the need for augmentation of transmission connection assets at MTS 22 kV is not expected to arise over the next decade.


MALVERN 66 kV TERMINAL STATION (MTS 66 kV)

MTS 66 kV is the main source of supply for over 80,000 customers in Elsternwick, Caulfield, Carnegie, Malvern East, Ashburton, Chadstone, Oakleigh, Ormond, Murrumbeena, Hughesdale and Bentleigh East.

MTS 66 kV is a summer critical terminal station. In summer 2020 the station reached its highest ever recorded peak demand of 233.2 MW (236 MVA). This exceeded the previous historic maximum demand of 228.7 MW (232 MVA) in summer 2019. Note that the transformers at MTS 66 kV support the demand of both 66 kV and 22 kV networks ex MTS (refer also to the Risk Assessment for MTS 22 kV).

There are no embedded generation units over 1 MW connected at MTS 66 kV.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational N rating (all transformers in service) and the (N-1) rating at 35°C as well as 40°C ambient temperature.



The N rating on the graph indicates the maximum load that can be supplied from MTS 66 kV with all transformers in service. Exceeding this level will require load shedding or emergency load transfers to keep the terminal station operating within its limits.

The graph indicates that the 10th percentile maximum demand is not expected to exceed the (N-1) rating until summer 2028 and the 50th percentile maximum demand is not expected to exceed the (N-1) rating in the 10 year forecast period.

The station load is forecast to have a power factor of 0.987 at times of peak demand. The demand at MTS 66 kV is expected to exceed 95% of the peak demand for approximately 4 hours per annum. There is approximately 16 MVA of load transfer available at MTS 66 kV for summer 2020/21.

On the basis of the latest forecasts, and given the minimal amount of load at risk over the next 10 years, the need for augmentation of transmission connection assets at MTS 66 kV is not expected to arise over the next decade.

MORWELL TERMINAL STATION 66 kV (MWTS 66 kV)

Morwell Terminal Station (MWTS) 66 kV is the main source of supply for a major part of south-eastern Victoria including Gippsland. It supplies Phillip Island, Wonthaggi and Leongatha in the west; Moe and Traralgon in the central area; to Omeo in the north; and to Bairnsdale and Mallacoota in the east.

AusNet Electricity Services is responsible for the transmission connection and distribution network planning for this region.

Magnitude, probability and impact of loss of load


MWTS 66 kV is supplied by two 150 MVA 220/66 kV transformers and one 165 MVA 220/66 kV transformer.

MWTS 66 kV is a summer peaking station and recorded a maximum demand of 452 MW (464 MVA) in early January 2013. The peak demand on the station reached 440.4 MW (443.8 MVA) in summer 2019/20. The peak demand period is usually quite short and coincides with a few weeks of peak tourism from Christmas to early January along the east coast of Victoria. The maximum demand recorded is very dependent on weather conditions during this short period. The load at MWTS 66 kV is forecast to decline slightly over the ten-year planning horizon. The station load has a power factor of 0.99 at maximum demand. MWTS 66 kV demand is expected to exceed 95% of the 50th percentile peak demand for 5 hours per annum.

The assessment of the energy at risk at MWTS 66 kV needs to take into account the significant levels of embedded generation that is connected into the MWTS 66 kV network and directly offsets the loading on the 220/66 kV transformers at MWTS. The embedded generation includes the 80 MW Bairnsdale Power Station (BPS), the 10 MW Traralgon Power Station, the Wonthaggi and Toora Wind Farms, totalling 33 MW, and the 106 MW Bald Hills Wind Farm. While a precise assessment is difficult due to the intermittency of the generation in the 66 kV loop, to make a realistic assessment of the risk at MWTS the total output from these embedded generators is assumed to be 60 MVA.


The “N-1” and “N” ratings shown on the graph below include the transformer capacity as well as the assumed 60 MVA contribution from embedded generation. For example the 395 MVA “N-1” rating includes the 335 MVA capacity of two 220/66 kV transformers and 60 MVA from embedded generation. The graph also shows the 10th and 50th percentile summer maximum demand forecast together with the station’s operational “N” rating (all transformers in service plus 60 MVA from embedded generation) and the “N-1” rating at an ambient temperature of 35°C. The “N” rating on the chart indicates the maximum load that can be supplied from MWTS 66 kV with all transformers in service. Summer peak demand loading at MWTS is expected to exceed the station’s “N-1” rating for the entire 10-year planning period.

MWTS 66 kV Summer Peak Demand Forecasts including generation



There is no energy at risk forecast under the 50th percentile demand forecast. The bar chart below depicts the energy at risk with one transformer out of service for the 10th percentile demand forecast, and the hours per year that the 10th percentile demand forecast is expected to exceed the “N-1” capability. The line graph shows the value to consumers of the expected unserved energy in each year, for the 10th percentile demand forecast.

Annual Energy and Hours at Risk at MWTS 66 (10% POE condition and Single Contingency Only)



MWTS is not expected to be loaded above its “N-1” rating under 50th percentile or 10th percentile winter maximum demand forecasts during the 10 year planning horizon.

Comments on Energy at Risk

As noted above, embedded generation is assumed to be contributing 60 MVA during the peak demand period, which represents approximately 25 percent of the total installed capacity of the embedded generators in the MWTS 66 kV network.

There is no energy at risk forecast under the 50th percentile demand forecast. Under higher summer temperature conditions (that is at the 10th percentile level), the energy at risk in 2020/21 is estimated to be 430 MWh. The estimated value to consumers of the energy at risk is \$17.5 million (based on a value of customer reliability of \$40,632/MWh)⁷⁴. When this energy at risk is weighted by the transformer unavailability, the expected unserved energy is estimated to be 2.9 MWh, which has a value to consumers of around \$0.12 million.

These key statistics for the year 2019/20 under “N-1” outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	0	0
Expected unserved energy at 50 th percentile demand	0	0
Energy at risk, at 10 th percentile demand forecast	430	\$17.5 million
Expected unserved energy at 10 th percentile demand	2.9	\$0.12 million

If one of the 220/66 kV transformers at MWTS is taken off line during peak loading times and the “N-1” station rating is exceeded, then the Overload Shedding Scheme for Connection Assets (OSSCA) which is operated by AusNet Transmission Group’s TOC⁷⁵ to protect the connection assets from overloading⁷⁶, will act swiftly to reduce the load in blocks to within safe loading limits. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with AusNet Electricity Services’ operational procedures after the operation of the OSSCA scheme.

Feasible options for alleviation of constraints

The following options are technically feasible to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

1. Embedded generation: Bairnsdale Power Station is currently contracted to provide network support services to AusNet Services. That network support contract was due to

⁷⁴ The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

⁷⁵ Transmission Operation Centre.

⁷⁶ OSSCA is designed to protect connection transformers against transformer damage caused by overloads. Damaged transformers can take months to repair or replace, which can result in prolonged, long term risks to the reliability of customer supply.

expire in March 2020 but has been extended to March 2022, at which time a feasible option would be to recontract network support services from Bairnsdale or another network support service provider in the area. Accordingly, AusNet Services has published Stage 1, the non-network options report, of a regulatory investment test for distribution (RIT-D) to address sub-transmission limitations in the East Gippsland area. The non-network options report is seeking submissions from network support proponents and is open for consultation until 8 January 2021. Information relating to the East Gippsland RIT-D is available on AusNet Services' website⁷⁷.

2. Subject to availability, an AusNet Transmission Services spare 220/66 kV transformer for rural areas (refer section 5.5) can be used to temporarily replace a failed transformer.
3. Install a fourth 220/66 kV transformer at MWTS: Installation of a 4th transformer at MWTS is a technically feasible option. However, fault level constraints would make such a solution costly to implement.
4. Installation of Power Factor Correction Capacitors: As the station is currently running with a power factor of around 0.99 at the summer peak, the use of additional capacitors to further improve the power factor and to reduce the MVA loading on the transformers will provide only marginal benefits.
5. Load transfers: Only 5 MVA of load can be shifted away from MWTS using the existing 22 kV distribution network, so this option does not make a material contribution to managing the risk at MWTS.

Preferred network option for alleviation of constraints

In view of the current level of expected unserved energy and the slight decline expected in demand at MWTS over the next 10 years, implementing a network solution is not considered to be economic over the ten-year planning horizon.

The table on the following page provides more detailed information on the station rating, demand forecasts, energy at risk and expected unserved energy assuming embedded generation is contributing 60 MVA.

⁷⁷ <https://ausnetservices.com.au/About/Projects-and-Innovation/Regulatory-Investment-Test>

MORWELL TERMINAL STATION 66kV (MWTS 66)**Detailed data: Magnitude and probability of loss of load**

Distribution Businesses supplied by this station:

AusNet Electricity Services (100%)

Normal cyclic rating with all plant in service

Summer N-1 Station Rating

Winter N-1 Station Rating

544 MVA via 3 transformers and embedded generation

395 MVA via 2 transformers and embedded generation

474 MVA via 2 transformers and embedded generation

Station: MWTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	392.3	390.0	386.4	382.7	379.7	376.7	373.7	371.2	370.2	371.2
50th percentile Winter Maximum Demand (MVA)	382.8	383.6	384.5	385.4	386.0	386.4	386.8	387.5	388.6	389.4
10th percentile Summer Maximum Demand (MVA)	451.9	449.8	446.5	442.9	440.2	437.4	434.7	432.4	431.7	433.0
10th percentile Winter Maximum Demand (MVA)	389.6	390.4	391.4	392.3	393.0	393.4	393.8	394.5	395.7	396.4
N - 1 energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N - 1 hours at risk at 50th percentile demand (hours)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
N - 1 energy at risk at 10th percentile demand (MWh)	430	397	347	297	260	224	191	166	158	172
N - 1 hours at risk at 10th percentile demand (hours)	17.1	16.6	15.7	14.8	14.1	13.2	12.3	11.5	11.2	11.7
N and N-1 Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
N and N-1 Expected Unserved Energy at 10th percentile demand (MWh)	2.8	2.6	2.3	2.0	1.7	1.5	1.3	1.1	1.0	1.1
N and N-1 Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M
N and N-1 Expected Unserved Energy value at 10th percentile demand	\$0.12M	\$0.11M	\$0.09M	\$0.08M	\$0.07M	\$0.06M	\$0.05M	\$0.04M	\$0.04M	\$0.05M
N and N-1 Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.03M	\$0.03M	\$0.03M	\$0.02M	\$0.02M	\$0.02M	\$0.02M	\$0.01M	\$0.01M	\$0.01M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The summer rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

MOUNT BEAUTY TERMINAL STATION 66 kV (MBTS 66 kV)

Mt Beauty Terminal Station (MBTS) is the main point of connection into the 220 kV electricity grid for Victoria's Kiewa hydro generation resources. The power stations include West Kiewa, McKay, Dartmouth, Clover and Eildon. MBTS is also the source of 66 kV supply for the alpine areas of Mt Hotham and Falls Creek along with the townships of Bright, Myrtleford and Mount Beauty.

The station has two 50 MVA 220/66 kV transformers with one transformer in service and the other available as a hot spare that can be brought into service in approximately 4 hours. With this transformer operating arrangement, the N rating will be equal to the "N-1" rating (i.e. equal to the capacity of one transformer). In addition, supply can also be taken from Clover Power Station and the 66 kV tie to Glenrowan Terminal Station via Myrtleford.


It is AusNet Electricity Services' responsibility to plan the electricity supply network for this region.

Magnitude, probability and impact of loss of load

MBTS is a winter peaking station with the peak demand on the MBTS 66 kV bus forecast to remain flat for the next 10 years. Peak demand at the station reached 47.9 MVA in winter 2012. The recorded peak demand in winter 2019 was 44.7 MW (45.3 MVA), which remains lower than the 2012 peak demand. The station load has a power factor of 0.99 at maximum demand. The demand at MBTS 66 kV is expected to exceed 95% of the 50th percentile peak demand for approximately 4 hours per annum. The summer peak demand is marginally lower than the winter peak demand.

The graph below depicts the 10th and 50th percentile winter maximum demand forecast together with the station's operational "N-1" rating (equal to "N" rating) at an ambient temperature of 5°C. With demand forecast to remain flat, MBTS 66 kV is not expected to reach its "N-1" winter station rating during the 10 year planning horizon.

MBTS 66 kV Winter Peak Demand Forecasts



The above analysis does not include the possibility of loss of load for the short period of about 4 hours that it takes to change over from the in-service transformer to the hot spare transformer. The 66 kV tie line to Glenrowan Terminal Station can support about 25 MW of MBTS load and this tie

line is operated normally closed so if the load is below this limit there will not be any loss of customer load during a transformer outage. Clover Power Station can generate around 26 MW and so any generation would also minimise the likelihood of the loss of customer load during a transformer outage.

It is recognised that at times of high demand, and with low output from Clover Power Station, a transformer outage at MBTS could result in the loss of some customer load for a short period of no more than 4 hours.

The energy at risk for a major transformer outage⁷⁸ in this situation (taking account of the limited 66 kV tie line capability) is significant at around 2,762 MWh in winter 2020. However, given that the hot spare transformer can be made available within 4 hours, the expected outage duration in the case of a major transformer failure at MBTS is 4 hours (rather than 2.65 months). Accordingly, the probability of the transformer being unavailable in this particular case is only 0.000457%. The expected unserved energy at MBTS is therefore approximately 0.013 MWh in 2019 and this is estimated to have a value to consumers of approximately \$458 (based on a value of customer reliability of \$36,288/MWh).

Full switching of the hot spare transformer with new 220 kV and 66 kV circuit breakers would eliminate this risk but this is estimated to cost around \$2 million. The expected benefits of full switching of the hot spare transformer does not economically justify the cost of the project within the ten year planning horizon.

⁷⁸ In this report, "major transformer outage" means an outage that has a mean duration of 2.65 months.

RED CLIFFS TERMINAL STATION (RCTS) 22 kV


Red Cliffs Terminal Station (RCTS) 22 kV consists of two 35 MVA 235/66/22 kV transformers supplying the 22 kV network ex-RCTS. An additional 140 MVA 235/66/22 kV transformer operates normally open on the 22 kV bus with an auto-close scheme to close this transformer onto the 22 kV bus in the event of a failure of either of the other two transformers. This configuration is the main source of supply for 4497 customers in Red Cliffs and the surrounding area. The station supply area includes Red Cliffs, Colignan and Werrimull.

The peak load for the RCTS 22 kV network reached 38.7 MVA in summer 2020. It is estimated that:

- For 9 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station transformer power factor at the peak time demand is 0.93 with both capacitor banks in service.

In the event of a failure of either of the 35 MVA transformers, both 35 MVA transformers will be switched out and the 140 MVA 235/66/22 kV transformer (which operates normally open on the 22 kV bus) will be automatically closed onto the 22 kV bus. There will be a momentary supply interruption during this process. The 140 MVA 235/66/22 kV transformer can also be closed onto the 22 kV bus in the event that load exceeds 55 MVA (22 kV dropper rating), with the two 35 MVA transformers being switched out to maintain fault levels below the 13.1 kA limit. This arrangement results in the station's "N-1" capacity being higher than the "N" capacity.

RCTS 22 kV demand is summer peaking. The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating and the "N-1" rating at 35°C ambient temperature. The RTS 22 kV station N rating was increased to 55 MVA following the uprating of the 22 kV droppers by AusNet Transmission Group in 2016.



The graph shows there is sufficient capacity at the station to supply all expected load at the 50th and 10th percentile temperatures over the forecast period, even with one transformer out of service. Under 10th percentile forecast conditions, there is a small amount of load at risk from 2027 onwards, which can be managed by utilising load transfers away to adjacent zone substations. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

RED CLIFFS TERMINAL STATION (RCTS) 66 kV

Red Cliffs Terminal Station (RCTS) 66 kV consists of two 70 MVA and one 140 MVA 235/66/22 kV transformers supplying the 66 kV network ex-RCTS. This configuration is the main source of supply for 22,096 customers in Red Cliffs and the surrounding area. The station supply area includes Merbein, Mildura and Robinvale.

Magnitude, probability and impact of loss of load

RCTS 66 kV demand is summer peaking. The maximum demand (load) for the 66 kV network now supplied from the station reached 136.8 MW in summer 2020. Due to the input of generation connected to the station, reverse power flows occur during low load periods. The minimum demand (export) at RCTS 66 reached -44.9 MW (48.9 MVA) in August 2019.


As noted in section 3.2.1 of this report, the connection of significant embedded generation to networks supplied from some terminal stations is expected to lead to reverse power flows that may necessitate a reduction in the ratings of some stations. RCTS 66 kV is one such station. In advance of AusNet Transmission Services completing its review of ratings at stations affected by reverse power flows, this risk assessment adopts the conservative assumption that from 2019 the station rating of RCTS 66 kV is reduced from cyclic to nameplate. This reduction is shown in the graph below.

The following risk assessment is based on forecast maximum demand (load) and station nameplate ratings.

It is estimated that:


- For 10 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station power factor at the time of maximum demand (load) is 0.96.
- The station power factor at the time of minimum demand (export) is -0.92.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.



The (N) rating on the above chart indicates the maximum load that can be supplied from RCTS with all transformers in service. Exceeding this level will initiate automatic load shedding by AusNet Transmission Group's automatic load shedding scheme.

The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile demand forecast, and the hours per year that the 50th percentile demand forecast is expected to exceed the N-1 capability rating. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.



Comments on Energy at Risk

For a major outage of one transformer at RCTS 66 kV during the summer period, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 62 hours in 2030. The energy at risk at the 50th percentile temperature under N-1 conditions is estimated to be 683 MWh in 2030. The estimated value to consumers of the 683 MWh of energy at risk is approximately \$28.5 million (based on a value of customer reliability of \$41,764 /MWh).⁷⁹ In other words, at the 50th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at RCTS 66 kV in 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers approximately \$28.5 million.

It is emphasised however, that the probability of a major outage of one of the two transformers occurring over the year is very low at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (683 MWh for 2030) is weighted by this low unavailability, the expected unsupplied energy is estimated to be around 4.4 MWh. This expected unserved energy is estimated to

⁷⁹ The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

have a value to consumers of around \$185,400 (based on a value of customer reliability of \$41,764/MWh).

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) summer temperatures occurring in each year. Under 10th percentile temperature conditions, the energy at risk in 2030 is estimated to be 1,933 MWh. The estimated value to consumers of this energy at risk in 2030 is approximately \$80.7 million. The corresponding value of the expected unserved energy (of 12.6 MWh) is approximately \$525,000.

These key statistics for the year 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	683	\$28.5 million
Expected unserved energy at 50 th percentile demand	4.4	\$185,400
Energy at risk, at 10 th percentile demand forecast	1,933	\$80.7 million
Expected unserved energy at 10 th percentile demand	12.6	\$525,000

Possible impacts of a transformer outage on customers

If one of the transformers at RCTS 66 kV is taken off line during peak loading times and the N-1 station rating is exceeded, the OSSCA⁸⁰ automatic load shedding scheme which is operated by AusNet Transmission Group's TOC⁸¹ will act swiftly to reduce the loads in blocks to within safe loading limits. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with Powercor's operational procedures after the operation of the OSSCA scheme.

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or alleviate the emerging constraint over the next ten year planning horizon:

1. Embedded generation: A new solar farm (Karadoc Solar Farm (KSF) has been commissioned in 2019 and is generating into the 66 kV infrastructure with a capacity of 90 MW and will be able to help supply the loads in the RCTS supply area, and may defer the need for any capacity augmentation within the forecast period. Yatpool Solar Farm (YSF) is due to be commissioned in 2020 and will add another 81 MW.
2. Possible uptake of battery storage in the future could provide some contribution to supporting the peak load.

⁸⁰ Overload Shedding Scheme of Connection Asset.

⁸¹ Transmission Operation Centre.

3. A contingency plan to transfer RVL zone substation from RCTS to WETS (~25 MVA) will be implemented in the event of the loss of one of the RCTS 220/66 kV transformers.
4. Subject to availability, an AusNet Transmission Group spare 220/66 kV transformer for rural areas (refer to Section 5.5) can be used to temporarily replace a failed transformer to minimise the transformer outage period.

Preferred option(s) for alleviation of constraints

As already noted, a contingency plan to transfer RVL zone substation from RCTS to WETS (~25 MVA) will be implemented in the event of the loss of one of the RCTS 220/66 kV transformers. In addition, generation output from the new solar farms YSF and KSF may help supply the loads at RCTS if required.

The level of expected unserved energy over the forecast period suggests that installation of additional capacity at RCTS 66 kV is unlikely to be economically justified during the forecast period. The contingency plan described above will provide an effective means of mitigating load at risk over the ten year planning horizon.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

Red Cliffs Terminal Station 66 kV

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: Powercor (100%)

Nameplate rating with all plant in service 280 MVA via 2 transformers (Summer peaking)

Summer N-1 Station Rating: 140 MVA [See Note 1 below for interpretation of N-1]

Winter N-1 Station Rating: 140 MVA

Station: RCTS66	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	133.4	142.2	145.8	148.5	149.1	153.3	152.7	158.6	166.4	170.9
50th percentile Winter Maximum Demand (MVA)	92.3	99.0	100.7	101.6	103.1	105.2	107.9	111.4	115.6	120.4
10th percentile Summer Maximum Demand (MVA)	146.3	152.3	155.9	159.4	159.6	164.1	168.4	174.5	182.7	184.1
10th percentile Winter Maximum Demand (MVA)	104.7	110.0	111.9	113.8	114.4	116.7	119.7	123.1	127.4	133.7
N-1 energy at risk at 50th percentile demand (MWh)	0.0	1.0	7.0	18.5	22.4	63.9	57.7	163.2	433.4	683.0
N-1 hours at risk at 50th percentile demand (hours)	0.0	0.8	3.0	5.5	6.0	13.0	12.0	22.5	45.5	62.0
N-1 energy at risk at 10th percentile demand (MWh)	8.7	52.5	106.1	182.1	189.2	336.0	536.0	933.5	1707.9	1932.9
N-1 hours at risk at 10th percentile demand (hours)	3.3	11.3	17.0	24.0	24.8	37.3	52.3	77.3	120.5	129.5
Expected Unserved Energy at 50th percentile demand (MWh)	0.000	0.01	0.05	0.12	0.15	0.42	0.37	1.06	2.82	4.44
Expected Unserved Energy at 10th percentile demand (MWh)	0.06	0.34	0.69	1.18	1.23	2.18	3.48	6.07	11.10	12.56
Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.01M	\$0.01M	\$0.02M	\$0.02M	\$0.04M	\$0.12M	\$0.19M
Expected Unserved Energy value at 10th percentile demand	\$0.00M	\$0.01M	\$0.03M	\$0.05M	\$0.05M	\$0.09M	\$0.15M	\$0.25M	\$0.46M	\$0.52M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.00M	\$0.00M	\$0.01M	\$0.02M	\$0.02M	\$0.04M	\$0.05M	\$0.11M	\$0.22M	\$0.29M

Notes:

1. "N-1" means nameplate station transformer output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.6 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the sector values given in Table 1 of Section 2.4, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

RICHMOND TERMINAL STATION 22 kV (RTS 22 kV)


RTS 22 kV is a summer critical station equipped with two 75 MVA 220/22 kV transformers, providing supply to 6,286 customers in CitiPower's distribution network. The terminal station's supply area includes inner suburban areas in Richmond and Melbourne City's Russell Place and surrounding areas. The station also provides supply to City Link and public transport railway substations east of the Central Business District.

As part of AusNet Transmission Group's asset renewal program, the two existing 220/22 kV transformers were replaced by two new 75 MVA 220/22 kV transformers in 2018. The N and N-1 station rating have subsequently changed to approximately 190 MVA and 95 MVA respectively. This is reflected in the graph below.

The peak load on the station reached 43.0 MW in summer 2020. It is estimated that:

- For 4 hours per year, 95% of peak demand is expected to be reached under the 50th percentile summer forecast.
- The station load power factor at time of peak demand is 0.98.

The graph below depicts the latest 10% and 50% probability maximum demand forecasts for summer over the next 10 years, together with the operational N and N-1 ratings for RTS 22 kV. The demand forecasts include the effects of committed future load transfer works. RTS 22 kV load reductions (approximately 25 MVA) in 2014 and 2015 are due to load transfers to RTS 66 kV as part of the Prahran (PR22) Zone Substation de-commissioning process.



The graph shows there is sufficient station capacity to supply all anticipated load, and that no customers would be at risk if a forced transformer outage occurred at RTS 22 kV over the forecast period. Accordingly, no capacity augmentation is planned at RTS 22 kV over the next ten years.

RICHMOND TERMINAL STATION 66 kV (RTS 66 kV)


RTS 66 kV is a summer critical station consisting of three 225 MVA 220/66 kV transformers. The terminal station is shared by CitiPower (89%) and United Energy (11%), providing supply to a total of 155,197 customers in the Eastern Central Business District and widespread inner suburban areas in the east and south-east of Melbourne. In 2018 AusNet Transmission Group completed an asset replacement project at RTS, which involved replacing the ageing five existing 150 MVA transformers with three 225 MVA transformers. The peak load on the station reached 561.7 MW in summer 2020.

It is estimated that:

- For 4 hours per year, 95% of peak demand is expected to be reached in a 50th percentile summer.
- The station load power factor at time of peak demand is 0.99.

RTS 66 is one of the terminal stations supplying the Melbourne CBD. In order to meet the code requirements of security of supply to the Melbourne CBD, CitiPower has been undertaking works to re-configure the CBD 66 kV network to provide the required security to maintain supply from alternate supply points. This means that for an 'N-1' event in other parts of the CBD network, additional load can be switched onto RTS 66. This required additional capacity must be reserved at the terminal station to ensure that CBD load can be supplied under any of the CBD Security contingency arrangements.

The following graph shows recent actual demand at the station, and the forecast demand from 2021 to 2031. The station's (N) and (N-1) ratings at 35 degrees C are also shown.



In September 2020, MP zone substation was transferred from RTS 66 to BTS which removed the load at risk at RTS 66 until 2029 when the 10th percentile demand forecast reaches the N-1 rating and at this point load transfers will be used to manage any load at risk. Therefore, the need for further augmentation of capacity at RTS 66 kV is not expected to arise over the next ten years.

RINGWOOD TERMINAL STATION 22 kV (RWTS 22 kV)

Ringwood Terminal Station provides supply at two voltage levels - 66 kV and 22 kV. RWTS 22 kV is supplied by two 75 MVA 220/22 kV three-phase transformers. RWTS 22 kV is the main source of 22 kV supply for the local area and for the commuter railway network.


The geographic coverage of the station's supply area includes Ringwood, Mitcham, Wantirna and Nunawading. The electricity distribution networks for this area are the responsibility of both AusNet Electricity Services (68%) and United Energy Distribution (32%).

Peak demand at the station occurs in summer. Summer peak demand at RWTS 22 kV is forecast to grow slightly over the ten year planning period. The 2019/20 summer peak demand reached 88.7 MW (89.7 MVA), whereas the highest recorded peak demand is 96.2 MVA, which occurred in summer 2008/09. Demand at RWTS 22 kV is expected to exceed 95% of the 50th percentile peak demand for 3 hours per annum. The station load has a power factor of 0.99 at maximum demand but load on the transformers has a power factor of 1.0 if all the 22 kV capacitors are switched in at the station.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's expected operational "N" rating (all transformers in service) and the "N-1" rating at an ambient temperature of 35°C.

The graph indicates that the summer maximum demand at RWTS 22 kV remains below its "N" and "N-1" ratings within the 10 year planning period. Similarly, the winter demand at RWTS 22 kV is not expected to reach the station's "N" or "N-1" winter rating during the ten year planning horizon.

RWTS 22 kV Summer Peak Demand Forecasts



With no forecast risk in the planning horizon, there is no augmentation planned in the next ten years and any risk will be managed through load transfers or other cost-effective operational action.

RINGWOOD TERMINAL STATION 66 kV (RWTS 66 kV)

Ringwood Terminal Station is the main source of supply for a major part of the outer eastern metropolitan area. The geographic coverage of the station's supply area spans from Lilydale and Woori Yallock in the north east; to Croydon, Bayswater and Boronia in the east; and Box Hill, Nunawading and Ringwood to the west.

The electricity supply distribution networks for this region are the responsibility of both AusNet Electricity Services (76%) and United Energy (24%).

Background

Ringwood Terminal Station provides supply at two voltage levels - 66 kV and 22 kV. RWTS 66 kV is supplied by four 150 MVA 220/66 kV transformers and peak demand occurs in summer.

In March 2016 the B2 transformer at RWTS failed. It was replaced in August 2016 by one of the metropolitan spare transformers. AusNet Transmission Group also replaced the No. 4 220/66 kV transformer with a new 150 MVA unit in July 2018.

The existing four transformers are operated in two separate bus groups to limit the maximum fault currents on the 66 kV buses to within their respective switchgear ratings. Under network normal configuration, the No. 1 and No. 2 transformers are operated in parallel as one group (RWTS bus group 1-3) and supply the No.1 and No. 3 66 kV buses respectively. The No. 3 and No. 4 transformers are operated in parallel as another group (RWTS bus group 2-4) and supply the No.2 and No. 4 66 kV buses respectively. To configure the station as two separate bus groups, the 66 kV bus 1-2 and bus 3-4 tie circuit breakers are operated normally open.

Given this configuration, load demand on the RWTS bus groups 1-3 and 2-4 must be kept within the capabilities of their respective two transformers at all times otherwise load shedding may occur. For an unplanned transformer outage in any of the two RWTS bus groups, an auto close scheme will operate resulting in parallel operation of the three remaining transformers.

In late-2020, AusNet Transmission Group reviewed and updated the cyclic ratings of the RWTS transformers. This review resulted in:

- for RWTS bus group 1-3, an increased "N" summer cyclic (35°C) rating of 341 MVA, up from 326 MVA.
- for RWTS bus group 2-4, an increased "N" summer cyclic rating (35°C) of 355 MVA, up from 338 MVA.
- for RWTS 66 kV total station, an increased "N-1" summer cyclic rating (35°C) of 520 MVA, up from 498 MVA.

These increased cyclic ratings are a result of a changing transformer load profiles driven by increased distributed energy resources (DER) reducing station loading during the day.

Combined Summer Peak Demand forecasts for RWTS 66 kV - Total Station Demand


The peak demand on the station reached a record of 508 MW (516 MVA) in summer 2008/09 under extreme weather conditions. The recorded peak demand in summer 2019/20 was 482.4 MW (492.5 MVA), which was lower than the summer 2008/09 station peak demand. The station load has a power factor of 0.98 at maximum demand but the load on the

transformers has a power factor of 1 due to installed 66 kV capacitor banks. RWTS 66 kV demand is expected to exceed 95% of the 50th percentile peak demand for 7 hours per annum.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's expected operational "N" rating (all transformers in service) and the "N-1" rating at 35°C as well as 40°C ambient temperatures.

The graph indicates that the demand at RWTS 66 kV remains below its N rating throughout the 10-year planning period. The 50th percentile summer peak demand is also not expected to exceed the station's N-1 rating. However, the 10th percentile summer peak demand is forecast to exceed the station's N-1 rating from summer 2020/20 through to 2022/23 before demand declines below the rating.

The combined winter demand at RWTS 66 kV is not expected to reach the station's "N-1" winter rating during the ten year planning horizon.




RWTS Bus groups 1-3 and 2-4: Summer Peak Demand Forecasts

In addition to considering the station's total summer demand under "N-1" conditions as shown above, it is essential to assess the risk of load shedding on the individual bus groups when both of their respective transformers are in service, i.e. under "N" conditions.

RWTS Bus group 1-3: Peak demand at RWTS 66 kV bus group 1-3 occurs in summer. Based on the individual summer demand forecasts for this bus group, with both transformers in service, i.e. under "N" conditions, the demand on this bus group is forecast to remain within the 10th and 50th percentile demands. When required, such as if demand exceeds the 10th percentile level, 22 kV load transfers would be utilised to manage system normal loading to within the terminal station's limits.

This bus group supplies United Energy's zone substations Nunawading (NW) and Box Hill (BH), and AusNet Electricity Services' zone substations Ringwood North (RWN), Lilydale (LDL), Chrinside Park (CPK) and Woori Yallock (WYK).


The graph below depicts the 10th and 50th percentile summer maximum demand forecasts together with the bus group 1-3 "N" rating at an ambient temperature of 35°C and 40°C.



RWTS Bus group 2-4: Similar to bus group 1-3, the peak demand at RWTS 66 kV bus group 2-4 also occurs in summer. Based on the individual summer demand forecasts for this bus group, with both transformers in service, i.e. under "N" conditions, the demand on this bus group at the 50th or 10th percentile temperature is forecast to remain within its "N" rating throughout the ten year planning horizon. This means that there is no expectation of load shedding or load transfers being required to keep loading within plant ratings on this bus group under normal operating conditions during summer or winter.

This bus group supplies AusNet Electricity Services' zone substations Boronia (BRA), Croydon (CYN) and Bayswater (BWR).

The graph below depicts the 10th and 50th percentile summer maximum demand forecasts together with the bus group 2-4 rating at an ambient temperature of 35°C and 40°C.



Comments on Energy at Risk

RWTS 66 kV is a summer peaking station and most of the energy at risk occurs in the summer period because in addition to higher summer demand, the rating of the transformers is lower at higher ambient temperatures. Additionally, the bulk of the energy at risk at RWTS 66 kV is under system normal conditions on the No.1-3 bus group. For these reasons, the comments below focus on both the post-contingency energy at risk for the entire station and the pre-contingent energy at risk on the No.1-3 bus group over the summer period.

Based on the latest demand forecast bus group No.1-3 has no pre-contingent energy at risk over the 10-year period.

For an outage of one 220/66 kV transformer at RWTS, the No. 1-3 and No. 2-4 bus groups will be tied and supplied by the three remaining in-service transformers. With a transformer out of service there will be sufficient capacity at the station to supply all demand at the 50th percentile temperature for the ten-year forecast period. At the 10th percentile temperature, for an outage of one 220/66 kV transformer at RWTS, there will be a minor amount of load at risk in 2020/21 and this risk will be reduced as demand declines throughout the planning horizon.

Feasible options for alleviation of constraints

The following options are technically feasible and may be economic to mitigate any risk of supply interruption and/or to alleviate the emerging constraints.

1. Implement emergency plans to transfer load to adjacent terminal stations: Both AusNet Electricity Services and United Energy have plans to enable load transfers under emergency conditions via emergency 66 kV ties, and via 22 kV feeders under system normal conditions, to the adjacent East Rowville and Templestowe terminal stations. The 22 kV feeders have a transfer capability of approximately 55 MVA. When required, such as if demand exceeding a 10th percentile temperature day is anticipated, the 22 kV load transfers would be utilised to manage system normal loading to within the terminal station's limits until augmentation is economically justified. The emergency 66 kV ties

from RWTS 66 kV can be in operation within a few hours and have a transfer capability of approximately 50 MVA each.

2. Rebalance loads: Bus group 1-3 carries around 60% of the station's load and has a slightly lower rating. Rebalancing loads across the two bus groups may be feasible and could be implemented to manage the "N" loading on bus group 1-3. AusNet Electricity Services and United Energy will continue to jointly investigate the feasibility of load rebalancing options as demand changes over time, to rebalance loads in the most efficient manner.
3. Rebalance transformer capacity: Since bus group 1-3 carries around 60% of the station's load but has a slightly lower rating, swapping the bus connections of the B4 transformer and the B1 transformer may be a feasible option and could be implemented to manage the "N" loading on bus group 1-3. Together with AusNet Transmission Group, AusNet Electricity Services and United Energy will jointly investigate the feasibility of swapping transformer bus connections to manage the split bus group loadings.
4. Install an additional 50 MVAR 66 kV capacitor bank: RWTS currently has two 50 MVAR 66 kV capacitor banks on 66 kV bus number 2 of the 2-4 bus group, and the station operates with a power factor around 0.98 lagging in summer. An additional 50 MVAR 66 kV capacitor bank on bus group 1-3 will help to reduce the net MVA supplied by the transformers by approximately 10.1 MVA.
5. Relocate the existing 2B 50 MVAR 66 kV capacitor bank: As already noted, RWTS currently has two 50 MVAR 66 kV capacitor banks on 66 kV bus number 2 of the 2-4 bus group. With the 10th percentile loading on bus group 1-3 forecast to be higher than bus group 2-4, moving one of the existing capacitor banks from the 2-4 bus group to the 1-3 bus group will reduce the net load supplied by the 1-3 bus group transformers by approximately 6.8 MVA. While moving a capacitor bank will help to manage the "N" loading, it will not further help manage the N-1 loading.
6. Install a 5th 220/66 kV transformer at Ringwood Terminal Station: The site has provision for a 5th transformer however it will require relocation of the existing capacitor banks to free up an appropriate location for the new transformer, thereby adding to the option cost.
7. Demand Management: United Energy and AusNet Electricity Services have developed a number of innovative network tariffs that encourage voluntary demand reduction during times of network constraints. The amount of demand reduction depends on the tariff uptake and the subsequent change in the load pattern, and will be taken into consideration when determining the optimum timing for a capacity augmentation.
8. Embedded Generation: Embedded generation could help reduce network loading.

Preferred network option for alleviation of constraints

The preferred option to manage the energy at risk at the station is to rebalance loads across the two 66 kV bus groups, as identified in Option 2. AusNet Electricity Services and United Energy will jointly identify the works required to rebalance loads in the most efficient way, following which the cost and optimal timing of the required works will be established.

AusNet Services and United Energy will continue to monitor loading on at RWTS and take appropriate action as required. Prior to implementing any augmentation option it is proposed to implement the following temporary measures to cater for rare but possible high system normal loading or an unplanned outage of one of the transformers at RWTS under critical loading conditions:

- maintain 22 kV feeder contingency plans to transfer load to adjacent terminal stations. The 22 kV feeders have a transfer capability out of the RWTS of approximately 55 MVA, which can be used to manage system normal loading if required;
- enable load transfers under contingency conditions via emergency 66 kV ties to the adjacent East Rowville and Templestowe terminal stations, respectively. The emergency 66 kV ties from RWTS 66 kV can be in operation within a few hours and have a transfer capability of approximately 50 MVA each;
- subject to availability, a spare 220/66 kV transformer for metropolitan areas (refer Section 5.5) can be used to temporarily replace a failed transformer.

The tables on the following pages provide more detailed data on the station and bus group 1-3 ratings, demand forecasts, energy at risk and expected unserved energy estimates.

RINGWOOD TERMINAL STATION 66kV (RWTS 66)**Detailed data: Magnitude and probability of loss of load**

Distribution Businesses supplied by this station:

Normal cyclic rating with all plant in service

Summer N-1 Station Rating (MVA):

Winter N-1 Station Rating (MVA):

AusNet Electricity Services (76%), United Energy (24%)

696 MVA via 4 transformers (Summer peaking)

520 MVA [See Note 1 below for interpretation of N-1]

588 MVA

Station: RWTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	456.3	453.5	450.8	445.6	441.3	438.1	434.1	429.6	426.7	427.1
50th percentile Winter Maximum Demand (MVA)	342.2	343.9	345.5	345.1	344.6	344.1	344.0	344.5	345.8	348.3
10th percentile Summer Maximum Demand (MVA)	506.6	504.0	501.6	497.2	493.4	490.9	487.5	483.3	480.9	481.8
10th percentile Winter Maximum Demand (MVA)	349.7	351.5	353.2	352.9	352.5	352.2	352.2	352.7	354.1	356.7
N - 1 energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N - 1 hours at risk at 50th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
N - 1 energy at risk at 10th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N - 1 hours at risk at 10th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy at 10th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M
Expected Unserved Energy value at 10th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an summer ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

RINGWOOD TERMINAL STATION 66kV Bus group 1-3 (RWTS 66)**Detailed data: Magnitude and probability of loss of load**

Distribution Businesses supplied by this station:

Normal cyclic rating with all plant in service

Normal cyclic rating with all plant in service

AusNet Electricity Services (76%), United Energy (24%)

341 MVA via 2 transformers (Summer 50%POE peaking)

330 MVA via 2 transformers (Summer 10%POE peaking)

Station: RWTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	280.2	279.8	279.8	277.0	275.5	275.0	273.5	271.3	269.7	269.9
50th percentile Winter Maximum Demand (MVA)	203.3	206.1	208.6	209.2	209.7	210.0	210.5	211.1	212.1	213.6
10th percentile Summer Maximum Demand (MVA)	310.6	310.4	310.7	308.6	307.7	307.8	306.8	304.8	303.7	304.3
10th percentile Winter Maximum Demand (MVA)	207.0	209.9	212.5	213.1	213.7	214.1	214.7	215.5	216.5	218.1
N energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N hours at risk at 50th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
N energy at risk at 10th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N hours at risk at 10th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy at 10th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy value at 50th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M
Expected Unserved Energy value at 10th percentile demand	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.00M

Notes:

1. "N" means cyclic station output capability rating with all transformers in service. The rating is at a summer ambient temperature of 35 degrees Centigrade.
2. "N energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N capability rating.
3. "N hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N capability rating.
4. "Expected unserved energy" equals "energy at risk" under "N" conditions.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

SHEPPARTON TERMINAL STATION (SHTS) 66 kV


Shepparton Terminal Station (SHTS) 66 kV consists of three 150 MVA 220/66 kV transformers and is the main source of supply for over 73,085 customers in Shepparton and the Goulburn–Murray area. The station supply area includes the towns of Shepparton, Echuca, Mooroopna, Yarrawonga, Kyabram, Cobram, Numurkah, Tatura, Rochester, Nathalia, Tongala, and Rushworth.

Demand at SHTS is summer peaking. Growth in summer peak demand at SHTS has averaged around 2.10 MVA (0.9%) per annum over the last 5 years. Peak load on the station in the summer of 2020 reached 284.3 MVA.

It is estimated that:

- For 12 hours per year, 95% of peak demand is expected to be reached under the 50th percentile forecast.
- The station load power factor at the time of peak demand is 0.98.

The chart below depicts the 10th and 50th percentile summer maximum demand forecast together with the station operational “N” rating (all transformers in service) and the “N-1” rating at 35°C ambient temperature.



The chart shows there is sufficient capacity at the station to supply all expected demand at the 50th and 10th percentile temperature, over the forecast period even with one transformer out of service. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

SOUTH MORANG TERMINAL STATION (SMTS 66 kV)

Background


A 220/66 kV connection station with two 220/66 kV 225 MVA transformers was established at the existing South Morang Terminal Station (SMTS) site in 2008. The re-arrangement of 66 kV loops with the establishment of SMTS resulted in the 160 MW Somerton Power Station being connected to the SMTS 66 kV bus.

The geographic coverage of the area supplied by the new connection assets at SMTS spans from Seymour, Kilmore, Kalkallo, Kinglake and Rubicon in the north to Mill Park in the south and from Doreen and Mernda in the east to Somerton and Craigieburn in the west. The electricity distribution networks for this area are the responsibility of both AusNet Electricity Services (71%) and Jemena Electricity Networks (29%).

SMTS 66 kV is a summer peaking station. The recorded peak demand in summer 2019/20 was 372.3 MW (381.7 MVA), which is the historical maximum for the station. The station load has a power factor of 0.98 at maximum demand. Demand is expected to exceed 95% of the 50th percentile peak demand for 4 hours per annum.

Magnitude, probability and impact of loss of load

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C as well as 40°C ambient temperatures.




The "N" rating on the above chart indicates the maximum load that can be supplied from SMTS with both transformers in service.

With the projected growth in customer demand in the area, it is expected that SMTS will continue to exceed its "N-1" rating in summer at the 50th percentile and 10th percentile summer demand forecasts, as shown in the graph above.


In the winter, the rating of the transformers is higher than the summer rating due to lower ambient temperatures. Thus, energy at risk during the winter period is generally lower than the summer period. The graph below demonstrates the 10th and the 50th percentile winter maximum demand forecast together with the station's operational "N" rating and "N-1" rating. SMTS is expected to remain within its "N-1" rating under both 50th percentile and 10th percentile winter maximum demand forecasts for the 10-year planning horizon.

SMTS 66 kV Winter Peak Demand Forecasts



The bar chart below depicts the energy at risk over the winter and summer periods with one transformer out of service for the 50th percentile demand forecast, and the hours each year that the 50th percentile demand forecast is expected to exceed the "N-1" station capability. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.

Annual Energy and Hours at Risk at SMTS 66 (Single Contingency Only)



As already noted, SMTS 66 kV is a summer peaking station and the energy at risk occurs in the summer period because the rating of the transformers is lower at higher ambient temperatures in addition to higher summer demand. The comments below therefore focus on the energy at risk over the summer period.

Comments on Energy at Risk assuming Somerton Power Station is unavailable

Assuming that Somerton Power Station is unavailable, then for an outage of one transformer at SMTS over the entire summer period, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 143 hours in summer 2029/30. The energy at risk at the 50th percentile temperature under “N-1” conditions is estimated to be 3,892 MWh in summer 2029/30. The estimated value to consumers of the 3,892 MWh of energy at risk is approximately \$135 million (based on a value of customer reliability of \$34,778 MWh)⁸². In other words, at the 50th percentile demand level, without any contribution from embedded generation and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at SMTS in summer 2029/30 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$135 million.

It is emphasised however, that the probability of a major outage of one of the two transformers occurring over the year is very low, at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (3,892 MWh) is weighted by this low transformer unavailability, the expected unserved energy is estimated to be around 17.2 MWh. This expected unserved energy is estimated to have a value to consumers of around \$0.60 million (based on a value of customer reliability of \$34,778/MWh).

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) temperatures occurring each year. Under higher temperature conditions (that is, at the 10th percentile level), the energy at risk in 2029/30 summer is estimated to be 7,868 MWh. The estimated value to consumers of the energy at risk in 2029/30 summer is approximately \$174 million. The corresponding value of the expected unserved energy (of 34.7 MWh) is approximately \$1.2 million.

These key statistics for the summer of 2029/30 under “N-1” outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	3,892	\$135 million
Expected unserved energy at 50 th percentile demand	17.2	\$0.60 million
Energy at risk, at 10 th percentile demand forecast	7,867	\$174 million
Expected unserved energy at 10 th percentile demand	37.7	\$1.2 million

⁸² The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

If one of the 220/66 kV transformers at SMTS is taken off line during peak loading times and the “N-1” station rating is exceeded, then the Overload Shedding Scheme for Connection Assets (OSSCA), which is operated by AusNet Transmission Group’s TOC⁸³ to protect the connection assets from overloading⁸⁴, will act swiftly to reduce the loads in blocks to within safe loading limits. In the event of OSSCA operating, it would automatically shed up to 130 MVA of load, affecting approximately 53,000 customers in 2020/21. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at feeder level in accordance with AusNet Electricity Services and Jemena’s operational procedures after the operation of the OSSCA scheme.

Comments on Energy at Risk assuming Somerton Power Station is available

The previous comments on energy at risk are based on the assumption that there is no embedded generation available to offset the 220/66 kV transformer loading. The Somerton Power Station (SPS) is capable of generating up to 160 MW and this generation is connected to the SMTS 66 kV bus via the SMTS-ST-SSS-SMTS 66 kV loop. There is no firm commitment that generation will be available to offset transformer loading at SMTS; however it is most likely that the times of peak demand at SMTS will coincide with periods of high wholesale electricity prices, resulting in a high likelihood that SPS will be generating. If SPS is generating to its full capacity there would be no energy at risk at SMTS over the ten year planning horizon for both the 50th and 10th percentile summer maximum demand forecast.

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of a supply interruption and/or to alleviate the emerging capacity constraints:

1. Implement contingency plans to transfer load to adjacent terminal stations. AusNet Electricity Services has established and implemented the necessary plans that enable up to 20 MVA of load transfers via existing 22 kV feeders to adjoining zone substations. Jemena has plans and the capability to transfer an additional 13 MVA. This option is able to partly reduce the interruption duration and load at risk resulting from a major transformer failure.
2. Install a third 225 MVA 220/66 kV transformer at South Morang Terminal Station (SMTS), which would also require the installation of fault limiting reactors.
3. Demand Management. AusNet Electricity Services is currently using an MVA tariff to encourage large customers to improve their power factor as well as a critical peak pricing tariff to encourage them to reduce load at peak demand times and thus reduce the station loading. Up to 50% of the maximum demand at SMTS 66 kV is expected to be summer residential load, consisting largely of air conditioning load. With the existing load mix it is likely that demand reduction initiatives can play a limited role in reducing the peak summer load at SMTS 66 kV.
4. Embedded Generation. As mentioned above, the Somerton power station is connected to SMTS. A network support agreement with SPS or other generators connected to the SMTS 66 kV bus will help to defer the need for network augmentation.

⁸³ Transmission Operation Centre.

⁸⁴ OSSCA is designed to protect connection transformers against transformer damage caused by overloads. Damaged transformers can take months to repair or replace which can result in prolonged, long term risks to the reliability of customer supply.

Preferred network option for alleviation of constraints

1. In the event that there are no firm commitments by interested parties to offer network support services by installing local generation or through demand side management initiatives that would reduce future load at SMTS 66 kV; it will be proposed to install a new third 220/66 kV transformer at SMTS 66 kV. The capital cost of this option is estimated at \$22 million, which includes the cost of installing three fault limiting reactors. This equates to a total annual cost of approximately \$1.6 million per annum. Under the latest demand forecast, the installation of the third transformer at SMTS would not be economically justified in the forecast period.
2. Implement the following temporary measures to cater for an unplanned outage of one transformer at SMTS under critical loading conditions until the new 220/66 kV transformer is commissioned:
 - maintain contingency plans to transfer load quickly to adjacent terminal stations;
 - rely on Somerton Power Station (SPS) generation to reduce loading at SMTS 66 kV, and investigate the option of formalising a network support agreement with SPS;
 - fine-tune the OSSCA scheme settings in conjunction with TOC to minimise the impact on customers of any load shedding that may take place to protect the connection assets from overloading; and
 - subject to availability, one of AusNet Transmission Group's spare 220/66 kV transformers for the metropolitan area (refer Section 5.5) can be used to temporarily replace a failed transformer at SMTS. It is noted that AusNet Transmission Group currently has two 150 MVA spare transformers. Load sharing with a metro spare transformer will not be optimal, so the SMTS 66 kV capacity will be reduced under these emergency conditions.

The table on the following page provides more detailed data on the station rating, demand forecast, energy at risk and expected unserved energy assuming embedded generation is not available.

SOUTH MORANG TERMINAL STATION (SMTS 66 kV)**Detailed data: Magnitude and probability of loss of load**

Distribution Businesses supplied by this station:

AusNet Electricity Services (71%) Jemina Electricity Networks (29%)

Normal cyclic rating with all plant in service

530 MVA via 2 transformers (Summer peaking)

Summer N-1 Station Rating

265 MVA [See Note 1 below for interpretation of N-1]

Winter N-1 Station Rating

294 MVA

Station: SMTS 66 kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	347.9	350.7	352.2	352.9	353.7	354.3	356.0	357.8	360.5	364.3
50th percentile Winter Maximum Demand (MVA)	248.0	252.5	256.1	258.5	261.0	264.0	267.3	270.9	274.8	278.1
10th percentile Summer Maximum Demand (MVA)	378.1	381.3	383.3	384.1	385.1	386.7	388.2	390.7	393.8	397.6
10th percentile Winter Maximum Demand (MVA)	252.1	256.6	260.4	262.8	265.3	268.3	271.7	275.3	279.2	282.7
N - 1 energy at risk at 50th percentile demand (MWh)	2,283	2,521	2,653	2,718	2,787	2,844	3,004	3,182	3,463	3,892
N - 1 hours at risk at 50th percentile demand (hours)	100	106	109	111	113	115	119	124	132	143
N - 1 energy at risk at 10th percentile demand (MWh)	5,082	5,462	5,723	5,828	5,962	6,190	6,394	6,768	7,252	7,868
N - 1 hours at risk at 10th percentile demand (hours)	147	159	167	171	175	182	187	198	210	225
Expected Unserved Energy at 50th percentile demand (MWh)	10	11	12	12	12	13	13	14	15	17
Expected Unserved Energy at 10th percentile demand (MWh)	22	24	25	26	26	27	28	30	32	35
Expected Unserved Energy value at 50th percentile demand	\$0.35M	\$0.39M	\$0.41M	\$0.42M	\$0.43M	\$0.44M	\$0.46M	\$0.49M	\$0.53M	\$0.60M
Expected Unserved Energy value at 10th percentile demand	\$0.78M	\$0.84M	\$0.88M	\$0.90M	\$0.92M	\$0.95M	\$0.98M	\$1.04M	\$1.11M	\$1.21M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.48M	\$0.52M	\$0.55M	\$0.56M	\$0.57M	\$0.59M	\$0.62M	\$0.65M	\$0.71M	\$0.78M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The summer rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

SPRINGVALE TERMINAL STATION (SVTS)

Springvale Terminal Station (SVTS) is located in the south east of greater Melbourne. The geographic coverage of the station's supply area spans from Blackburn in the north to Noble Park in the south and from Wantirna South in the east to Riversdale in the west. The electricity supply network for this large region is split between United Energy (UE) and CitiPower (CP).

Background

SVTS has four 150 MVA 220/66 kV transformers and operates in a split bus arrangement. Under system normal conditions the No.1 & No.2 transformers (B1 & B2) are operated in parallel as one group (SVTS 1266) and supply the No.1 & No.2 buses. The No.3 & No.4 transformers (B3 & B4) are operated in parallel as a separate group (SVTS 3466) and supply the No.3 & No.4 buses. Connection between No.1 & No.4 buses is maintained via transfer buses No.5 & No.6. The 66 kV bus 2-3 and bus 4-5 tie circuit breakers are operated normally open to limit the fault levels on the 66 kV buses to within switchgear ratings. For an unplanned outage of any one of the four transformers, 66 kV bus 2-3 and bus 4-5 tie circuit breakers will close automatically and maintain the station in a 3-transformer closed loop arrangement. Given this configuration, the demand on the station will therefore need to be controlled as follows:

- Load demand on the SVTS 1266 group should be kept within the capabilities of the two transformers B1 & B2 at all times.
- Load demand on the SVTS 3466 group should be kept within the capabilities of the two transformers B3 & B4 at all times.
- Load demand on the total station should be kept within the capabilities of any three transformers when one transformer is out of service.

SVTS 66 kV is a summer critical terminal station. The station reached its highest recorded peak demand of 478 MW (491 MVA) in summer 2009 under extreme weather conditions. The peak demand in summer 2020 was 415.8 MW (423.9 MVA). Six embedded generation units (3 which operate only as a backup supply) over 1 MW are connected at SVTS 66 kV.⁸⁵

The magnitude, probability and load at risk for the two transformer groups are set out below.

SVTS 1266 (B12) Bus Group Summer Peak Forecasts


This bus group supplies Noble Park, Springvale South, Clarinda, Oakleigh East, Springvale and Springvale West zone substations owned by United Energy. Four generation units over 1 MW are connected at SVTS 1266 (B12) bus group.¹

The recorded peak demand in summer 2020 for the SVTS 1266 group was 221.8 MW (226.4 MVA). The load at SVTS 1266 (B12) is forecast to have a power factor of 0.980 at times of peak demand.

United Energy's new Keysborough zone substation was commissioned in 2014. Approximately 15 MW of demand was transferred away from SVTS to HTS. This load transfer is reflected in the graph below.

⁸⁵ The maximum demand forecasts adopted in this risk analysis exclude the impact of generation schemes.

The graph below depicts the 10th and 50th percentile summer maximum demand for SVTS 1266 and the corresponding rating with both transformers in service.




The graph above shows that with both transformers in service, there is adequate capacity to meet the anticipated maximum demand for the entire planning period.

SVTS 3466 (B34) Bus Group Summer Peak Forecasts

This bus group supplies East Burwood, Glen Waverley and Notting Hill zone substations owned by United Energy and Riversdale zone substation owned by CitiPower. Two generation units over 1 MW are connected at SVTS 3466 (B34) bus group.¹

The recorded peak demand in summer 2020 for the SVTS 3466 group was 197.4 MW (200.9 MVA). The load at SVTS 3466 (B34) is forecast to have a power factor of 0.982 at times of peak demand.

The graph below depicts the 10th and 50th percentile summer maximum demand for SVTS3466 and the corresponding rating with both transformers in service.



The graph above shows that with both transformers in service, there is adequate capacity to meet the anticipated maximum demand for the entire planning period.


SVTS Total Summer Peak Forecasts

The graph below depicts the 10th and 50th percentile total summer maximum demand forecasts together with the station's expected operational N rating (all transformers in service) and the (N-1) rating at 35°C as well as 40°C ambient temperature.

If one of the 220/66 kV transformers at SVTS is taken off line during peak loading times and the (N-1) station rating is exceeded, the OSSCA⁸⁶ load shedding scheme which is operated by AusNet Transmission Group's NOC⁸⁷ will act swiftly to reduce the loads in blocks to within safe loading limits. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with United Energy's and CitiPower's operational procedures after the operation of the OSSCA scheme.

⁸⁶ Overload Shedding Scheme of Connection Asset.

⁸⁷ Network Operations Centre.



The N rating on the graph indicates the maximum load that can be supplied from SVTS with all transformers in service. Exceeding this level will require load shedding or emergency load transfers to keep the terminal station operating within its limits.

The graph also indicates that the demand at SVTS 66 kV remains below its N-1 rating within the ten year planning period. Accordingly, no augmentation is planned at SVTS in the forward planning period.

The overall station load is forecast to have a power factor of 0.984 at times of peak demand. The demand at SVTS 66 kV is expected to exceed 95% of the peak demand for approximately 6 hours per annum. There is approximately 50.8 MVA of load transfer available at SVTS 66 kV for summer 2020/21.

SPRINGVALE TERMINAL STATION 66 kV

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: United Energy (95.3%) and CitiPower 4.7%)
Station operational rating (N elements in service): 673 MVA via 4 transformers (Summer peaking)
Summer N-1 Station Rating: 505 MVA [See Note 1 below for interpretation of N-1]
Winter N-1 Station Rating: 560 MVA

Station: SVTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	388	393	399	396	397	405	409	410	411	414
50th percentile Winter Maximum Demand (MVA)	306	314	322	322	324	324	326	328	331	335
10th percentile Summer Maximum Demand (MVA)	431	436	442	442	444	454	459	461	463	468
10th percentile Winter Maximum Demand (MVA)	312	320	327	329	330	331	333	335	338	343
N-1 energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N-1 hours at risk at 50th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
N-1 energy at risk at 10th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N-1 hours at risk at 10th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy at 10th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy value at 50th percentile demand	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k
Expected Unserved Energy value at 10th percentile demand	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k
Expected Unserved Energy value using AEMO weighting of 0.7 x 50th percentile value + 0.3 x 10th percentile value	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)


TEMPLESTOWE TERMINAL STATION (TSTS)

TSTS consists of three 150 MVA 220/66 kV transformers, and is the main source of supply for a major part of the north-eastern metropolitan area. The geographic coverage of the supply area spans from Eltham in the north to Canterbury in the south and from Donvale in the east to Kew in the west. The electricity supply network for this large region is split between United Energy, CitiPower, AusNet Electricity Services and Jemena Electricity Networks.

TSTS 66 kV is a summer critical terminal station. The station reached its highest recorded peak demand of 372.9 MW (386.2 MVA) in summer 2020. This eclipsed the previous peak set back in summer 2009 by 15.2 MW. There is one embedded generation unit over 1 MW connected at TSTS.⁸⁸

Magnitude, probability and impact of loss of load

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational N rating (all transformers in service) and the (N-1) rating at 35°C as well as 40°C ambient temperature.



The N rating on the chart indicates the maximum load that can be supplied from TSTS with all transformers in service. Exceeding this level will require load shedding or emergency load transfers to keep the terminal station operating within its limits.

The graph indicates that the overall demand at TSTS remains below its N rating within the 10 year planning period. The 50th percentile summer peak demand is not expected to exceed the station's (N-1) rating at 35°C within the 10 year planning period. However, the 10th percentile summer peak demand is forecast to exceed the station's (N-1) rating at 35°C and 40°C from summer 2021.

⁸⁸ The maximum demand forecasts adopted in this risk analysis exclude the impact of generation schemes.

The demand at TSTS 66 kV is expected to exceed 95% of the peak demand for approximately 3 hours per annum. The station load has a power factor of 0.973 at times of peak demand.

Comments on Energy at Risk

For an outage of one transformer at TSTS, it is expected that there would be insufficient capacity at the station to supply demand at the 10th percentile temperature from summer 2021 onwards.

By the end of the ten-year planning period in 2030, the energy at risk under N-1 conditions is 159 MWh at the 10th percentile demand forecast. Under these conditions, there would be insufficient capacity to meet demand for 8 hours in that year. The estimated value to customers of the 159 MWh of energy at risk in 2030 is approximately \$4.7 million (based on a value of customer reliability of \$29,619/MWh)⁸⁹. In other words, at the 10th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at TSTS over the summer of 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$4.7 million.

It is emphasised however, that the probability of a major outage of one of the three transformers occurring over the year is very low at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (159 MWh in 2030) is weighted by this low unavailability, the expected unserved energy is estimated to be around 1.0 MWh. This expected unserved energy is estimated to have a value to consumers of around \$31,000 (based on a value of customer reliability of \$29,619/MWh).

AusNet Transmission Group has indicated that two of the three transformers at TSTS have failure rates that are above average due to their condition. Therefore, the expected unserved energy calculated above may under-estimate the risk at this station. AusNet Transmission Group has evaluated the economic feasibility of replacing the old transformers at TSTS, and is currently undertaking a RIT-T. Based on the outcome of the Project Assessment Draft Report the preferred option is to replace the two transformers to address the asset failure risk, with the earliest delivery timing in 2024/25. The transformers will be replaced with 150 MVA transformers with no expected change to the station ratings. Given that AusNet Transmission Group plans to replace these transformers as part of its asset replacement program, the elevated failure rates are unlikely to advance any augmentation works at this terminal station.⁹⁰

The key statistics for the year 2030 under N-1 outage conditions are summarised in the table below.

⁸⁹ The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

⁹⁰ See link below for more details on Templestowe Terminal Station RIT-T:
<https://www.ausnetservices.com/en/About/Projects-and-Innovation/Regulatory-Investment-Test>

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	0	-
Expected unserved energy at 50 th percentile demand	0	-
Energy at risk, at 10 th percentile demand forecast	159	\$4.7 million
Expected unserved energy at 10 th percentile demand	1.0	\$31,000

If one of the 220/66 kV transformers at TSTS is taken off line during peak loading times and the (N-1) station rating is exceeded, the OSSCA⁹¹ load shedding scheme which is operated by AusNet Transmission Group's TOC⁹² will act swiftly to reduce the loads in blocks to within safe loading limits. Any load reductions that are in excess of the minimum amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with each distribution company's operational procedures after the operation of the OSSCA scheme.

In the case of TSTS supply at maximum loading periods, the OSSCA scheme would shed about 85 MW of load, affecting approximately 28,000 customers in 2021.

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

1. Implement a contingency plan to transfer load to adjacent terminal stations. United Energy, CitiPower, AusNet Electricity Services and Jemena Electricity Networks have established and implemented the necessary plans that enable load transfers under contingency conditions. These plans are reviewed annually prior to the summer season. The total transfer capability away from TSTS 66 kV onto adjacent terminal stations via the distribution network is assessed at 56 MVA for summer 2020-21.
2. Establish a new 220/66 kV terminal station. Two terminal station sites, one in Doncaster (DCTS) and another in Kew (KWTS), have been reserved for possible future electrical infrastructure development to meet customers' needs in the area. With established 220 kV tower lines to both sites, development of either of these sites could be economic depending upon the geographical location of additional customer load.
3. Install a fourth 150 MVA 220/66 kV transformers at TSTS. There is provision in the yard for an additional transformer.

The capital cost of installing a 220/66 kV transformer at TSTS 66 kV is estimated to be \$20 million. The estimated total annual cost of this network augmentation is approximately \$1.5 million.

On the present maximum demand forecasts, the fourth 220/66 kV transformer is not likely to be required within the ten year planning horizon.

⁹¹ Overload Shedding Scheme of Connection Asset.

⁹² Transmission Operations Centre.

Preferred network option(s) for alleviation of constraints

1. Implement the following temporary measures to cater for an unplanned outage of one transformer at TSTS under critical loading conditions:

- maintain contingency plans to transfer load quickly to adjacent terminal stations;
- fine-tune the OSSCA scheme settings in conjunction with TOC to minimise the impact on customers of any load shedding that may take place; and
- subject to availability, an AusNet Transmission Group spare 220/66 kV transformer for metropolitan areas (refer to Section 5.5) can be used to temporarily replace the failed transformer.

2. Install a fourth 150 MVA 220/66 kV transformers at TSTS.

In the absence of any commitment by interested parties to offer network support services by installing local generation or through demand side management initiatives that would reduce load at TSTS, it is proposed to install a fourth 220/66 kV transformer at TSTS. On the present forecasts, an additional 220/66 kV transformer is unlikely to be economic within the ten year planning horizon.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

TEMPLESTOWE TERMINAL STATION 66 kV

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: United Energy (41%), CitiPower (30%), SPI Electricity (21%), Jemena (8%)
Station operational rating (N elements in service): 549 MVA via 3 transformers (Summer peaking)
Summer N-1 Station Rating: 366 MVA [See Note 1 below for interpretation of N-1]
Winter N-1 Station Rating: 417 MVA

Station: TSTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	334	336	337	335	336	340	344	349	353	362
50th percentile Winter Maximum Demand (MVA)	238	241	244	246	249	252	256	261	268	276
10th percentile Summer Maximum Demand (MVA)	373	375	376	376	377	382	387	393	398	407
10th percentile Winter Maximum Demand (MVA)	244	247	250	252	254	258	263	268	275	283
N-1 energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N-1 hours at risk at 50th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
N-1 energy at risk at 10th percentile demand (MWh)	18	24	27	23	26	42	57	76	105	159
N-1 hours at risk at 10th percentile demand (hours)	3	3	3	3	3	3	4	5	7	8
Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy at 10th percentile demand (MWh)	0.1	0.2	0.2	0.2	0.2	0.3	0.4	0.5	0.7	1.0
Expected Unserved Energy value at 50th percentile demand	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k
Expected Unserved Energy value at 10th percentile demand	\$3.6k	\$4.7k	\$5.3k	\$4.6k	\$5.1k	\$8.1k	\$11.2k	\$14.7k	\$20.4k	\$31.1k
Expected Unserved Energy value using AEMO weighting of 0.7 x 50th percentile value + 0.3 x 10th percentile value	\$1.1k	\$1.4k	\$1.6k	\$1.4k	\$1.5k	\$2.4k	\$3.4k	\$4.4k	\$6.1k	\$9.3k

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. For 50th percentile value, the rating is at an ambient temperature of 35 degrees Centigrade. For 10th percentile value, the rating is at an ambient temperature of 40 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

TERANG TERMINAL STATION (TGTS) 66kV

Terang Terminal Station (TGTS) 66 kV consists of one 125 MVA transformer and one 150 MVA 220/66 kV transformer and is the main source of supply for over 78,427 customers in Terang and the surrounding area. The terminal station supply area includes Terang, Colac, Camperdown, Cobden, Warrnambool, Koroit, Portland and Hamilton.

Magnitude, probability and impact of loss of load

There is now 317 MW of wind generation capacity connected to the 66 kV network supplied from TGTS. The TGTS demand forecast used in this year's report includes a forecast of wind farm generation at peak demand. As noted in section 3.2.1 of this report, the connection of significant embedded generation to networks supplied from some terminal stations is expected to lead to reverse power flows that may necessitate a reduction in the ratings of some stations. TGTS 66 kV is one such station. In advance of AusNet Transmission Services completing its review of TGTS 66 kV ratings, this risk assessment adopts the conservative assumption that from 2019 the station rating of TGTS 66 kV is reduced from cyclic to nameplate. This reduction is shown in the graph below.


TGTS 66 kV demand for the past 5 years has been winter peaking but peaks can occur in summer or spring (depending upon the dairy industry load and the impact of wind farms connected to the 66 kV network). The metered station maximum demand (load) reached 157 MW (158 MVA) in 2019 winter. Due to the input from generation connected to the station, reverse power flows occur during low load periods. The recorded minimum demand (export) reached -71 MW (103.5 MVA) in March 2020 as shown in the graph.

The following risk assessment is based on forecast maximum demand (load) and station nameplate ratings.

It is estimated that:


- For 4 hours per year, 95% of peak demand is expected to be reached under the 50th percentile forecast.
- The station load power factor at the time of peak demand is 0.99.
- The station load power factor at the time of minimum demand is -0.69.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature.



The (N) rating on the chart indicates the maximum load that can be supplied from TGTS with all transformers in service.

The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile demand forecast, and the hours per year that the 50th percentile demand forecast is expected to exceed the N-1 capability rating. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.



Comments on Energy at Risk

For an outage of one transformer at TGTS, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 91.3 hours in 2030. The energy at risk at the 50th percentile temperature under N-1 conditions is estimated to be 827.4 MWh in 2030. The estimated value to consumers of the 827.4 MWh of energy at risk is approximately \$28.2 million (based on a value of customer reliability of \$ 34,026 per MWh).⁹³ In other words, at the 50th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at TGTS in 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$28.2 million.

It is emphasised however, that the probability of a major outage of one of the two transformers occurring over the year is very low at about 1.0% per transformer per annum, while the expected unavailability per transformer per annum is 0.221%. When the energy at risk (827.4 MWh for 2030) is weighted by this low unavailability, the expected unsupplied energy is estimated to be 3.6 MWh. This expected unserved energy is estimated to have a value to consumers of around \$122,000 (based on a value of customer reliability of \$34,026 MWh).

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) summer temperatures occurring in each year. Under 10th percentile temperature conditions, the energy at risk in 2030 is estimated to be 5,838 MWh. The estimated value to consumers of this energy at risk in 2030 is approximately \$199 million. The corresponding value of the expected unserved energy (of 25.3 MWh) is \$0.9 million.

Key statistics relating to energy at risk and expected unserved energy for the year 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	827.4	\$28.2 million
Expected unserved energy at 50 th percentile demand	3.6	\$122,000
Energy at risk, at 10 th percentile demand forecast	5,838	\$199 million
Expected unserved energy at 10 th percentile demand	25.3	\$0.9 million

Feasible options for alleviation of constraints

The following options are technically feasible and potentially economic to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

1. Replacing the #2 125 MVA 220/66 kV transformer at TGTS with a 150 MVA unit. For an indicative installation cost of \$14 million this option will most likely prove to be

⁹³ The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

uneconomic as it only provides a marginal increase in station capacity, hence necessitating additional capacity augmentation shortly afterwards.

2. Installation of a third 220/66 kV transformer (150 MVA) at TGTS at an indicative capital cost of \$18 million.
3. Demand reduction: There is an opportunity to develop a number of innovative customer schemes to encourage voluntary demand reduction during times of network constraint. The amount of demand reduction would depend on the customer uptake and would be taken into consideration when determining the optimum timing for any future capacity augmentation.
4. Embedded generation: Four existing wind farms (Codrington, Yambuk, Oaklands Hill and Mortons Lane) generate into the 66 kV infrastructure ex-TGTS with a total capacity of 131 MW. There are two committed wind farms, Salt Creek wind farm (54 MW) and Mt Gellibrand wind farm (132 MW), which have been commissioned in 2019 and will contribute generation into the 66 kV infrastructure ex-TGTS. Additional wind generation is being investigated in the area supplied by TGTS and this may defer any capacity augmentation planned for TGTS.
5. There are presently several large embedded generation 66 kV wind farm proposals in the area which may drive the need for an additional 150 MVA 220/66 kV transformer at TGTS to accommodate the reverse power flow expected at TGTS.
6. Possible uptake of battery storage in the future could provide some contribution to supporting the peak load.

Preferred option(s) for alleviation of constraints

In the absence of any commitment by interested parties to offer network support services by installing local generation or through demand side management initiatives that would reduce load at TGTS, it is proposed to:

1. Install a third 220/66 kV transformer (150 MVA) at TGTS at an indicative capital cost of \$18 million. This equates to a total annual cost of approximately \$1.33 million per annum. On the basis of the medium economic growth scenario and both 50th and 10th percentile weather probability, the transformer would not be expected to be required before 2030 to support the critical peak demand.
2. As a temporary measure, maintain contingency plans to transfer load quickly to the Geelong Terminal Station (GTS) by the use of the 66 kV tie lines between TGTS and GTS in the event of an unplanned outage of one transformer at TGTS under critical loading conditions. This load transfer is in the order of 15 MVA. Under these temporary measures, affected customers would be supplied from the 66 kV tie line infrastructure on a radial network, thereby reducing their level of reliability.
3. Subject to availability, an AusNet Transmission Group spare 220/66 kV transformer for rural areas (refer Section 5.5) can be used to temporarily replace a failed transformer to minimise the transformer outage period.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

TGTS Terminal Station

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: Powercor (100%)

Nameplate rating with all plant in service MVA
 275 via 2 transformers (summer)
Summer N-1 Station Rating: 125 [See Note 1 below for interpretation of N-1]
Winter N-1 Station Rating: 125

Station: TGTS	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	167.8	168.7	169.6	167.8	172.7	165.9	165.8	170.2	168.3	166.3
50th percentile Winter Maximum Demand (MVA)	149.1	149.8	150.1	151.5	151.4	152.7	153.2	153.3	155.4	151.3
10th percentile Summer Maximum Demand (MVA)	212.9	204.4	207.6	211.4	206.9	202.7	209.2	205.9	211.1	200.2
10th percentile Winter Maximum Demand (MVA)	172.8	173.8	175.4	176.7	174.9	176.5	178.1	176.9	178.7	174.7
N-1 energy at risk at 50% percentile demand (MWh)	825.1	887.5	944.5	900.2	1156.6	854.7	869.8	1084.4	1076.4	827.4
N-1 hours at risk at 50th percentile demand (hours)	89.0	93.5	97.5	96.5	111.8	93.5	95.0	109.5	110.5	91.3
N-1 energy at risk at 10% percentile demand (MWh)	8110.5	6458.6	7290.6	8270.9	7087.2	6515.0	8006.5	7167.5	8502.5	5838.1
N-1 hours at risk at 10th percentile demand (hours)	496.0	425.0	466.5	513.3	456.0	434.0	505.0	465.3	528.5	397.8
Expected Unserved Energy at 50th percentile demand (MWh)	3.58	3.85	4.09	3.90	5.01	3.70	3.77	4.70	4.66	3.59
Expected Unserved Energy at 10th percentile demand (MWh)	35.15	27.99	31.59	35.84	30.71	28.23	34.69	31.06	36.84	25.30
Expected Unserved Energy value at 50th percentile demand	\$0.12M	\$0.13M	\$0.14M	\$0.13M	\$0.17M	\$0.13M	\$0.13M	\$0.16M	\$0.16M	\$0.12M
Expected Unserved Energy value at 10th percentile demand	\$1.20M	\$0.95M	\$1.07M	\$1.22M	\$1.04M	\$0.96M	\$1.18M	\$1.06M	\$1.25M	\$0.86M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.44M	\$0.38M	\$0.42M	\$0.46M	\$0.43M	\$0.38M	\$0.44M	\$0.43M	\$0.49M	\$0.34M

Notes:

1. "N-1" means nameplate station output capability rating with outage of one transformer. The winter rating is at an ambient temperature of 5 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which specified demand forecast exceeds the N-1 capability rating.
3. "N-1 hours at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating.
4. "Expected unserved energy" means "N-1 energy at risk" for the specified demand forecast multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with a duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

THOMASTOWN TERMINAL STATION 66 kV (TTS 66 kV)

Thomastown Terminal Station (TTS) is located in the north of greater Melbourne. It operates at 220/66 kV and supplies Jemena Electricity Networks and AusNet Electricity Services customers in the Thomastown, Coburg, Preston, Watsonia, North Heidelberg, Lalor, Coolaroo and Broadmeadows areas.

Background


TTS has five 150 MVA transformers and is a summer critical station. Under system normal conditions, the No.1 & No.2 transformers are operated in parallel as one group (TTS(B12)) and supply the No.1 & No.2 66 kV buses. The No.3, No.4 & No.5 transformers are operated in parallel as a separate group (TTS(B34)) and supply the No.3 & No.4 66 kV buses. The 66 kV bus 2-3 and bus 1-4 tie circuit breakers are operated open to limit the maximum prospective fault levels on the four 66 kV busses to within the switchgear ratings.

For an unplanned transformer outage in the TTS(B12) group, the No.5 transformer will automatically change over to the TTS(B12) group. Therefore, an unplanned transformer outage of any one of the five transformers at TTS will result in both the TTS(B12) & TTS(B34) groups being comprised of two transformers each. Given this configuration, load demand on the TTS(B12) group must be kept within the capabilities of the two transformers at all times or load shedding may occur.

Transformer group TTS (B12) Summer Peak Forecasts

The graph below depicts the summer maximum demand forecasts (for 50th and 10th percentile temperatures) for TTS (B12) and the corresponding rating with both transformers (B1 & B2) operating. It is estimated that:

- For 7 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at the time of peak demand is 0.98.




The graph shows that with all transformers in service, there is adequate capacity to meet the anticipated maximum load demand for the entire forecast period. As explained above, if an unplanned transformer outage in the TTS(B12) group occurs, the No.5 transformer will automatically change over to the TTS(B12) group. In effect then, the N-1 and N ratings of the TTS(B12) group are equivalent. Thus there is sufficient capacity provided by the TTS(B12) group to meet the anticipated maximum demand for the entire forecast period, even under a transformer outage condition.

Transformer group TTS (B34) Summer Peak Forecasts

The graph below depicts the TTS (B34) rating with all transformers (B3, B4 & B5) in service ("N" rating), and with one of the three transformers out of service ("N-1" rating), along with the 50th and 10th percentile summer maximum demand forecasts. It is estimated that:

- For 5 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at the time of peak demand is 0.96.



The above graph shows that there is adequate TTS (B34) capacity to meet the anticipated maximum load demand for the entire forecast period.

Hence, the need for augmentation of transmission connection assets at TTS 66 kV is not expected to arise over the next ten years.

TYABB TERMINAL STATION (TBTS)

TBTS consists of three 150 MVA 220/66 kV transformers, and is the main source of supply for over 119,000 customers on the Mornington Peninsula. The geographic coverage of the area spans from Frankston South in the north to Portsea in the south.

TBTS 66 kV is a summer critical station. Summer peak demand at TBTS generally occurs on days of high ambient temperature during the summer holiday period (from mid-December to the end of January). Given the peak demand at TBTS is directly related to air-conditioning use during the summer holiday period along the coastal belt of the Mornington Peninsula, the peak is very sensitive to the maximum ambient temperature at this time. The station reached 263.7 MW (269 MVA) in summer 2019-20, which was 39.1 MW lower than the 2017-18 maximum demand which was the highest historic peak demand. There are two embedded generation units over 1 MW connected at TBTS and 11 generation units providing 11 MW network support for the lower Mornington Peninsula sub-transmission constraints.⁹⁴

Due to increasing risk at TBTS, a Regulatory Test was undertaken in 2011, which identified the installation of a third 150 MVA 220/66 kV transformer as the most economic network solution. A new third transformer was installed at TBTS and commissioned in November 2013 as shown in the graph below.

Magnitude, probability and impact of loss of load


The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational N rating (all transformers in service) and the N-1 rating at 35°C as well as 40°C ambient temperature.

The N rating on the chart below indicates the maximum load that can be supplied from TBTS with all transformers in service. Exceeding this level will initiate AusNet Transmission Group's automatic load shedding scheme.

The graph indicates that the demand at TBTS remains below its N rating within the 10 year planning period. However, the 10th percentile summer maximum demand is forecast to exceed the station's (N-1) rating at 40°C from summer 2026. The 50th percentile summer maximum demand is expected to remain within the (N-1) rating for the entire planning period.

The station load is forecast to have a power factor of 0.978 at times of peak demand. The demand at TBTS is expected to exceed 95% of peak demand for approximately 5 hours per annum.

⁹⁴ The maximum demand forecasts adopted in this risk analysis exclude the impact of generation schemes.



Comments on Energy at Risk

The graph above indicates that for an outage of one transformer at TBTS, it is expected that there would be sufficient capacity at the station to supply all demand at the 50th percentile temperature over the ten year forecast period.

However, for an outage of one transformer at TBTS, it is expected that from summer 2026, there would be insufficient capacity at the station to supply all demand at the 10th percentile temperature. By the end of the ten-year planning period in 2030, the energy at risk under N-1 conditions is 55 MWh at the 10th percentile demand forecast. Under these conditions, there would be insufficient capacity to meet demand for 5 hours in that year. The estimated value to customers of the 55 MWh of energy at risk in 2030 is approximately \$2.0 million (based on a value of customer reliability of \$35,561/MWh)⁹⁵. In other words, at the 10th percentile demand level, and in the absence of any other operational response that might be taken to mitigate the impact of a forced outage, a major outage of one transformer at TBTS over the summer of 2030 would be anticipated to lead to involuntary supply interruptions that would cost consumers \$2.0 million.

Typically, the probability of a major outage of a terminal station transformer occurring over the year is very low at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (55 MWh in 2030) is weighted by this low unavailability, the expected unserved energy is estimated to be around 0.4 MWh. This expected unserved energy is estimated to have a value to consumers of around \$12,900 (based on a value of customer reliability of \$35,561/MWh).

⁹⁵

The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.

These key statistics for the year 2030 under N-1 outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk, at 50 th percentile demand forecast	0.0	0
Expected unserved energy at 50 th percentile demand	0.0	0
Energy at risk, at 10 th percentile demand forecast	55	\$2.0 million
Expected unserved energy at 10 th percentile demand	0.3	\$12,900

Feasible options for alleviation of constraints

The following option is technically feasible and potentially economic to mitigate the risk of supply interruption and/or to alleviate the emerging constraint:

1. Implement a contingency plan to transfer load to adjacent terminal stations. United Energy has established and implemented the necessary plans that enable load transfers under contingency conditions, via both 66 kV sub-transmission and 22 kV distribution networks. These plans are reviewed annually prior to the summer season. Transfer capability away from TBTS 66 kV onto adjacent terminal stations via the distribution network is assessed at 16 MVA for summer 2021.

Given that the 50th percentile demand forecast is expected to remain below the N-1 rating of the station, no energy will be at risk for a single transformer outage based on the current 50th percentile demand forecast for the foreseeable future. The expected unserved energy under the 10th percentile demand forecast is also not significant over the ten year planning horizon. Moreover, the load at risk from summer 2026 can be managed operationally by transferring load under contingency via the distribution network.

On the basis of the current forecasts, no major demand related augmentation is planned at TBTS over the next ten years.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy.

TYABB TERMINAL STATION 66 kV

Detailed data: Magnitude and probability of loss of load

Distribution Businesses supplied by this station: United Energy (100%)
Station operational rating (N elements in service): 519 MVA (Summer peaking)
Summer N-1 Station Rating: 348 MVA [See Note 1 below for interpretation of N-1]
Winter N-1 Station Rating: 397MVA

Station: TBTS 66kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	283	288	295	296	299	308	314	317	319	323
50th percentile Winter Maximum Demand (MVA)	225	227	235	242	244	247	249	251	254	257
10th percentile Summer Maximum Demand (MVA)	316	322	330	331	334	344	350	354	357	361
10th percentile Winter Maximum Demand (MVA)	228	231	239	247	249	251	254	257	259	262
N-1 energy at risk at 50th percentile demand (MWh)	0	0	0	0	0	0	0	0	0	0
N-1 hours at risk at 50th percentile demand (hours)	0	0	0	0	0	0	0	0	0	0
N-1 energy at risk at 10th percentile demand (MWh)	0	0	0	0	0	5	19	28	38	55
N-1 hours at risk at 10th percentile demand (hours)	0	0	0	0	0	2	3	3	4	4
Expected Unserved Energy at 50th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Expected Unserved Energy at 10th percentile demand (MWh)	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.2	0.4
Expected Unserved Energy value at 50th percentile demand	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k
Expected Unserved Energy value at 10th percentile demand	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$1.2k	\$4.4k	\$6.6k	\$8.9k	\$12.9k
Expected Unserved Energy value using AEMO weighting of 0.7 x 50th percentile value + 0.3 x 10th percentile value	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.0k	\$0.4k	\$1.3k	\$2.0k	\$2.7k	\$3.9k

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4.
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) is in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)

WEMEN TERMINAL STATION (WETS)

Wemen Terminal Station (WETS) is a new station which was commissioned in February 2012. WETS consisted of one 70 MVA 235/66 kV transformer supplying part of the 66 kV network previously supplied by RCTS. An additional 70 MVA transformer was installed in 2018 increasing the N rating to 140 MVA. This configuration is the main source of supply for approximately 6,108 customers in the Wemen, Boundary Bend and Ouyen areas.

Magnitude, probability and impact of loss of load

WETS demand is summer peaking. The maximum demand (load) for the 66 kV network on the station reached 55.7 MW in summer 2020. Due to the input of generation connected to the station, reverse power flows occur during low load periods. The minimum demand (export) at WETS reached -141.3 MW (141.8 MVA) in September 2019.

The following risk assessment is based on forecast maximum demand (load) and station nameplate ratings.


It is estimated that:

- For 9 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at the time of maximum demand is 0.98.
- The station load power factor at the time of minimum demand is -0.99.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at 35°C ambient temperature. As WETS had only one transformer before the second transformer was installed in 2018, the "N-1" rating was zero until 2018/19. In 2018 Boundary Bend (BBD) zone substation was switched from RCTS to WETS while Robinvale (RVL) zone substation was switched from WETS to RCTS due to re-arrangement works on the 66 kV network in order to connect a new solar farm. As a result, WETS had a higher summer peak demand in 2019 than previous years as it is supplying BBD which has a higher demand than RVL.

As noted in section 3.2.1 of this report, the connection of significant embedded generation to networks supplied from some terminal stations is expected to lead to reverse power flows that may necessitate a reduction in the ratings of some stations. WETS 66 kV is one such station. The embedded generation includes two new solar farms that have been commissioned in 2019. Bannerton Solar Park (BSP) and Wemen Sun Farm (WSF) provide 88 MW and 86 MW respectively at peak.

In advance of AusNet Transmission Services completing its review of ratings at WETS 66 kV this risk assessment adopts the conservative assumption that from 2019 the station rating of WETS 66 kV is reduced from cyclic to nameplate. This reduction is shown in the graph below.



In order to mitigate the risk of generation curtailment of new solar farms in the area an additional 70 MVA transformer was installed on the WETS 66 kV system in 2018, as noted above. The transformer is running in hard parallel (banked) with the existing 70 MVA transformer (i.e. no additional 220 kV or 66 kV circuit breakers were installed). In the event of a transformer outage at WETS the generators will have to reduce generation to avoid overloading the remaining transformer. AEMO has a constraint equation managing the terminal station transformer reverse loading. The generators are sent dispatch signals to reduce generation if the constraint equation binds. Any generation reduction is implemented via AEMO's dispatch process. In addition, Powercor is currently working on a transformer overload protection scheme and this will be installed as a backup to the AEMO constraint equation.

There will be sufficient capacity at the station to supply all expected load demand at the 50th and 10th percentile temperature, over the forecast period, even with one transformer out of service. Therefore, the need for additional augmentation or other corrective action to supply load is not expected to arise over the next ten years. Additional generation, however, may require augmentation of transformer capacity, the cost of which would either be met by the connecting generator(s), or would be recovered from load customers where a RIT-T demonstrates that the augmentation delivers net market benefits.

WEST MELBOURNE TERMINAL STATION 22 kV (WMTS 22 kV)


WMTS 22 kV is a summer critical station consisting of two 165 MVA 220/22 kV transformers, which supplies 9,555 customers in CitiPower's distribution network. The terminal station provides major 22 kV supply to the West Melbourne area including Melbourne Docks, Docklands Areas, North Melbourne (including a railway substation), Parkville and Carlton, and the northern and western inner Central Business District and surrounding areas.

A new 66/11 kV zone substation (BQ) was established in 2011. BQ zone substation is now supplied via the newly established Brunswick Terminal Station (BTS 66 kV) and partly offloaded WMTS 22 kV over 2012 – 2014. Further offloads from WMTS 22 have occurred and will continue to occur to both BTS 66 and WMTS 66 over the next 6 years. These offloads are shown in the WMTS 22 load forecast below.

The peak load on the station reached 65 MW in summer 2019/20. It is estimated that:

- For 6 hours per year, 95% of peak demand is expected to be reached under the 50th percentile summer demand forecast.
- The station load power factor at the time of peak demand is 0.96.

The graph below depicts the station's operational N rating for all transformers in service and the N-1 rating (at 35 and 43 degrees ambient temperature), and the latest 10th and 50th percentile maximum demand forecasts for the next ten years. The N-1 ratings are restricted by over-voltage limits on transformer tapping.



The graph shows that there is sufficient capacity at the station to supply the forecast 50th and 10th percentile demands over the forecast period, even with one transformer out of service. It is planned that all WMTS 22kV load will be offloaded to WMTS 66kV and BTS 66kV before 2026. As part of its asset renewal program, AusNet Transmission Group plans to retire all of the existing WMTS 22 kV systems by the end of 2021, but negotiations are currently underway to defer retirement to enable supply to be provided to a major customer until 2025.

WEST MELBOURNE TERMINAL STATION 66 kV (WMTS 66 kV)

WMTS 66 kV is a summer critical station consisting of four 150 MVA 220/66 kV transformers. The terminal station is shared by CitiPower (77%) and Jemena Electricity Networks (23%). The terminal station provides major supply for 72,464 customers in the western Central Business District, including Docklands areas, as well as the inner suburbs of Northcote and Brunswick West in the north, and Kensington, Flemington, Footscray and Yarraville in the west.

WMTS 66 kV is operating with one of the four transformers on “Normal Open Auto-close” duty (i.e. on hot stand-by with a facility for automatic closing upon forced outage of any one of the three normal-running transformers). This arrangement facilitates control of the 66 kV fault level to within the terminal station fault level rating. With this transformer operating arrangement, the N rating will be approximately equal to the N-1 rating (i.e. equal to the capacity of three transformers), thus imposing a restriction that the terminal station should not be loaded beyond the N-1 rating at any time.

Following the extremely hot summer in 2009, AusNet Transmission Group expressed concern regarding the operating temperature of the WMTS 220/66 kV transformers. In order to avoid operating the WMTS transformers at temperatures that would result in accelerated aging, AusNet Transmission Group has reduced the WMTS Terminal Station summer cyclic ratings by about 5.5% to 497 MVA at 35°C ambient temperature and about 10% to 463 MVA at 43°C ambient temperature. As part of its asset renewal program, AusNet Transmission Group plans to replace all four existing 150 MVA 220/66 kV transformer units (B1, B2, B3 and B4) with three 225 MVA transformer units by the end of 2021. This will result in the forecast fault level remaining below the station rating at both West Melbourne 220 kV and 66 kV.

The peak load on the station reached 294.7 MW (301 MVA) in summer 2020.

It is estimated that:

- For 21 hours per year, 95% of peak demand is expected to be reached under the 50th percentile demand forecast.
- The station load power factor at time of peak demand is 0.98.

The graph below depicts:


- the station’s N-1 rating (approximately equal to the N rating) at 35°C and the new N and N-1 ratings with three new 225 MVA transformers which are to be commissioned by end of 2021; and
- the latest 10th and 50th percentile maximum demand forecasts during the summer periods over the next ten years.

The forecast demands include the effects of load transfer works⁹⁶ which were undertaken after the establishment of BTS 66 kV in late 2016. It also includes the further offloads⁹⁷ from WMTS 22 to WMTS 66 prior to the planned decommissioning of the 22 kV supply from WMTS, and new 66 kV supplies for Melbourne Metro Tunnel which will connect in 2021 (8 MVA) and gradually increase to 53 MVA by 2040.

⁹⁶ WA (52.7 MW), BQ (49.2 MW) and VM (42.0 MW) transfer from WMTS 66 to BTS 66 in late 2016.

⁹⁷ J (6.6 MW) transfer from WMTS 22 to WMTS 66 and TP (3.0 MW) from FBTS to WMTS 66 in 2020, VR (9.2 MW) and DA (23 MW) transfer from WMTS 22 to WMTS 66 within the next two years.

WMTS 66 is one of the terminal stations supplying the Melbourne CBD. In order to meet the code requirements of security of supply to the Melbourne CBD, CitiPower has been undertaking works to re-configure the CBD 66 kV network to provide the required security to maintain supply from alternate supply points. This means that for a 'N-1' event in other parts of the CBD network, additional load can be switched onto WMTS 66. This required additional capacity must be reserved at the terminal station to ensure that CBD load can be supplied under any of the CBD Security contingency arrangements



The graph shows that currently there is sufficient capacity at WMTS 66 kV to supply the forecast 10th percentile and 50th percentile demand over the planning period, even with one transformer out of service. Therefore, the need for augmentation or other corrective action is not expected to arise over the next ten years.

WODONGA TERMINAL STATION (WOTS 66 kV and 22 kV)

Wodonga Terminal Station is the main source of supply for a significant part of north-eastern Victoria. The supply is via two 330/66/22 kV three-winding transformers with a nominal rating of 75 MVA each.

This terminal station supplies Wodonga centrally as well as the area from Rutherglen in the west to Corryong in the east. The Hume Power Station (HPS) is connected to the WOTS 66 kV bus and can supply up to 58 MVA into the WOTS 66 kV bus, offsetting the load on the transformers.

AusNet Electricity Services is responsible for planning the transmission connection and distribution network for this region.


Magnitude, probability and impact of loss of load

WOTS is a summer peaking station and the combined 66 kV and 22 kV summer peak demand is forecast to remain flat for the next ten years. To accurately assess the transformer loading, the 66 kV and 22 kV loads need to be considered together because of the physical arrangement of the transformer windings.

The peak load on the station reached 107.4 MVA in summer 2008/09 but had a period of decline before recently flattening. The recorded peak demand in summer 2019/20 was 87.0 MW (87.8 MVA), which is in-line with the flat forecast. The demand at WOTS 66 kV and 22 kV is expected to exceed 95% of the 50th percentile peak demand for 4 hours per annum. The station load has a power factor of 0.99 at maximum demand and load on the transformers is further supported by 22 kV capacitor banks installed at the station.

The graph below depicts the 10th and 50th percentile summer maximum demand forecast together with the station's operational "N" rating (all transformers in service) and the "N-1" rating at an ambient temperature of 35°C.


WOTS 66 kV and 22 kV combined Summer Peak Demand Forecasts



The combined 66 kV and 22 kV load at WOTS is not expected to reach the “N” summer station rating within the 10 year planning horizon, but it presently exceeds the “N-1” rating at the 50th and 10th percentile summer demand level, and is forecast to continue to do so. Demand on the individual 66 kV and 22 kV windings is well within the ratings of the individual windings.

The combined 66 kV and 22 kV winter maximum demand at WOTS is less than the summer maximum demand and the station winter rating is higher than the summer rating. Forecast 50th and 10th percentile winter demand at WOTS 66 kV and 22 kV is not expected to exceed the “N -1” winter station rating in the next ten years.

The bar chart below depicts the energy at risk with one transformer out of service for the 50th percentile summer demand forecast, and the hours each year that the 50th percentile summer demand forecast is expected to exceed the “N-1” capability. The line graph shows the value to consumers of the expected unserved energy in each year, for the 50th percentile demand forecast.



Comments on Energy at Risk - Assuming HPS generation is not available

For a major outage of any one of the two 330/66/22 kV transformers at WOTS over the entire summer period, and assuming that Hume Power Station is unavailable, there will be insufficient capacity at the station to supply all demand at the 50th percentile temperature for about 15.1 hours in 2020/21, increasing slightly to 15.8 hours in summer 2029/30. The energy at risk under “N-1” conditions is forecast to increase from 32 MWh in 2020/20 to 35 MWh in summer 2029/30. The estimated value to consumers of the energy at risk in 2029/30 is approximately \$1.5 million (based on a value of customer reliability of \$43,392/MWh at WOTS)⁹⁸.

⁹⁸ The value of unserved energy is derived from the sector values given in Table 1 of Section 2.4, weighted in accordance with the composition of the load at this terminal station.

However the probability of a major outage of one of the two transformers occurring over the year is very low, at about 1.0% per transformer per annum, whilst the expected unavailability per transformer per annum is 0.221%. When the energy at risk (35 MWh for summer 2029/30) is weighted by this low unavailability, the expected unsupplied energy is estimated to be around 0.15 MWh. The corresponding value of expected unserved energy is approximately \$6,713.

It should also be noted that the above estimates of energy at risk and expected unserved energy are based on an assumption of average (50th percentile) summer temperatures occurring in each year. Under higher (10th percentile) summer temperature conditions, the energy at risk in 2029/30 is estimated to be 504 MWh. The estimated value to consumers of the energy at risk in 2029/30 is approximately \$21.9 million. The corresponding expected unserved energy at the 10th percentile demand forecast is 2.3 MWh, which has an estimated value to consumers of approximately \$0.1 million.

The key statistics for the year 2029/30 under “N-1” outage conditions are summarised in the table below.

	MWh	Valued at consumer interruption cost
Energy at risk at 50 th percentile demand forecast	35	\$1.5 million
Expected unserved energy at 50 th percentile demand	0.05	\$6,713
Energy at risk at 10 th percentile demand forecast	5.4	\$21.9 million
Expected unserved energy at 10 th percentile demand	2.3	\$0.1 million

If one of the 330/66/22 kV transformers at WOTS is taken off line during peak loading times and the “N-1” station rating is exceeded, then the Overload Shedding Scheme for Connection Assets (OSSCA) which is enabled by AusNet Transmission Group’s TOC⁹⁹ to protect the connection assets from overloading¹⁰⁰, will act swiftly to reduce the loads in blocks to within safe loading limits. If OSSCA operation does occur, any load reductions that are in excess of the amount required to limit load to the rated capability of the station would be restored at zone substation feeder level in accordance with AusNet Electricity Services’ operational procedures after the operation of the OSSCA scheme.

Comments on Energy at Risk - Assuming HPS generation is available

The previous comments on energy at risk are based on the assumption that there is no embedded generation available to offset the 330/66/22 kV transformer loading.

However, the generation from Hume Power Station (HPS) can be fed into the WOTS 66 kV bus. The power station is capable of generating up to 58 MVA. This generation can also be connected to TransGrid’s 132 kV network in New South Wales. The generation from HPS is dependent on water releases from Hume Dam for irrigation and the water level in the dam can vary widely from year to year. There is presently no

⁹⁹ Transmission Operation Centre.

¹⁰⁰ OSSCA is designed to protect connection transformers against damage caused by overloads. Damaged transformers can take months to repair or replace which can result in prolonged, long term risks to the reliability of customer supply.

guarantee that generation from HPS will be available to offset transformer loading at WOTS. With HPS generating to its full capacity there would be no energy at risk at WOTS over the ten year planning horizon for the 50th or 10th percentile summer maximum demand forecasts.

Feasible options for alleviation of constraints

The demand at WOTS has remained relatively flat in recent years, a trend that is forecast to continue over the 10-year planning horizon. It is important to continue to monitor the actual demand at WOTS, and if there is movement in forecast maximum demand in the future, appropriate action will be taken to manage the risk at the lowest cost to consumers.

The following are potentially feasible options for addressing constraints at this station.

1. Load transfers

Only 1 MVA of load can be shifted away from WOTS using the existing distribution network, so this option has limited ability to manage the risk at WOTS in the future.

2. Addition of Power Factor Correction Capacitors

The station is currently running with a power factor of around 0.99 at summer peak. At this power factor the use of additional capacitor banks to reduce the MVA loading would only provide marginal benefits.

3. Demand reduction

Over sixty percent of the peak demand is from Commercial and Industrial customers. AusNet Electricity Services may investigate demand management, through either special tariff incentives or a demand management aggregator, to assess these alternatives to network augmentation.

4. Embedded generation

As discussed above, subject to available water HPS can provide up to 58 MVA of network support to WOTS.

5. Fine tuning OSSCA

OSSCA scheme settings are reviewed annually to minimise the impact on customers of any load shedding that may take place to protect the connection assets from overloading.

It is noted that the two 330/66/22 kV transformers at WOTS are the only two of this voltage ratio in Victoria. AusNet Transmission Group does not have a spare transformer suitable for use at WOTS, so it is expected that it would take approximately 12 months to replace a failed transformer at WOTS.

Preferred network option for alleviation of constraints

In view of the current and forecast level of expected unserved energy at WOTS, implementation of a network solution is unlikely to be economic over the ten-year planning horizon.

The table on the following page provides more detailed data on the station rating, demand forecasts, energy at risk and expected unserved energy assuming embedded generation is not available.

WODONGA TERMINAL STATION 66kV and 22kV Loading (WOTS)**Detailed data: Magnitude and probability of loss of load**

Distribution Businesses supplied by this station:

AusNet Electricity Services (100%)

Normal cyclic rating with all plant in service

162 MVA via 2 transformers (Summer peaking)

Summer N-1 Station Rating

81 MVA [See Note 1 below for interpretation of N-1]

Winter N-1 Station Rating

87 MVA

Station: WOTS 66kV & 22kV	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
50th percentile Summer Maximum Demand (MVA)	87.9	87.9	87.7	87.5	87.4	87.4	87.3	87.3	87.5	88.1
50th percentile Winter Maximum Demand (MVA)	68.2	68.3	68.5	68.8	69.1	69.4	69.7	70.1	70.5	70.8
10th percentile Summer Maximum Demand (MVA)	95.0	95.1	94.9	94.7	94.7	94.7	94.6	94.7	94.9	95.5
10th percentile Winter Maximum Demand (MVA)	70.1	70.2	70.2	70.3	70.4	70.7	71.0	71.3	71.8	72.0
N - 1 energy at risk at 50th percentile demand (MWh)	32	33	30	26	25	25	24	24	27	35
N - 1 hours at risk at 50th percentile demand (hours)	15	15	14	13	13	13	12	13	13	16
N - 1 energy at risk at 10th percentile demand (MWh)	457	461	446	428	426	425	424	428	450	504
N - 1 hours at risk at 10th percentile demand (hours)	98	98	96	94	94	94	94	94	97	103
Expected Unserved Energy at 50th percentile demand (MWh)	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2
Expected Unserved Energy at 10th percentile demand (MWh)	2.0	2.0	2.0	1.9	1.9	1.9	1.9	1.9	2.0	2.2
Expected Unserved Energy value at 50th percentile demand	\$0.01M	\$0.01M	\$0.01M	\$0.01M	\$0.00M	\$0.00M	\$0.00M	\$0.00M	\$0.01M	\$0.01M
Expected Unserved Energy value at 10th percentile demand	\$0.09M	\$0.09M	\$0.09M	\$0.08M	\$0.08M	\$0.08M	\$0.08M	\$0.08M	\$0.09M	\$0.10M
Expected Unserved Energy value using AEMO weighting of 0.7 X 50th percentile value + 0.3 X 10th percentile value	\$0.03M	\$0.03M	\$0.03M	\$0.03M	\$0.03M	\$0.03M	\$0.03M	\$0.03M	\$0.03M	\$0.03M

Notes:

1. "N-1" means cyclic station output capability rating with outage of one transformer. The summer rating is at an ambient temperature of 35 degrees Centigrade.
2. "N-1 energy at risk" is the amount of energy in a year during which the specified demand forecast exceeds the N-1 capability rating. Energy at risk at the specified demand forecast when all plant is in service (N) is shown separately.
3. "N-1 hours per year at risk" is the number of hours in a year during which the specified demand forecast exceeds the N-1 capability rating. Hours at risk at the specified demand forecast when all plant is in service (N) are shown separately.
4. "Expected unserved energy" means "energy at risk" multiplied by the probability of a major outage affecting one transformer. "Major outage" means an outage with duration of 2.65 months. The outage probability is derived from the base reliability data given in Section 5.4
5. The value of unserved energy is derived from the relevant climate zone and sector VCR values given in the AER VCR December 2019 final determination, weighted in accordance with the composition of the load at this terminal station.
6. The 0.7 and 0.3 weightings applied to the 50th and 10th percentile expected unserved energy estimates (respectively) are in accordance with the approach applied by AEMO, and described on page 12 of its publication titled *Victorian Electricity Planning Approach*, published in June 2016 (see http://www.aemo.com.au/-/media/Files/Electricity/NEM/Planning_and_Forecasting/Victorian_Transmission/2016/Victorian-Electricity-Planning-Approach.ashx)